## SIEMENS

## Data sheet

## 6ES7315-2EH14-0AB0



SIMATIC S7-300 CPU 315-2 PN/DP, Central processing unit with 384 KB work memory, 1st interface MPI/DP 12 Mbit/s, 2nd interface Ethernet PROFINET, with 2-port switch, Micro Memory Card required

General information	
Product type designation	CPU 315-2 PN/DP
HW functional status	01
Firmware version	V3.2
Product function	
Isochronous mode	Yes; Via PROFIBUS DP or PROFINET interface
Engineering with	
<ul> <li>Programming package</li> </ul>	STEP 7 V5.5 or higher
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1 s
Input current	
Current consumption (rated value)	750 mA
Current consumption (in no-load operation), typ.	150 mA
Inrush current, typ.	4 A
l²t	1 A <sup>2</sup> ·s
Power loss	
Power loss, typ.	4.65 W
Memory	
Work memory	
<ul> <li>integrated</li> </ul>	384 kbyte
• expandable	No
Load memory	
• Plug-in (MMC)	Yes
<ul> <li>Plug-in (MMC), max.</li> </ul>	8 Mbyte
<ul> <li>Data management on MMC (after last programming), min.</li> </ul>	10 a
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
• without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.05 µs
for word operations, typ.	0.09 µs
for fixed point arithmetic, typ.	0.12 µs
for floating point arithmetic, typ.	0.45 µs

CPU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be
	reduced by the MMC used.
DB	
• Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
OB	
• Size, max.	64 kbyte
Number of free cycle OBs	1; OB 1
Number of time alarm OBs	1; OB 10
Number of delay alarm OBs	2; OB 20, 21
Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
Number of process alarm OBs	1; OB 40
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3; OB 55, 56, 57
<ul> <li>Number of isochronous mode OBs</li> </ul>	1; OB 61
Number of startup OBs	1; OB 100
<ul> <li>Number of asynchronous error OBs</li> </ul>	6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
<ul> <li>Number of synchronous error OBs</li> </ul>	2; OB 121, 122
Nesting depth	
<ul> <li>per priority class</li> </ul>	16
<ul> <li>additional within an error OB</li> </ul>	4
Counters, timers and their retentivity	
S7 counter	
Number	256
Retentivity	
— adjustable	Yes
— preset	Z 0 to Z 7
Counting range	20027
— adjustable	Yes
— lower limit	0
	999
— upper limit	222
IEC counter	No.
• present	Yes
•Туре	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	256
Retentivity	
— adjustable	Yes
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Туре	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte
	I LO NUYIC
Flag	2.049 http
• Size, max.	2 048 byte
Retentivity available	Yes; MB 0 to MB 2 047
Retentivity preset	MB 0 to MB 15
<ul> <li>Number of clock memories</li> </ul>	8; 1 memory byte
Data blocks	

<ul> <li>Retentivity adjustable</li> </ul>	Yes; via non-retain property on DB
Retentivity preset	Yes
Local data	
<ul> <li>per priority class, max.</li> </ul>	32 768 byte; Max. 2048 bytes per block
Address area	
I/O address area	
Inputs	2 048 byte
Outputs	2 048 byte
of which distributed	
— Inputs	2 048 byte
- Outputs	2 048 byte
Process image	
• Inputs	2 048 byte
Outputs	2 048 byte
<ul> <li>Inputs, adjustable</li> </ul>	2 048 byte
Outputs, adjustable	2 048 byte
Inputs, default	128 byte
Outputs, default	128 byte
Subprocess images	
Number of subprocess images, max.	1; With PROFINET IO, the length of the user data is limited to 1600 bytes
Digital channels	
Inputs	16 384
— of which central	1 024
Outputs	16 384
— of which central	1 024
Analog channels	
Inputs	1 024
— of which central	256
Outputs	1 024
— of which central	256
Hardware configuration	
Number of expansion units, max.	3
Number of DP masters	
integrated	1
• via CP	4
Number of operable FMs and CPs (recommended)	
• FM	8
	8
• CP, PtP	8 10
• CP, PtP • CP, LAN Rack	10
• CP, PtP • CP, LAN Rack • Racks, max.	
CP, PtP     CP, LAN Rack     Racks, max.     Modules per rack, max.	10
• CP, PtP • CP, LAN Rack • Racks, max.	10
CP, PtP     CP, LAN Rack     Racks, max.     Modules per rack, max. Time of day Clock	10 4 8
CP, PtP     CP, LAN  Rack     Racks, max.     Modules per rack, max.  Time of day  Clock     Hardware clock (real-time)	10
CP, PtP     CP, LAN  Rack      Racks, max.     Modules per rack, max.  Time of day  Clock      Hardware clock (real-time)     retentive and synchronizable	10 4 8 Ves Yes
CP, PtP     CP, LAN  Rack      Racks, max.     Modules per rack, max.  Time of day  Clock      Hardware clock (real-time)     retentive and synchronizable     Backup time	10 4 8 Ves Yes 6 wk; At 40 °C ambient temperature
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock Elevation (real-time) <ul> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF
<ul> <li>CP, PtP</li> <li>CP, LAN</li> </ul> Rack <ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock Elevation (real-time) <ul> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> <li>Time of day</li> <li>Clock</li> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> <li>Operating hours counter</li> <li>Number</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
<ul> <li>CP, PtP</li> <li>CP, LAN</li> </ul> Rack <ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number range</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues at the time of day it had when power was switched off the clock continues at the time of day it had when power was switched off
<ul> <li>CP, PtP</li> <li>CP, LAN</li> </ul> Rack <ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number/Number range</li> <li>Range of values</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
<ul> <li>CP, PtP</li> <li>CP, LAN</li> </ul> Rack <ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number</li> <li>Range of values</li> <li>Granularity</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h
<ul> <li>CP, PtP</li> <li>CP, LAN</li> </ul> Rack <ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number</li> <li>Range of values</li> <li>Granularity</li> <li>retentive</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number</li> <li>Number range</li> <li>Range of values</li> <li>Granularity</li> <li>retentive</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> <li>Time of day</li> <li>Clock</li> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> <li>Operating hours counter</li> <li>Number</li> <li>Number/Number range</li> <li>Range of values</li> <li>Granularity</li> <li>retentive</li> <li>Clock synchronization</li> <li>supported</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Deviation per day, max.</li> <li>Behavior of the clock following POWER-ON</li> <li>Behavior of the clock following expiry of backup period</li> </ul> Operating hours counter <ul> <li>Number</li> <li>Number</li> <li>Number range</li> <li>Range of values</li> <li>Granularity</li> <li>retentive</li> </ul>	10 4 8 Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart

• to DP, master	Yes; With DP slave only slave clock
• on DP, device	Yes
• in AS, master	Yes
• in AS, device	Yes
<ul> <li>on Ethernet via NTP</li> </ul>	Yes; As client
Digital inputs	
Number of digital inputs	0
Digital outputs	
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Interfaces	0
Number of PROFINET interfaces	1; 2 ports (switch) RJ45
Number of RS 485 interfaces	1; Combined MPI / PROFIBUS DP
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	Yes
Interface types	
• RS 485	Yes
<ul> <li>Output current of the interface, max.</li> </ul>	200 mA
Protocols	
• MPI	Yes
<ul> <li>PROFIBUS DP master</li> </ul>	Yes
<ul> <li>PROFIBUS DP device</li> </ul>	Yes
<ul> <li>Point-to-point connection</li> </ul>	No
MPI	
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s
Services	
- PG/OP communication	Yes
— Routing	Yes
— Global data communication	Yes
— S7 basic communication	Yes
— S7 communication	Yes
- S7 communication, as client	No; but via CP and loadable FB
— S7 communication, as server	Yes
PROFIBUS DP master	
Transmission rate, max.	12 Mbit/s
<ul> <li>max. number of DP devices</li> </ul>	124
Services	
— PG/OP communication	Yes
- Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
- S7 communication	Yes
- S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS
	DP or PROFINET IO
- SYNC/FREEZE	Yes
- activation/deactivation of DP devices	Yes
<ul> <li>max. number of DP devices that can be activated/deactivated at the same time</li> </ul>	8
<ul> <li>Direct data exchange (slave-to-slave communication)</li> <li>DPV1</li> </ul>	Yes; as subscriber Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP device	
User data per Dr device	

	044 http
— Inputs, max.	244 byte
— Outputs, max.	244 byte
1st interface / PROFIBUS DP device / header	
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s
<ul> <li>automatic baud rate search</li> </ul>	Yes; only with passive interface
<ul> <li>Address area, max.</li> </ul>	32
<ul> <li>User data per address area, max.</li> </ul>	32 byte
Services	
— PG/OP communication	Yes
— Routing	Yes; Only with active interface
— Global data communication	No
<ul> <li>— S7 basic communication</li> </ul>	No
— S7 communication	Yes
- S7 communication, as client	No
— S7 communication, as server	Yes; Connection configured on one side only
— Direct data exchange (slave-to-slave	Yes
communication)	
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
	PROFINET
Interface type Isolated	Yes
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
Interface types	
RJ 45 (Ethernet)	Yes
<ul> <li>Number of ports</li> </ul>	2
<ul> <li>integrated switch</li> </ul>	Yes
Protocols	
• MPI	No
PROFINET IO Controller	Yes; Also simultaneously with IO-Device functionality
PROFINET IO Device	Yes; Also simultaneously with IO Controller functionality
PROFINET CBA	Yes
PROFIBUS DP master	No
PROFIBUS DP device	No
Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	100 Mh:Ha
Transmission rate, max.	100 Mbit/s
Services	Nee.
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; With loadable FBs, max. configurable connections: 14, max. number of
— Isochronous mode	instances: 32 Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS
	DP or PROFINET IO
— IRT	Yes
— Shared device	Yes
— Prioritized startup	Yes
<ul> <li>Number of IO devices with prioritized startup, max.</li> </ul>	32
<ul> <li>— Number of connectable IO Devices, max.</li> </ul>	128
<ul> <li>— Of which IO devices with IRT, max.</li> </ul>	64
— of which in line, max.	64
<ul> <li>— Number of IO Devices with IRT and the option "high flexibility"</li> </ul>	128
— of which in line, max.	61
<ul> <li>— Number of connectable IO Devices for RT, max.</li> </ul>	128

— of which in line, max.	128
<ul> <li>Activation/deactivation of IO Devices</li> </ul>	Yes
<ul> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8
<ul> <li>IO Devices changing during operation (partner</li> </ul>	Yes
ports), supported	
<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
<ul> <li>Device replacement without swap medium</li> </ul>	Yes
— Send cycles	250 $\mu s,$ 500 $\mu s,1$ ms; 2 ms, 4 ms (not in the case of IRT with "high flexibility" option)
— Updating time	$250~\mu s$ to $512~m s$ (depending on the operating mode, see Manual "S7-300 CPU 31xC and CPU 31x, technical Data" for more details)
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
— User data consistency, max.	1 024 byte
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; With loadable FBs, max. configurable connections: 14, max. number of instances: 32
— Isochronous mode	No
— IRT	Yes
- PROFlenergy	Yes; With SFB 73 / 74 prepared for loadable PROFlenergy standard FB for I- Device
— Shared device	Yes
<ul> <li>— Number of IO Controllers with shared device, max.</li> </ul>	2
Transfer memory	
— Inputs, max.	1 440 byte; Per IO Controller with shared device
— Outputs, max.	1 440 byte; Per IO Controller with shared device
Submodules	
— Number, max.	64
— User data per submodule, max.	1 024 byte
PROFINET CBA	
acyclic transmission	Yes
cyclic transmission	Yes
Open IE communication	
<ul> <li>Number of connections, max.</li> </ul>	8
Local port numbers used at the system end	0, 20, 21, 23, 25, 80, 102, 135, 161, 443, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535
<ul> <li>Keep-alive function, supported</li> </ul>	Yes
Protocols	
PROFIsafe	No
Redundancy mode	
Media redundancy	
- Switchover time on line break, typ.	200 ms; PROFINET MRP
<ul> <li>— Number of stations in the ring, max.</li> </ul>	50
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
Number of connections, max.	8
<ul> <li>— Number of connections, max.</li> <li>— Data length for connection type 01H, max.</li> </ul>	
	1 460 byte
Data length for connection type 11H, max.	32 768 byte
— several passive connections per port, supported	Yes
ISO-on-TCP (RFC1006)	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	8
— Data length, max.	32 768 byte
• UDP	Yes; via integrated PROFINET interface and loadable FBs
<ul> <li>— Number of connections, max.</li> </ul>	
	8
— Data length, max.	8 1 472 byte
— Data length, max. Web server	1 472 byte
— Data length, max.	

Number of HTTP clients	5
communication functions / header	
PG/OP communication	Yes
Data record routing	Yes
Global data communication	
supported	Yes
Number of GD loops, max.	8
Number of GD packets, max.	8
Number of GD packets, transmitter, max.	8
Number of GD packets, receiver, max.	8
Size of GD packets, max.	22 byte
<ul> <li>Size of GD packet (of which consistent), max.</li> </ul>	22 byte
S7 basic communication	
supported	Yes
• User data per job, max.	76 byte
User data per job (of which consistent), max.	76 byte; 76 bytes (with X SEND or X RCV); 64 bytes (with X PUT or X GET
	as server)
S7 communication	
supported	Yes
• as server	Yes
• as client	Yes; via integrated PROFINET interface and loadable FB or via CP and loadable FB
• User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
S5 compatible communication	
supported	Yes; via CP and loadable FC
communication functions / PROFINET CBA (with set target commu	
<ul> <li>Setpoint for the CPU communication load</li> </ul>	50 %
<ul> <li>Number of remote interconnection partners</li> </ul>	32
<ul> <li>number of master/device functions</li> </ul>	30
<ul> <li>total of all master/device connections</li> </ul>	1 000
<ul> <li>data length of all incoming master/device connections, max.</li> </ul>	4 000 byte
<ul> <li>data length of all outgoing master/device connections, max.</li> </ul>	4 000 byte
Number of device-internal and PROFIBUS interconnections	500
<ul> <li>Data length of device-internal und PROFIBUS interconnections, max.</li> </ul>	4 000 byte
Data length per connection, max.	1 400 byte
performance data / PROFINET CBA / remote interconnection	
— Sampling interval, min.	500 ms
— Number of incoming interconnections	100
- Number of outgoing interconnections	100
— Data length of all incoming interconnections, max.	2 000 byte
<ul> <li>Data length of all outgoing interconnections, max.</li> </ul>	2 000 byte
<ul> <li>— data volume / as user data for remote interconnections / in the case of acyclic transmission / with PROFINET CBA / per connection / maximum</li> </ul>	1 400 byte
performance data / PROFINET CBA / remote interconnection /	/ with cyclic transfer / header
- Transmission frequency: Transmission interval, min.	10 ms
- Number of incoming interconnections	200
— Number of outgoing interconnections	200
<ul> <li>Data length of all incoming interconnections, max.</li> </ul>	2 000 byte
<ul> <li>Data length of all outgoing interconnections, max.</li> </ul>	2 000 byte
<ul> <li>data volume / as user data for remote interconnections / with cyclical transfer / with PROFINET CBA / per connection / maximum</li> </ul>	450 byte
performance data / PROFINET CBA / HMI variables via PROF	INET / acyclic / header
— Number of stations that can log on for HMI variables (PN OPC/iMap)	3; 2x PN OPC/1x iMap
— HMI variable updating	500 ms
— Number of HMI variables	200
— Data length of all HMI variables, max.	2 000 byte

performance data / PROFINET CBA / PROFIBUS proxy funct	ionality / header
— supported	Yes
- Number of linked PROFIBUS devices	16
— Data length per connection, max.	240 byte; Slave-dependent
Number of connections	
overall	16
<ul> <li>usable for PG communication</li> </ul>	15
<ul> <li>reserved for PG communication</li> </ul>	1
<ul> <li>— adjustable for PG communication, min.</li> </ul>	1
<ul> <li>— adjustable for PG communication, max.</li> </ul>	15
<ul> <li>usable for OP communication</li> </ul>	15
- reserved for OP communication	1
<ul> <li>— adjustable for OP communication, min.</li> </ul>	1
<ul> <li>— adjustable for OP communication, max.</li> </ul>	15
<ul> <li>usable for S7 basic communication</li> </ul>	14
- reserved for S7 basic communication	0
<ul> <li>— adjustable for S7 basic communication, min.</li> </ul>	0
— adjustable for S7 basic communication, max.	14
usable for S7 communication	14
- reserved for S7 communication	0
— adjustable for S7 communication, min.	0
— adjustable for S7 communication, max.	14
<ul> <li>total number of instances, max.</li> </ul>	32
<ul> <li>usable for routing</li> </ul>	X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max.
S7 message functions	14; X2 as PROFINET: 24 max.
Number of login stations for message functions, max.	16; Depending on the configured connections for PG/OP and S7 basic
	communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes; Up to 2 simultaneously Yes
Single step Number of breakpoints Status/control	Yes 4
Single step Number of breakpoints Status/control • Status/control variable	Yes
Single step Number of breakpoints Status/control • Status/control variable • Variables	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         Forcing	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         Forcing         • Forcing	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         Forcing         • Forcing, variables	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof • Number of entries readable in RUN, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499
Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. of which status variables, max. of which control variables, max. of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. adjustable of which powerfail-proof • Number of entries readable in RUN, max. adjustable	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         — adjustable         — of which powerfail-proof         • Number of entries readable in RUN, max.         — adjustable         — preset	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         - of which control variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         - of which control variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         Forcing         • Status/conditions	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         - of which control variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         - of which control variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out         Ambient conditions         Ambient temperature during operation	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out         Ambient conditions         Ambient temperature during operation         • min.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10 O °C
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out         Ambient conditions         Ambient temperature during operation         • min.         • max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10 O °C
Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         - of which status variables, max.         - of which control variables, max.         - of which control variables, max.         - of which control variables, max.         Forcing         • Forcing         • Forcing, variables         • Number of variables, max.         Diagnostic buffer         • present         • Number of entries, max.         - adjustable         - of which powerfail-proof         • Number of entries readable in RUN, max.         - adjustable         - preset         Service data         • can be read out         Ambient conditions         Ambient temperature during operation         • min.         • max.         configuration / header	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100; Only the last 100 entries are retained 499 Yes; From 10 to 499 10 O °C

configuration / programming / header	
Command set	see instruction list
Nesting levels	8
System functions (SFC)	see instruction list
<ul> <li>System function blocks (SFB)</li> </ul>	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
Block encryption	Yes; With S7 block Privacy
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Weights	
Weight, approx.	340 g

last modified:

4/25/2024 🖸