SIEMENS







Edition 06/2024

EQUIPMENT MANUAL

SINAMICS

SINAMICS S120

Air-cooled chassis power units

www.siemens.com/drives

SIEMENS Introduction **Fundamental safety** instructions System overview **SINAMICS** Line-side power components **S120** Air-cooled chassis power units **Line Modules Motor Modules Equipment Manual DC link components** Motor-side power components Cabinet design and EMC **Maintenance and Servicing**

Appendix

Legal information

Warning notice system

This manual contains notices you have to observe in order to ensure your personal safety, as well as to prevent damage to property. The notices referring to your personal safety are highlighted in the manual by a safety alert symbol, notices referring only to property damage have no safety alert symbol. These notices shown below are graded according to the degree of danger.

♠ DANGER

indicates that death or severe personal injury will result if proper precautions are not taken.

∕ WARNING

indicates that death or severe personal injury may result if proper precautions are not taken.

CAUTION

indicates that minor personal injury can result if proper precautions are not taken.

NOTICE

indicates that property damage can result if proper precautions are not taken.

If more than one degree of danger is present, the warning notice representing the highest degree of danger will be used. A notice warning of injury to persons with a safety alert symbol may also include a warning relating to property damage.

Qualified Personnel

The product/system described in this documentation may be operated only by **personnel qualified** for the specific task in accordance with the relevant documentation, in particular its warning notices and safety instructions. Qualified personnel are those who, based on their training and experience, are capable of identifying risks and avoiding potential hazards when working with these products/systems.

Proper use of Siemens products

Note the following:

⚠ WARNING

Siemens products may only be used for the applications described in the catalog and in the relevant technical documentation. If products and components from other manufacturers are used, these must be recommended or approved by Siemens. Proper transport, storage, installation, assembly, commissioning, operation and maintenance are required to ensure that the products operate safely and without any problems. The permissible ambient conditions must be complied with. The information in the relevant documentation must be observed.

Trademarks

All names identified by [®] are registered trademarks of Siemens Aktiengesellschaft. The remaining trademarks in this publication may be trademarks whose use by third parties for their own purposes could violate the rights of the owner.

Disclaimer of Liability

We have reviewed the contents of this publication to ensure consistency with the hardware and software described. Since variance cannot be precluded entirely, we cannot guarantee full consistency. However, the information in this publication is reviewed regularly and any necessary corrections are included in subsequent editions.

Table of contents

1	Introduct	ion	11
	1.1	The SINAMICS converter family	11
	1.2	Usage phases and their documents/tools (as an example)	14
	1.3	Where can the various topics be found?	15
	1.4	Training and support	16
	1.5	Directives, standards, certificates	16
	1.6	Correct and intended use	19
	1.7	Additional information	20
	1.8	General Data Protection Regulation	21
2	Fundame	ntal safety instructions	23
	2.1	General safety instructions	23
	2.2	Handling electrostatic sensitive devices (ESD)	29
	2.3	Warranty and liability for application examples	29
	2.4	Industrial cybersecurity	30
	2.5	Residual risks of power drive systems	31
3	System o	verview	33
	3.1	The SINAMICS range of drives	33
	3.2	SINAMICS S120 drive system	37
	3.3	Technical specifications	40
	3.4	Derating factors as a function of installation altitude and ambient temperature	43
	3.5	Standards	45
	3.6	Basic structure of a drive system with SINAMICS S120	
	3.6.1 3.6.2	Structure of a drive system with SINAMICS S120 and regulated infeed	48
	3.0.2	feedback unit	49
	3.6.3	Structure of a drive system with SINAMICS S120 and unregulated infeed	50
4	Line-side	power components	51
	4.1	General	51
	4.2	Line filters for Basic Line Modules	
	4.2.1 4.2.2	Description	
	4.2.3	Dimension drawing	55
	4.2.4	Technical data	57

4.3 4.3.1	Line filters for Smart Line Modules and Active Line Modules Description	
4.3.2	Safety information	
4.3.3	Dimension drawing	
4.3.4	Technical data	65
4.4	Line reactors for Basic Line Modules	66
4.4.1	Description	
4.4.2	Safety information	
4.4.3	Dimension drawing	
4.4.4	Technical data	
4.5	Line reactors for Smart Line Modules	72
4.5.1	Description	
4.5.2	Safety information	
4.5.3	Dimension drawing	
4.5.4	Technical data	
4.6	Active Interface Modules	81
4.6.1	Description	81
4.6.2	Safety information	
4.6.3	Interface description	
4.6.3.1	Overview	
4.6.3.2	Connection example	
4.6.3.3	Motor circuit breaker -Q101	
4.6.3.4	Line/load connection	
4.6.3.5	DRIVE-CLiQ interface X500	91
4.6.3.6	X530 neutral point grounding	92
4.6.3.7	X609 terminal strip	93
4.6.3.8	Meaning of the LED on the Voltage Sensing Module (VSM) in the Active Interface Module	94
4.6.4	Dimension drawing	
4.6.5	Electrical connection	
4.6.6	Technical data	105
4.7	Active Interface Modules Chassis-2	108
4.7.1	Description	
4.7.2	Safety information	
4.7.3	Interface description	
4.7.3.1	Overview	
4.7.3.2	Connection example	
4.7.3.3	Motor circuit breaker -Q101	113
4.7.3.4	Line/load connection	114
4.7.3.5	DRIVE-CLiQ interface X500	114
4.7.3.6	X530 neutral point grounding	115
4.7.3.7	X609 terminal strip	116
4.7.3.8	Meaning of the LED on the Voltage Sensing Module (VSM) in the Active Interface	4
4.7.4	Module Dimension drawing	
4.7.4	Installation	
4.7.5	Electrical connection	
4.7.7	Pre-charging input circuit for Active Interface Modules Chassis-2	 17 <u>4</u>
4.7.8	Technical data	400

Line Mod	Line Modules		
5.1	Introduction	131	
5.2	Basic Line Modules	132	
5.2.1	Description	132	
5.2.2	·		
5.2.3			
5.2.3.1	·		
5.2.3.2			
5.2.3.3	Line/load connection	140	
5.2.3.4	X9 terminal strip	141	
5.2.3.5	X41 EP terminal / temperature sensor connection	141	
5.2.3.6	X42 terminal strip	143	
5.2.3.7	DRIVE-CLiQ interfaces X400, X401, X402	143	
5.2.3.8	Meaning of the LEDs on the Control Interface Module in the Basic Line Module	144	
5.2.4	Dimension drawing	145	
5.2.5			
5.2.6			
5.2.7.3	Overload capability	161	
5.3			
	·		
	·		
	·		
	·		
	· ·		
	·		
	·		
	·		
5.4.3.7			
	5.1 5.2 5.2.1 5.2.2 5.2.3 5.2.3.1 5.2.3.2 5.2.3.3 5.2.3.4 5.2.3.5 5.2.3.6 5.2.3.7 5.2.3.8 5.2.4 5.2.5 5.2.6 5.2.7 5.2.7.1 5.2.7.2 5.2.7.3 5.3 5.3.1 5.3.2 5.3.3 5.3.3.1 5.3.3.2 5.3.3.3 5.3.3.4 5.3.3.5 5.3.3.6 5.3.3.7 5.3.3.8 5.3.3.6 5.3.3.7 5.3.3.8 5.3.3.6 5.3.3.7 5.3.3.8 5.3.3.6 5.3.3.7 5.3.3.8 5.3.3.6 5.3.3.7 5.3.3.8 5.3.6 5.3.3.7 5.3.3.8 5.3.6 5.3.6.1 5.3.6.2 5.3.6.3 5.4.1 5.4.2 5.4.3.3 5.4.3.1 5.4.3.5 5.4.3.6 5.4.3.5 5.4.3.6	5.1 Introduction 5.2 Basic Line Modules 5.2.1 Description 5.2.2 Safety information 5.2.3 Interface description 5.2.3.1 Overview 5.2.3.2 Connection example 5.2.3.3 Linelload connection 5.2.3.4 X9 terminal strip 5.2.3.5 X41 EP terminal / temperature sensor connection. 5.2.3.6 X42 terminal strip 5.2.3.7 DRIVE-CLIO interfaces X400, X401, X402 5.2.3.8 Meaning of the LEDs on the Control Interface Module in the Basic Line Module 5.2.4 Dimension drawing. 5.2.5 Electrical connection 5.2.6 Precharging circuit for the Basic Line Modules, frame size GD 5.2.7 Technical data 5.2.7.1 Basic Line Modules, 380 480 V 3 AC 5.2.7.2 Basic Line Modules, 500 690 V 3 AC 5.2.7.3 Overload capability. 5.3 Smart Line Modules 5.3.1 Description 5.3.2 Safety information. 5.3.3.1 Interface description 5.3.3.2 Connection example 5.3.3.3 Linelload connection. 5.3.3.4 X9 terminal strip 5.3.3.5 X41 EP terminal / temperature sensor connection. 5.3.3.6 X2 terminal strip 5.3.3.7 DRIVE-CLIO interfaces X400, X401, X402 5.3.3.8 Meaning of the LEDs on the Control Interface Module in the Smart Line Module. 5.3.1 Dimension drawing. 5.3.3.2 Safety information. 5.3.3.3 Linelload connection. 5.3.3.4 X9 terminal strip 5.3.3.5 Smart Line Modules, 3 AC 380 480 V 5.3.3.6 Technical data 5.3.6 Technical data 5.3.7 DRIVE-CLIO interfaces X400, X401, X402 5.3.8 Mart Line Modules, 3 AC 380 480 V 5.3.9 Smart Line Modules, 3 AC 500 690 V 5.3.1 Description 5.3.2 Safety information 1.1 Line Modules, 3 AC 500 690 V 5.3.3.1 Description 5.3.3.2 Safety information 1.3.3.3 Linelload connection. 5.3.4 Dimension drawing. 5.3.5 Linelload connection. 5.3.6 Technical data 5.3.7 Linelload connection. 5.3.8 Linelload connection. 5.3.9 Linelload connection. 5.3.1 Linelload connection. 5.3.2 Linelload connection. 5.3.3 Linelload connection. 5.3.	

5.4.4 Dimension drawing	
5.4.6 Technical data	210
5.4.6.1 Active Line Modules, 380 480 V 3 AC	215
5.4.6.2 Active Line Modules, 500 690 V 3 AC	
5.4.6.3 Overload capability	223
5.5 Active Line Modules Chassis-2	224
5.5.1 Description	
5.5.2 Safety information	
5.5.3 Interface description	
5.5.3.1 Overview	
5.5.3.2 Connection example	
5.5.3.3 Line/load connection	
5.5.3.4 X51 connection, fan power supply	
5.5.3.5 X9 terminal strip	
5.5.3.6 X41 EP terminal / temperature sensor connection	
5.5.3.7 X42 terminal strip	
5.5.3.8 X46 terminal strip	
5.5.3.9 X47 contactor feedback signal	238
5.5.3.10 X49 terminal block	
5.5.3.11 DRIVE-CLiQ interfaces X400, X401, X402	239
5.5.3.12 Test points for 1 mm test probes	240
5.5.3.13 Meaning of the LEDs on the Active Line Module	241
5.5.4 Dimension drawing	242
5.5.5 Installation	245
5.5.6 Electrical connection	249
5.5.7 Technical data	
5.5.7.1 Active Line Modules Chassis-2, 380 480 V 3 AC	252
5.5.7.2 Overload capability	257
6 Motor Modules	259
6.1 Motor Modules Chassis	259
6.1 Motor Modules Chassis	
6.1.1 Description	259
6.1.1 Description	259 261
6.1.1 Description	259 261 263
6.1.1 Description	
6.1.1 Description 6.1.2 Safety information 6.1.3 Interface description 6.1.3.1 Overview 6.1.3.2 Connection example	
6.1.1 Description	
6.1.1 Description 6.1.2 Safety information 6.1.3 Interface description 6.1.3.1 Overview 6.1.3.2 Connection example 6.1.3.3 DC link/motor connection 6.1.3.4 X9 terminal strip	
6.1.1 Description 6.1.2 Safety information 6.1.3 Interface description 6.1.3.1 Overview 6.1.3.2 Connection example 6.1.3.3 DC link/motor connection 6.1.3.4 X9 terminal strip 6.1.3.5 DCPS, DCNS connection for a dv/dt filter	
6.1.1 Description	
6.1.1 Description 6.1.2 Safety information 6.1.3 Interface description 6.1.3.1 Overview 6.1.3.2 Connection example 6.1.3.3 DC link/motor connection 6.1.3.4 X9 terminal strip 6.1.3.5 DCPS, DCNS connection for a dv/dt filter. 6.1.3.6 X41 EP terminal / temperature sensor connection 6.1.3.7 X42 terminal strip 6.1.3.8 X46 Brake control and monitoring. 6.1.3.9 DRIVE-CLiQ interfaces X400, X401, X402 6.1.3.10 Meaning of the LEDs on the Control Interface Module in the Motor Module.	
6.1.1 Description 6.1.2 Safety information 6.1.3 Interface description 6.1.3.1 Overview 6.1.3.2 Connection example 6.1.3.3 DC link/motor connection 6.1.3.4 X9 terminal strip 6.1.3.5 DCPS, DCNS connection for a dv/dt filter. 6.1.3.6 X41 EP terminal / temperature sensor connection 6.1.3.7 X42 terminal strip 6.1.3.8 X46 Brake control and monitoring. 6.1.3.9 DRIVE-CLiQ interfaces X400, X401, X402 6.1.3.10 Meaning of the LEDs on the Control Interface Module in the Motor Module.	
6.1.1 Description	
6.1.1 Description	
6.1.1 Description	

	6.1.6.4	Current de-rating depending on the pulse frequency	294
	6.1.6.5	Parallel connection of Motor Modules	
	6.2	Motor Modules Chassis-2	298
	6.2.1	Description	
	6.2.2	Safety information	
	6.2.3	Interface description	
	6.2.3.1	Overview	
	6.2.3.2	Connection example	
	6.2.3.3	DC link/motor connection	
	6.2.3.4	X51 connection, fan power supply	
	6.2.3.5	X9 terminal strip	
	6.2.3.6	X41 EP terminal / temperature sensor connection	
	6.2.3.7	X42 terminal strip	
	6.2.3.8	X46 Brake control and monitoring	
	6.2.3.9	X47 contactor feedback signal	
	6.2.3.10	X49 terminal block	
	6.2.3.11	DRIVE-CLIQ interfaces X400, X401, X402	
	6.2.3.11	Test points for 1 mm test probes	
	6.2.3.12	Meaning of the LEDs on the Motor Module	
	6.2.4	Dimension drawing	
	6.2.5	Installation	
	6.2.6	Electrical connection	
	6.2.7	Technical data	
	6.2.7.1	Motor Modules, 510 720 V DC (line voltage 3 AC 380 480 V)	
	6.2.7.1	Overload capability	
	6.2.7.3	Current de-rating depending on the pulse frequency	
	6.2.7.3	Parallel connection of Motor Modules Chassis-2	
7	DC link co	mponents	335
	7.1	Braking Module	335
	7.1.1	Description	335
	7.1.2	Safety information	337
	7.1.3	Interface description	338
	7.1.3.1	Braking Module for frame sizes FX, FB	338
	7.1.3.2	Braking Module for frame sizes GX, GB, GD	339
	7.1.3.3	Braking Module for frame sizes HX, JX	340
	7.1.3.4	Connection example	341
	7.1.3.5	Braking resistor connection	341
	7.1.3.6	X21 digital inputs/outputs	342
	7.1.3.7	S1 Threshold switch	343
	7.1.4	Installation	345
	7.1.4.1	Installing the Braking Module in an Active Line Module / Motor Module, frame size FX	345
	7.1.4.2	Installing the Braking Module in a Smart Line Module / Active Line Module / Motor	
		Module, frame size GX	348
	7.1.4.3	Installing the Braking Module in a Smart Line Module / Active Line Module / Motor	
		Module, frame size HX	351
	7.1.4.4	Installing the Braking Module in a Smart Line Module / Active Line Module / Motor	•
		Module, frame size JX	352
	7.1.4.5	Installing the Braking Module in a Basic Line Module, frame size FB	
	7.1.4.6	Installing the Braking Module in a Basic Line Module, frame size GB, GD	
	7.1.5	Technical specifications	
	· · · -		

	7.2	Braking resistors	359
	7.2.1	Description	
	7.2.2	Safety information	
	7.2.3	Dimension drawing	
	7.2.4	Electrical connection	363
	7.2.5	Technical data	364
8	Motor-si	de power components	367
	8.1	Sine-wave filter	
	8.1.1	Description	
	8.1.2	Safety information	
	8.1.3	Dimension drawing	
	8.1.4	Technical data	371
	8.2	Motor reactors	
	8.2.1	Description	
	8.2.2	Safety information	
	8.2.3	Dimension drawing	
	8.2.4	Technical data	380
	8.3	dv/dt filter plus Voltage Peak Limiter	
	8.3.1	Description	
	8.3.2	Safety information	
	8.3.3	Interface description	
	8.3.4	Connecting the dv/dt filter plus Voltage Peak Limiter	
	8.3.5	Dimension drawing, dv/dt reactor	
	8.3.6	Dimension drawing of the Voltage Peak Limiter	
	8.3.7	Technical data	
	8.4	dv/dt filter compact plus Voltage Peak Limiter	
	8.4.1	Description	
	8.4.2	Safety information	
	8.4.3	Interface description	
	8.4.4	Connecting the dv/dt filter compact plus Voltage Peak Limiter	
	8.4.5	Dimension drawing for dv/dt filter compact plus Voltage Peak Limiter	
	8.4.6	Technical data	
9	Cabinet	design and EMC	425
	9.1	Information	425
	9.1.1	General	
	9.1.2	Safety information	
	9.1.3	Directives	428
	9.2	EMC-compliant design and control cabinet configuration	428
	9.3	Electromagnetic fields at the workplace	
	9.3.1	Preliminary remarks	
	9.3.2	Measurements/evaluations for SINAMICS S120 chassis air cooled	430
	9.4	Cabinet air conditioning	
	9.4.1	General	
	9.4.2	Ventilation	432
	9.5	Control cabinet installation for devices in the Chassis format	444
	9.6	Control cabinat installation for devices in the Chassis-2 format	115

	9.6.1	Installing the devices in a Rittal VX25 control cabinet	
	9.6.1.1	Installing an Active Line Modules Chassis-2 or Motor Modules Chassis-2	445
	9.6.1.2	Installing an Active Interface Modules Chassis-2	
	9.6.2	Installing the devices in a Rittal TS8 control cabinet	
	9.6.2.1	Installing an Active Line Modules Chassis-2 or Motor Modules Chassis-2	
	9.6.2.2	Installing an Active Interface Modules Chassis-2	463
10	Maintena	nce and Servicing	467
	10.1	Chapter content	467
	10.2	Maintenance	468
	10.3	Maintenance	
	10.3.1	Installation device	
	10.3.2	Using crane lifting lugs to transport power blocks	471
	10.4	Replacing components	476
	10.4.1	Safety information	
	10.4.2	Messages after replacement of DRIVE-CLiQ components	
	10.4.3	Replacing the power block, Active Line Module, and Motor Module, frame size FX	477
	10.4.4	Replacing the power block, Smart Line Module, Active Line Module, and Motor Module,	
	10.15	frame size GX	480
	10.4.5	Replacing the power block, Smart Line Module, Active Line Module, and Motor Module,	407
	10.4.6	frame size HXReplacing the power block, Smart Line Module, Active Line Module, and Motor Module,	483
	10.4.6	frame size JXframe.size JX	188
	10.4.7	Replacing the power block, Basic Line Module, frame size FB	
	10.4.8	Replacing the power block, Basic Line Module GB, GD	
	10.4.9	Replacing the Control Interface Module, Active Line Module and Motor Module, frame size FX	
	10.4.10	Replacing the Control Interface Module, Smart Line Module, Active Line Module, and	. 490
		Motor Module, frame size GX	498
	10.4.11	Replacing the Control Interface Module, Smart Line Module, Active Line Module, and	
		Motor Module, frame size HX	500
	10.4.12	Replacing the Control Interface Module, Smart Line Module, Active Line Module, and	
		Motor Module, frame size JX	502
	10.4.13	Replacing the Control Interface Module, Active Line Module and Motor Module Chassis-	50 4
	10 4 14	2, frame size FS2, FS2+, FS4, FS4+	
	10.4.14	Replacing the Control Interface Module, Basic Line Module, frame size FB	
	10.4.15 10.4.16	Replacing the Control Interface Module, Basic Line Module, frame size GB, GD	510
	10.4.10	sizes FX, GX	512
	10.4.17	Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame	. 112
		size HX	514
	10.4.18	Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame	
		size JX	518
	10.4.19	Replacing the fan, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4, FS4+	520
	10.4.20	Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame	520
		sizes FS2, FS2+, FS4+	523
	10.4.21	Replacing the fan, Active Interface Module, frame size FI	
	10.4.22	Replacing the fan, Active Interface Module, frame size GI	
	10.4.23	Replacing the fan, Active Interface Module, frame size HI	
	10.4.24	Replacing the fan. Active Interface Module, frame size Jl	533

	10.4.25	Replacing the fan, Active Interface Module Chassis-2	535
	10.4.26	Replacing the fan, Basic Line Module, frame sizes FB, GB, GD	
	10.4.27	Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size HX	539
	10.4.28	Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size JX	542
	10.4.29	Replacement of the fan fuses	
	10.5	Long time storage of replacement parts	
	10.5.1	Storing fans for devices in the Chassis-2 format	545
	10.6	Forming the DC link capacitors	546
	10.7	Recycling and disposal	550
Α	Appendix		551
	A.1	Cable lugs	551
	A.2	List of abbreviations	553
	Index		562

Introduction

1.1 The SINAMICS converter family

With the SINAMICS converter family, you can solve any individual drive task in the low-voltage, medium-voltage and DC voltage range. From converters to motors and controllers, all Siemens drive components are perfectly matched to each other and can be easily integrated into your existing automation system. With SINAMICS you are prepared for digitization. You benefit from highly efficient engineering with a variety of tools for the entire product development and production process. And you also save space in the control cabinet – thanks to the integrated safety technology.

You can find additional information about SINAMICS at the following address (http://www.siemens.com/sinamics).

SINAMICS documentation

The SINAMICS documentation is organized in the following categories:

- General documentation/catalogs
- User documentation
- Manufacturer/service documentation

Standard scope

The scope of the functionality described in this document can differ from that of the drive system that is actually supplied.

- Other functions not described in this documentation might be able to be executed in the drive system. However, no claim can be made regarding the availability of these functions when the equipment is first supplied or in the event of service.
- The documentation can also contain descriptions of functions that are not available in a particular product version of the drive system. Please refer to the ordering documentation only for the functionality of the supplied drive system.
- Extensions or changes made by the machine manufacturer must be documented by the machine manufacturer.

For reasons of clarity, this documentation does not contain all of the detailed information about all of the product types, and cannot take into consideration every conceivable type of installation, operation and service/maintenance.

1.1 The SINAMICS converter family

Sales law

Typical use cases are listed in this product documentation and in the online help to illustrate possible application areas for our products. These are purely exemplary and do not constitute a statement on the suitability of the respective product for applications in specific individual cases. Unless explicitly agreed as part of a contract, Siemens assumes no liability for such suitability. Suitability for a particular application in specific individual cases must be assessed by the user on a case-for-case basis, taking into account all technical, legal and other requirements. Always observe the descriptions of the technical properties and the relevant constraints of the respective product provided in the product documentation.

Target group

This documentation is intended for machine manufacturers, commissioning engineers, and service personnel who use the SINAMICS drive system.

Benefits

This manual provides all of the information, procedures and operator actions required for the particular usage phase.

Siemens MySupport/Documentation

You can find information on how to create your own individual documentation based on Siemens content and adapt it for your own machine documentation at the following address (https://support.industry.siemens.com/My/ww/en/documentation).

Additional information

You can find information on the following topics at the following address (https://support.industry.siemens.com/cs/ww/en/view/108993276):

- Ordering documentation / overview of documentation
- Additional links to download documents
- Using documentation online (find and search in manuals/information)

Siemens Product Configurator

2D dimension drawings and 3D CAD models are available in the Siemens Product Configurator at the following address (https://www.siemens.com/spc).

Questions relating to the technical documentation

Please send any questions about the technical documentation (e.g. suggestions for improvement, corrections) to the following email address (mailto:docu.motioncontrol@siemens.com).

FAQs

You can find Frequently Asked Questions under Product Support (https://support.industry.siemens.com/cs/ww/en/ps/faq).

Information on the product



You can obtain information about your product via the ID link. The ID link is a globally unique identifier according to IEC 61406-1.

A QR code is provided on your product and the product packaging. You can recognize the ID link by the frame with a black frame corner at the bottom right.

Scan the QR code using either a standard code scanner or the "Industry Online Support" app.

When using a standard code scanner, you open the scanned ID link in an Internet web browser that is provided on your device.

You can use the ID link to obtain product data, manuals, Declarations of Conformity, certificates and other information about your product.

Siemens Support for on the move



The "Siemens Industry Online Support" app supports you in the following areas, for example:

- Resolving problems when executing a project
- · Troubleshooting when faults develop
- Expanding a system or planning a new system

Further, you have access to the Technical Forum and other articles that our experts have drawn-up:

- FAQs
- Application examples
- Manuals
- Certificates
- Product announcements and much more

There is a data matrix code or QR code on the nameplate of your product. Scan the code using the "Siemens Industry Online Support" app to obtain technical information about the device.

The app is available for Apple iOS and Android.

Web sites of third-party companies

This document includes hyperlinks to web sites of third-party companies Siemens accepts no responsibility for the content of these web sites, nor does it use these web sites and their content for its own use, as Siemens cannot check these web sites and is also not responsible for the content and information provided on them. The user uses these web sites at his own risk.

1.2 Usage phases and their documents/tools (as an example)

1.2 Usage phases and their documents/tools (as an example)

Usage phase	Tools	
Orientation	SINAMICS S sales documentation	
Planning/engineering	SIZER engineering tool	
	SINAMICS Low Voltage Configuration Manual	
	Configuration manuals, motors	
Decision mak-	SINAMICS S120 catalogs	
ing/ordering	SINAMICS S120 and SIMOTICS (Catalog D 21.4)	
	SINAMICS Converters for Single-Axis Drives – Built-In Units (D 31.1)	
	SINAMICS S120 Chassis Format Units and Cabinet Modules, SINAMICS S150 Converter Cabinet Units (catalog D 21.3)	
Configur-	SINAMICS S120 Equipment Manual for Control Units and Supplementary System Components	
ing/installation	SINAMICS S120 Equipment Manual for Booksize Power Units	
	SINAMICS S120 Equipment Manual for Air-Cooled Chassis Power Units	
	SINAMICS S120 Equipment Manual for Liquid-Cooled Chassis Power Units	
	SINAMICS S120 Equipment Manual water-cooled chassis power units for common cooling circuits	
	SINAMICS S120 Equipment Manual for AC Drives	
	SINAMICS S120M Equipment Manual for Distributed Drive Technology	
Commissioning	STARTER Commissioning Tool	
	SINAMICS S120 Getting Started	
	SINAMICS S120 Commissioning Manual	
	SINAMICS S120 Function Manual Drive Functions	
	SINAMICS S120 Safety Integrated Function Manual	
	SINAMICS S120 Communication Function Manual	
	SINAMICS S120/S150 List Manual	
Using/operating	SINAMICS S120 Commissioning Manual	
	SINAMICS S120 Function Manual Drive Functions	
	SINAMICS S120/S150 List Manual	
Maintenance/Service	SINAMICS S120 Commissioning Manual	
	SINAMICS S120/S150 List Manual	
List of references	SINAMICS S120/S150 List Manual	

You can find SINAMICS S120 documentation on the Internet at the following address.

See also

SINAMICS S120 Documentation (https://support.industry.siemens.com/cs/ww/en/ps/13231/man)

1.3 Where can the various topics be found?

Software		Manual
Alarms	Described in order of ascending numbers	SINAMICS S120/S150 List Manual
Parameters	Described in order of ascending numbers	SINAMICS S120/S150 List Manual
Function block	Sorted according to topic	SINAMICS S120/S150 List Manual
diagrams	Described in order of ascending numbers	
Drive functions		SINAMICS S120 Function Manual Drive Functions
Communication topics		SINAMICS S120 Function Manual Communication ²⁾
Safety Integrated	Basic and Extended Functions	SINAMICS S120 Safety Integrated Function Manual
	Basic Functions	SINAMICS S120 Function Manual Drive Functions
Commissioning	Of a simple SINAMICS S120 drive with STARTER	Getting Started ¹⁾
Commissioning	With STARTER	SINAMICS S120 Commissioning Manual ¹⁾
Commissioning	Of a simple SINAMICS S120 drive with Startdrive	Getting Started ²⁾
Commissioning	With Startdrive	SINAMICS S120 Commissioning Manual ²⁾
Web server		SINAMICS S120 Function Manual Drive Functions

Hardware		Manual
Control Units and expansion components		SINAMICS S120 Equipment Manual for Control Units and Supplementary System Components
Booksize power units		SINAMICS S120 Equipment Manual for Booksize Power Units
Chassis power units		SINAMICS S120 Equipment Manual for Chassis Power Units, Air-cooled
		SINAMICS S120 Manual for Chassis Power Units, liquid cooled
		SINAMICS S120 Equipment Manual for Chassis Power Units, Water-cooled for common cooling circuits
AC drive compon	ents	SINAMICS S120 Equipment Manual for AC Drives
S120 Combi com	ponents	SINAMICS S120 Equipment Manual Combi
Diagnostics via	STARTER	SINAMICS S120 Commissioning Manual ¹⁾
LEDs	Startdrive	SINAMICS S120 Commissioning Manual ²⁾
Meaning of the L	EDs	Equipment Manuals
High Frequency Drive components		SINAMICS S120 System Manual High Frequency Drives

¹⁾ Up to firmware version 5.1 SP1

²⁾ From firmware version 5.2

1.4 Training and support

1.4 Training and support

Training

At the following address, you can find information about SITRAIN - Siemens training courses for products, systems and solutions for drive and automation technology: Training (http://www.siemens.com/sitrain).

Siemens Industry Online Support

You can find the following information in the Siemens Industry Online Support:

- Product support
- Global forum for information and best practice sharing between users and specialists
- Local contact persons via the contact person database (→ Contact)
- Product information
- FAQs (frequently asked questions)
- Application examples
- Manuals
- Downloads
- Compatibility tool
- Newsletter with product selection
- Catalogs/brochures
- Certificates

Address: Siemens Industry Online Support (https://support.industry.siemens.com/cs/ww/en)

1.5 Directives, standards, certificates

Relevant directives and standards

You can obtain an up-to-date list of currently certified components on request from your local Siemens office or your local sales support office. If you have any questions relating to certifications that have not yet been completed, please ask your Siemens contact person.

Certificates for download

The certificates can be downloaded from the Internet:

Certificates (https://support.industry.siemens.com/cs/ww/en/ps/13206/cert)



EC declaration of conformity

You can find the EC Declaration of Conformity for the relevant directives as well as the relevant certificates, prototype test certificates, manufacturers declarations and test certificates for functions relating to functional safety ("Safety Integrated") on the Internet at the following address (https://support.industry.siemens.com/cs/ww/en/ps/13231/cert).

The following directives and standards are relevant for SINAMICS S devices:

• European Low Voltage Directive

SINAMICS S devices fulfil the requirements stipulated in the Low-Voltage Directive 2014/35/EU, insofar as they are covered by the application area of this directive.

• European Machinery Directive

SINAMICS S devices fulfil the requirements stipulated in the Low-Voltage Directive 2006/42/EC, insofar as they are covered by the application area of this directive.

The use of SINAMICS S devices in a typical machine application have been fully assessed for compliance with the main regulations relating to health and safety in this directive.

Directive 2011/65/EU

SINAMICS S devices comply with the requirements of Directive 2011/65/EU relating to the restriction of the use of certain hazardous substances in electrical and electronic devices (RoHS II).

• European EMC Directive

SINAMICS S devices comply with the EMC Directive 2014/30/EU.

· Requirements for the UK market

SINAMICS S devices with the UKCA marking on the nameplate satisfy the requirements for the UK market (England, Wales and Scotland).

· Eurasian conformity

SINAMICS S devices comply with the requirements of the Russia/Belarus/Kazakhstan customs union (EAC).

· North American market

SINAMICS S devices with one of the test symbols displayed fulfill the requirements stipulated for the North American market as a component of drive applications.

You can find the relevant certificates on the Internet pages of the certifiers (https://productiq.ulprospector.com/en).

Australia and New Zealand (RCM formerly C-Tick)

SINAMICS S devices showing the test symbols fulfill the EMC requirements for Australia and New Zealand.

Quality systems

Siemens AG employs a quality management system that meets the requirements of ISO 9001 and ISO 14001.









1.5 Directives, standards, certificates

Standards that are not relevant



China Compulsory Certification

SINAMICS S devices do not fall in the area of validity of the China Compulsory Certification (CCC).

You can find detailed information at: "Certificates for export to China (https://support.industry.siemens.com/cs/ww/en/view/46382761)".

For individual parts that are subject to CCC but are supplied as spare parts, negative certificates are required instead of certificates for shipment to China.

These are required anew for each individual delivery and are to be applied for by the exporter at the following address (http://www.china-certification.com).

EMC limit values for South Korea



SINAMICS S devices with the KC marking on the nameplate comply with EMC requirements for South Korea.

이 기기는 업무용(A급) 전자파적합기기로서 판매자 또는 사용자는 이 점을 주의하시기 바라며, 가정외의 지역에서 사용하는 것을 목적으로 합니다.

For sellers or other user, please keep in mind that this device in an A-grade electromagnetic wave device. This device is intended to be used in areas other than home.

The mandatory EMC limits for Korea correspond to the limits of IEC 61800-3 (EMC product standard for adjustable speed electrical drive systems) for category C2 or to limit class A, Group 1 according to EN 55011.

Compliance with the limits according to category C2 or class A, group 1 is achieved with suitable additional measures. Further, additional measures may be required, such as using an additional radio interference suppression filter (EMC filter).

The measures for EMC-compliant design of the system are described in detail in this manual and in the "SINAMICS Low Voltage Engineering Manual".

The final statement regarding compliance with the standard is always specified by the respective label attached to the individual unit.

Information on product-related environmental protection

You can find additional information about product-related environmental protection at the following address (https://support.industry.siemens.com/cs/ww/en/view/39200038).

1.6 Correct and intended use



Death or serious injury if not used as intended

Not using as intended can result in hazardous states.

Carefully observe the description of intended use

Note

It cannot be guaranteed that EMC emission limits are complied with if the products are connected to an isolated line supply grounded through a high ohmic connection, or a line supply with a grounded line conductor.

• Draw-up an EMC plan to comply with the EMC requirements of the intended application.

The products described in this manual, together with software, accessories and options, form an electric drive to supply low voltage, three-phase motors.

The products are professional devices for stationary indoor use in industrial, light-industrial and commercial applications and are intended for supply from a non-public (industrial) low-voltage grid. The products are not intended for use in residential areas and are not intended for supply from a public low-voltage grid.

The products must be transported and stored correctly and installed, commissioned and maintained by professionals who have adequate knowledge to implement the safety, security and EMC measures in accordance with the specifications described in this manual and recognized state-of-the-art engineering practice.

You may only use the products when the following requirements are complied with:

- All regulations and directives that are applicable at the place of final use, especially with regard to electrical safety, functional safety and electromagnetic compatibility (EMC).
- All instructions, notes, technical specifications, safety information, and security information provided in this manual and other supporting documentation.

The products are part of a machine or system. They must ensure the safety of persons and material assets, as well as electromagnetic compatibility, by applying suitable measures when designing the system.

A risk assessment of the complete application, including third-party products and implementation of adequate safety and security measures must be performed before you use the product.

Products without protective enclosure (IP00 or IP20) are intended for installation in control panels or control cabinets that provide the required level of protection.

Any other use that is not expressly permitted can result in malfunctions and unpredictable hazards.

1.7 Additional information

Ensuring reliable operation

The manual describes a desired state which, if maintained, ensures the required level of operational reliability and compliance with EMC limit values.

Should there be any deviation from the requirements in the equipment manual, appropriate actions (e.g. measurements) must be taken to check/prove that the required level of operational reliability and compliance with EMC limit values are ensured.

Spare parts

Spare parts are available on the Internet at the following address (https://www.sow.siemens.com/).

Product maintenance

The components are subject to continuous further development within the scope of product maintenance (improvements to robustness, discontinuations of components, etc).

These further developments are "spare parts-compatible" and do not change the article number.

In the scope of such spare parts-compatible further developments, connector/connection positions are sometimes changed slightly. This does not cause any problems with proper use of the components. Please take this fact into consideration in special installation situations (e.g. allow sufficient clearance for the cable length).

Use of third-party products

This document contains recommendations relating to third-party products. Siemens accepts the fundamental suitability of these third-party products.

You can use equivalent products from other manufacturers.

Siemens does not accept any warranty for the properties of third-party products.

Ground symbols

Table 1-1 Symbols

Icon	Meaning
	Connection for protective conductor
	Ground (e.g. M 24 V)
	Connection for function potential bonding

1.8 General Data Protection Regulation

Compliance with the General Data Protection Regulation

Siemens respects the principles of data protection, in particular the data minimization rules (privacy by design).

For this product, this means:

The product does not process neither store any person-related data, only technical function data (e.g. time stamps). If the user links these data with other data (e.g. shift plans) or if he stores person-related data on the same data medium (e.g. hard disk), thus personalizing these data, he has to ensure compliance with the applicable data protection stipulations.

1.8 General Data Protection Regulation

Fundamental safety instructions

2.1 General safety instructions



MARNING

Electric shock and danger to life due to other energy sources

Touching live components can result in death or serious injury.

- Only work on electrical devices when you are qualified for this job.
- Always observe the country-specific safety rules.

Generally, the following steps apply when establishing safety:

- 1. Prepare for disconnection. Notify all those who will be affected by the procedure.
- 2. Isolate the drive system from the power supply and take measures to prevent it being switched back on again.
- 3. Wait until the discharge time specified on the warning labels has elapsed.
- 4. Check that there is no voltage between any of the power connections, and between any of the power connections and the protective conductor connection.
- 5. Check whether the existing auxiliary supply circuits are de-energized.
- 6. Ensure that the motors cannot move.
- 7. Identify all other hazardous energy sources, e.g. compressed air, hydraulic systems, water. Switch the energy sources to a safe state.
- 8. Check that the correct drive system is completely locked.

After you have completed the work, restore the operational readiness in the inverse sequence.



MWARNING

Risk of electric shock and fire from supply networks with an excessively high impedance

Excessively low short-circuit currents can lead to the protective devices not tripping or tripping too late, and thus causing electric shock or a fire.

• In the case of a conductor-conductor or conductor-ground short-circuit, ensure that the short-circuit current at the point where the converter is connected to the line supply at least meets the minimum requirements for the response of the protective device used.

2.1 General safety instructions





Risk of electric shock and fire from supply networks with an excessively low impedance

Excessively high short-circuit currents can lead to the protective devices not being able to interrupt these short-circuit currents and being destroyed, and thus causing electric shock or a fire.

• Ensure that the prospective short-circuit current at the line terminal of the converter does not exceed the breaking capacity (SCCR or lcc) of the protective device used.



/ WARNING

Electric shock if there is no ground connection

For missing or incorrectly implemented protective conductor connection for devices with protection class I, high voltages can be present at open, exposed parts, which when touched, can result in death or severe injury.

• Ground the device in compliance with the applicable regulations.



MARNING

Electric shock due to connection to an unsuitable power supply

When equipment is connected to an unsuitable power supply, exposed components may carry a hazardous voltage that might result in serious injury or death.

 Only use power supplies that provide SELV (Safety Extra Low Voltage) or PELV (Protective Extra Low Voltage) output voltages for all connections and terminals of the electronics modules.



/ WARNING

Electric shock due to equipment damage

Improper handling may cause damage to equipment. For damaged devices, hazardous voltages can be present at the enclosure or at exposed components; if touched, this can result in death or severe injury.

- Ensure compliance with the limit values specified in the technical data during transport, storage and operation.
- Do not use any damaged devices.



MWARNING

Electric shock due to unconnected cable shield

Hazardous touch voltages can occur through capacitive cross-coupling due to unconnected cable shields.

• As a minimum, connect cable shields and the cores of power cables that are not used (e.g. brake cores) at one end at the grounded housing potential.



NWARNING

Arcing when a plug connection is opened during operation

Opening a plug connection when a system is in operation can result in arcing that may cause serious injury or death.

• Only open plug connections when the equipment is in a voltage-free state, unless it has been explicitly stated that they can be opened in operation.



MARNING

Electric shock due to residual charges in power components

Because of the capacitors, a hazardous voltage is present for up to 5 minutes after the power supply has been switched off. Contact with live parts can result in death or serious injury.

• Wait for 5 minutes before you check that the unit really is in a no-voltage condition and start work.

NOTICE

Damage to equipment due to unsuitable tightening tools.

Unsuitable tightening tools or fastening methods can damage the screws of the equipment.

- Be sure to only use screwdrivers which exactly match the heads of the screws.
- Tighten the screws with the torque specified in the technical documentation.
- Use a torque wrench or a mechanical precision nut runner with a dynamic torque sensor and speed limitation system.
- Calibrate the tools used on a regular basis.

NOTICE

Property damage due to loose power connections

Insufficient tightening torques or vibration can result in loose power connections. This can result in damage due to fire, device defects, or malfunctions.

- Tighten all power connections to the prescribed torque.
- Check all power connections at regular intervals, particularly after equipment has been transported.



Electromagnetic interference due to inadequate shield support

A lack of adequate shield support for the power cables can cause malfunctions and impermissibly high levels of interference.

- Use the shield connection plates supplied or recommended.
- · Use the shield connection clamps recommended.

2.1 General safety instructions

MWARNING

Spread of fire from built-in devices

Built-in devices can cause a fire and a pressure wave in the event of a fault. The higher the power rating of a converter, the more dangerous the effects of an arc or pressure wave. Fire and smoke can escape from the control cabinet and cause serious personal injury and material damage.

- Install built-in appliances in a robust metal control cabinet that is suitable for protecting people from fire and smoke.
- Ensure that smoke can only escape via controlled and monitored paths.
- Only operate built-in devices with the control cabinet doors closed.
- When control cabinet doors are open, only qualified electrical personnel are permitted to carry out service and maintenance work.

MARNING

Active implant malfunctions due to electromagnetic fields

Converters generate electromagnetic fields (EMF) during operation. Electromagnetic fields may interfere with active implants, e.g. pacemakers. People with active implants in the immediate vicinity of systems are at risk.

- As the operator of an EMF-emitting installation, assess the individual risks of persons with active implants.
- Observe the data on EMF emission provided in the product documentation.

ACAUTION

Symptomatic reactions of the respiratory tract and the skin to chemicals

A newly purchased product may contain traces of substances that were identified as sensitizers.

Sensitizers are substances that can cause pulmonary and skin sensitization after exposure.

Once sensitized, further exposure can result in severe reactions, even at low levels. In the most extreme cases, those involved can develop asthma and/or dermatitis.

• If the product has a strong smell associated with it, keep it in a well ventilated room for 14 days.

MARNING

Unexpected movement of machines caused by radio devices or mobile phones

Using radio devices, cellphones, or mobile WLAN devices in the immediate vicinity of the components can result in equipment malfunction or faults and damage to the devices. Malfunctions may impair the functional safety of machines and can therefore put people in danger or lead to property damage.

- Avoid operating radio devices, cellphones and mobile WLAN devices in the direct vicinity of converters and operating units.
- Scan the machine readable code, e.g. a QR code, from the farthest distance possible or switch off the converter power supply before scanning.
- Only operate built-in devices with the control cabinet doors closed.
- When control cabinet doors are open, only qualified electrical personnel are permitted to carry out service and maintenance work.

MARNING

Damage to motor insulation due to excessive voltages

When operated on systems with grounded line conductor or in the event of a ground fault in the IT line system, the motor insulation can be damaged by the higher voltage to ground. If you use motors that have insulation that is not designed for operation with grounded line conductors, you must perform the following measures:

- IT system: Use a ground fault monitor and eliminate the fault as quickly as possible.
- TN or TT systems with grounded line conductor: Use an isolating transformer on the line side

MARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating of components with subsequent fire and smoke. This can cause serious injury or even death. This can also result in increased failures and shorter service lives for devices/systems.

• Ensure compliance with the specified minimum clearance as ventilation clearance for the respective component.

NOTICE

Overheating due to inadmissible mounting position

The device may overheat and therefore be damaged if mounted in an inadmissible position.

• Only operate the device in admissible mounting positions.

2.1 General safety instructions

MWARNING

Unrecognized dangers due to missing or illegible warning labels

Dangers might not be recognized if warning labels are missing or illegible. Unrecognized dangers may cause accidents resulting in serious injury or death.

- Check that the warning labels are complete based on the documentation.
- Attach any missing warning labels to the components, where necessary in the national language.
- Replace illegible warning labels.

NOTICE

Device damage caused by incorrect insulation resistance tests

High test voltages can damage the device.

- Measure the insulation resistance of low voltage circuits of machines or systems only with \leq 500 V DC.
- Measure the insulation resistance of SELV circuits of machines or systems only with ≤ 250 V DC.

NOTICE

Device damage caused by incorrect voltage tests

High test voltages can damage the device. Capacitive leakage currents can falsify the test results.

• Disconnect the components before you carry out a voltage test on the machine. 1)

¹⁾ The components are voltage tested in accordance with the IEC 61800-5-1 product standard and must be disconnected during testing in accordance with IEC 60204-1:2021 Section 18.4.



Unexpected movement of machines caused by inactive safety functions

Inactive or non-adapted safety functions can trigger unexpected machine movements that may result in serious injury or death.

- Observe the information in the appropriate product documentation before commissioning.
- Carry out a safety inspection for functions relevant to safety on the entire system, including all safety-related components.
- Ensure that the safety functions used in your drives and automation tasks are adjusted and activated through appropriate parameterizing.
- Run a function test.
- Only put your plant into live operation once you have guaranteed that the functions relevant to safety are running correctly.

Note

Important safety instructions for Safety Integrated functions

If you want to use Safety Integrated functions, you must observe the safety instructions in the Safety Integrated documentation.

2.2 Handling electrostatic sensitive devices (ESD)

Electrostatic sensitive devices (ESD) are individual components, integrated circuits, modules or devices that may be damaged by either electric fields or electrostatic discharge.



NOTICE

Equipment damage due to electric fields or electrostatic discharge

Electric fields or electrostatic discharge can cause malfunctions through damaged individual components, integrated circuits, modules or devices.

- Only pack, store, transport and send electronic components, modules or devices in their original packaging or in other suitable materials, e.g. conductive foam rubber or aluminum foil.
- Only touch components, modules and devices when you are grounded by one of the following methods:
 - Wearing an ESD wrist strap
 - Wearing ESD shoes or ESD grounding straps in ESD areas with conductive flooring
- Only place electronic components, modules or devices on conductive surfaces (table with ESD surface, conductive ESD foam, ESD packaging, ESD transport container).

2.3 Warranty and liability for application examples

The application examples are not binding and do not claim to be complete regarding configuration, equipment or any eventuality which may arise. Application examples are not customer-specific solutions, but merely provide assistance with typical tasks.

As user, you are responsible for ensuring that the products described are operated correctly. Application examples do not relieve you of your responsibility for safe handling when using, installing, operating and maintaining the equipment.

2.4 Industrial cybersecurity

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, systems, machines and networks.

In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial security concept. Products and solutions from Siemens constitute one element of such a concept.

Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. These systems, machines and components should only be connected to an enterprise network or the Internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place.

For additional information on industrial cybersecurity measures that may be implemented, please visit:

https://www.siemens.com/cybersecurity-industry (https://www.siemens.com/cybersecurity-industry (https://www.siemens.com/cybersecurity-industry).

Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they become available, and that only the latest product versions are used. Use of product versions that are no longer supported, and failure to apply latest updates may increase customer's exposure to cyber threats.

To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under:

https://www.siemens.com/cert (https://www.siemens.com/cert).

Additional information is provided on the Internet: Industrial security Configuration Manual (https://support.industry.siemens.com/cs/ww/en/view/108862708)

MWARNING

Unsafe operating states resulting from software manipulation

Software manipulations, e.g. viruses, Trojans, or worms, can cause unsafe operating states in your system that may lead to death, serious injury, and property damage.

- Keep the software up to date.
- Incorporate the automation and drive components into a state-of-the-art, integrated industrial cybersecurity concept for the installation or machine.
- Make sure that you include all installed products in the integrated industrial cybersecurity concept.
- Protect files stored on exchangeable storage media from malicious software by with suitable protection measures, e.g. virus scanners.
- Carefully check all cybersecurity-relevant settings once commissioning has been completed.

2.5 Residual risks of power drive systems

When assessing the machine or system-related risk in accordance with the respective local regulations (e.g. EC Machinery Directive), the machine manufacturer or system integrator must take into account the following residual risks emanating from the control and drive components of a drive system:

- 1. Unintentional movements of the driven machine or system components during commissioning, operation, maintenance and repairs caused by, for example:
 - Hardware faults and/or software errors in the sensor technology, control system, actuator technology, and connection system
 - Response times of the controller and drive
 - Operation and/or environmental conditions outside the specification
 - Condensation/conductive pollution
 - Parameterization, programming, cabling, and installation errors
 - Use of wireless devices/mobile phones in the immediate vicinity of electronic components
 - External influence/damage
 - X-rays, ionizing radiation and cosmic radiation
- 2. Unusually high temperatures including open flames as well as the emission of light, noise, particles, gases, etc. can occur inside and outside the components under fault conditions caused by, for example:
 - Component malfunctions
 - Software errors
 - Operation and/or environmental conditions outside the specification
 - External influence/damage
 - Short circuits or ground faults in the DC link of the converter
- 3. Hazardous shock voltages caused by, for example:
 - Component malfunctions
 - Influence of electrostatic charging
 - Induction of voltages in moving motors
 - Operation and/or environmental conditions outside the specification
 - Condensation/conductive pollution
 - External influence/damage
- 4. Electrical, magnetic and electromagnetic fields generated in operation that can pose a risk to people with a pacemaker, implants or metal replacement joints, etc. if they are too close.
- 5. Release of environmental pollutants or emissions as a result of improper operation of the system and/or failure to dispose of components safely and correctly

2.5 Residual risks of power drive systems

- 6. Influence on communication systems via the line supply, e.g. ripple-control transmitters or data communication via the line supply
- 7. Motors for use in potentially explosive areas:

When moving components such as bearings become worn, this can cause enclosure components to exhibit unexpectedly high temperatures during operation, creating a hazard in areas with a potentially explosive atmosphere.

For more information about the residual risks of the drive system components, see the relevant sections in the technical user documentation.

System overview 3

3.1 The SINAMICS range of drives

Field of application

SINAMICS is the comprehensive family of drives from Siemens designed for machine and plant engineering applications. SINAMICS offers solutions for all drive tasks:

- · Simple pump and fan applications in the process industry
- Complex single drives in centrifuges, presses, extruders, elevators, as well as conveyor and transport systems
- Drive line-ups in textile, plastic film, and paper machines as well as in rolling mill plants.
- Servo drives with a high dynamic performance for machine tools, as well as packaging and printing machines



Figure 3-1 SINAMICS as part of the Siemens modular automation system

3.1 The SINAMICS range of drives

Variants

Depending on the application, the SINAMICS range offers the ideal variant for any drive task.

- SINAMICS V converters focus on the essential issues both regarding the hardware as well as the functionality. This results in a high degree of ruggedness while at the same time reducing capital investment costs.
- SINAMICS G converters have functions that are perfect in addressing basic and medium demands relating to the dynamic response.
- SINAMICS S converters have been specially developed for use in demanding single-axis and multi-axis applications in mechanical and plant engineering and for a broad range of Motion Control tasks.

Platform concept

All SINAMICS versions are based on a platform concept. Common hardware and software components, as well as standardized tools for design, configuration and commissioning tasks, ensure high-level integration across all components. SINAMICS handles a wide variety of drive tasks without system gaps.

The different SINAMICS versions can be easily combined with each other.

Totally Integrated Automation and communication

SINAMICS is an integral component of Siemens Totally Integrated Automation. The integrated and seamless SINAMICS system covering engineering, data management, and communication at the automation level ensures solutions with low associated costs in conjunction with the SIMATIC, SIMOTION, and SINUMERIK control systems.




Figure 3-2 SINAMICS in the automation environment

Depending on the application, the appropriate converter can be selected and incorporated in the automation concept. With this in mind, the converters are clearly subdivided into their different applications. A wide range of communication options (depending on the drive type) are available for establishing a communication link to the automation system:

- PROFINET
- PROFIBUS
- EtherNet/IP
- Modbus TCP
- Modbus RTU
- AS-interface
- CANopen
- BacNet MS/TP

3.1 The SINAMICS range of drives

Integrated Drive System (IDS)

The Siemens Integrated Drive Systems (IDS) solution offers perfectly matched drive components with which you can meet your requirements. The drive components come into their own as Integrated Drive System, extending from engineering and commissioning through to operation.

The Drive Technology Configurator is is used to configure a seamlessly integrated system: Simply select the motor and converter and dimension them using the SIZER for Siemens Drives engineering tool.

The commissioning tools STARTER and SINAMICS Startdrive integrate the motor data at the same time, therefore simplifying efficient commissioning.

Integrated Drive Systems are integrated in the TIA Portal – which simplifies engineering, commissioning and diagnostics.

Quality management according to DIN EN ISO 9001

SINAMICS is able to meet the highest requirements in terms of quality. Comprehensive quality assurance measures in all development and production processes ensure a consistently high level of quality.

It goes without saying that our quality management system is certified by an independent authority in accordance with EN ISO 9001.

Universal applications

SINAMICS meets the requirements of relevant international standards and regulations - from the EN European standards through IEC to UL and cULus.

System properties

The SINAMICS range is characterized by the following system properties:

- Standard and seamless functionality based on a platform concept
- · Standardized engineering
- High degree of flexibility and combination capability
- Wide range of power ratings
- Designed for global use
- SINAMICS Safety Integrated
- Higher economic efficiency and effectiveness
- High energy efficiency
- Wide range of coupling options to higher-level control systems
- Totally Integrated Automation

3.2 SINAMICS S120 drive system

Modular system for sophisticated drive tasks

SINAMICS S120 solves demanding drive tasks for a wide range of industrial applications and is, therefore, designed as a modular system. Users can choose from many different harmonized components and functions to create a solution that best meets their requirements. SIZER, a high-performance engineering tool, makes it easier to choose and determine the optimum drive configuration. SINAMICS S120 is enhanced by a wide range of motors. Whether synchronous or induction, all motor types are supported by SINAMICS S120.

Particularly suitable for multi-axis applications

Coordinated drives that carry out drive tasks together are used in many mechanical and plant engineering applications, including running gears in gantry cranes, stretching systems in the textile industry, or paper machines and rolling mills. These require drives with a connected DC link which allows cost-saving energy balancing between braking and driving axes.

SINAMICS S120 features Line Modules (infeed modules) and Motor Modules (inverter modules) covering a wide power range which, having been designed for seamless integration, pave the way for compact multi-axis drive configurations.

3.2 SINAMICS S120 drive system




Figure 3-3 SINAMICS S120 system overview

System architecture with a central Control Unit

Electronically coordinated individual drives work together to perform your drive tasks. Higher-level controllers operate the drives to achieve the required coordinated movement. This requires cyclic data exchange between the controller and all the drives. This exchange usually took place via a field bus, which required a great deal of time and effort for installation and configuration. SINAMICS S120 takes a different approach. A central Control Unit controls the drive for all connected axes and also establishes the technological links between the drives and/or axes. Since all the required data is stored in the central Control Unit, it does not need to be transferred. Inter-axis connections can be established within a Control Unit and easily configured in the STARTER commissioning tool using a mouse.

The SINAMICS S120 Control Unit solves basic technological tasks autonomously. For complex numerical or motion-control tasks, high-performance SIMOTION D modules are used instead.

DRIVE-CLiQ – the digital interface between all components

All SINAMICS S120 components, including the motors and encoders, are interconnected by a shared serial interface called DRIVE-CLiQ. The standardized cables and connectors reduce the variety of different parts and cut stock inventory costs.

Converter boards (Sensor Modules) for converting standard encoder signals to DRIVE-CLiQ are available for third-party motors or retrofit applications.

Electronic rating plates in all components

An important digital linkage element of the SINAMICS S120 drive system are the electronic type plates integrated in every component. They allow all drive components to be detected automatically via a DRIVE-CLiQ link. As a result, data does not need to be entered manually when commissioning or replacing components – making commissioning even more secure and reliable!

The electronic rating plates of the motors contain, for example, the parameters of the electrical equivalent circuit diagram and the characteristic data of the integrated motor encoder in addition to information such as article and identification numbers.

SINAMICS S120 components

The SINAMICS S120 components are primarily used for multi-axis drive tasks.

The following power components are available:

- Line-side power components, such as fuses, contactors, line reactors and line filters for switching the power supply and complying with EMC regulations.
- Line Modules, which supply power centrally to the DC link.
- **DC-link components** which are used optionally to stabilize the DC-link voltage.
- Motor Modules, which act as inverters, receive power from the DC link, and supply the
 connected motors.
- Motor-side components, such as sine-wave filters, motor reactors, and dV/dt filters for reducing the voltage loads on the motor windings.

To carry out the required functions, SINAMICS S120 is equipped with:

- A Control Unit that carries out all drive and technological functions across all axes.
- Additional system components that enhance functionality and offer different interfaces for encoders and process signals.

SINAMICS S120 components were developed for installation in cabinets. They have the following features and characteristics:

- Easy to handle, simple installation and wiring
- Practical connection system, cable routing according to EMC requirements
- · Standardized design, seamless integration.

3.3 Technical specifications

Unless specified otherwise, the following technical data is valid for all the following components of the air-cooled SINAMICS S120 drive system.

Table 3-1 General technical data

Electrical data					
Line supply voltage	• 3 AC 380 V -10% (-15% < 1 min) 3 AC 480 V +10%				
	• 3 AC 500 V -10 % (-15 % < 1 min) 3 AC 690 V +10 %				
Line frequency	47 63 Hz				
Output voltage	O to line supply voltage, depending on the type of infeed. With an Active Line Module, it is also possible to achieve a higher output voltage.				
Output frequency	Vector control: 0 550 Hz ¹⁾ Servo control: 0 550 Hz ¹⁾ U/f control: 0 550 Hz ¹⁾				
Electronics power supply	24 V DC (20.4 28.8 V) implemented as PELV circuit according to IEC 61800-5-1 Ground = negative pole grounded through the electronics				
Maximum short-circuit current lcc according to IEC, in conjunction with the specified fuses or circuit breakers for devices in the Chassis format	 1.1 447 kW: 65 kA 448 671 kW: 84 kA 672 1193 kW: 170 kA >1194 kW: 200 kA 				
Maximum short-circuit current lcc according to IEC, in conjunction with the specified fuses or circuit breakers for devices in the Chassis-2 format	100 kA				
Rated short-circuit current SCCR (Short Circuit Current Rating) in accordance with UL508C (up to 600 V), in conjunction with the specified fuses or circuit breakers	 1.1 447 kW: 65 kA 448 671 kW: 84 kA 672 1193 kW: 170 kA >1194 kW: 200 kA 				
Rated short-circuit current SCCR (Short-Circuit Current Rating) according to UL61800-5-1, in conjunction with the specified fuses or circuit breakers for devices in the Chassis-2 format	100 kA				
Frequency with which the DC link is pre- charged	Max. 1 precharge every 3 minutes				
Overvoltage category	Class III according to IEC 61800-5-1				
Electromagnetic compatibility (EMC)					
Emitted interference					
• Standard	Category C3 (second environment) according to IEC 61800-3				
With line filter	Category C2 (first *) and second environments) according to IEC 61800-3				
	*) When used in the first environment, an appropriately trained and authorized technical person must set up the drive and commission it.				
	NOTE: An appropriately trained and authorized technician is person or organization with the required experience for setting up and/or for commissioning the drive systems, including the associated EMC aspects.				
Noise immunity	Use in the first and second environments according to IEC 61800-3				

Mechanical data	
Vibratory load	
Transport ²⁾	• IEC 60721-3-2:1997, Class 2M2
Operation	Test values according to IEC 60068-2-6 test Fc:
·	– 10 58 Hz: Constant deflection = 0.075 mm
	 58 150 Hz: Constant acceleration = 9.81 m/s² (1 g)
Shock load	
Transport ²⁾	• IEC 60721-3-2:1997, Class 2M2
Operation	• Test values according to IEC 60068-2-27 test Ea: 98 m/s² (10 g) / 20 ms
Ambient conditions	, , ,
Degree of protection	IP00 or IP20 acc. to IEC 60529
Protection class	Class I (with protective conductor system) and Class III (PELV) acc. to IEC 61800-5-1
Touch protection	EN 50274 and DGUV regulation 3 when used for the intended purpose
Permissible ambient and coolant tempera- ture (air) during operation for line-side components, Line Modules and Motor Modules	0 +40 °C without derating, >40 +55 °C see derating characteristics
Permissible ambient and coolant tempera- ture (air) during operation for Active Inter- face Modules, Active Line Modules and Motor Modules Chassis-2	-10 +45 °C for installation altitudes ≤ 1000 m above sea level without derating -10 +40 °C for installation altitudes ≤ 2000 m above sea level without derating >45 +60 °C for installation altitudes ≤ 2000 m above sea level, see the derating characteristics
Permissible ambient and coolant temperature (air) during operation for DC link and motor-side power components	0 +55 °C up to 2000 m above sea level
Cooling method according to IEC 60146-1-1	Active Interface Modules, Basic Line Modules, Smart Line Modules, Active Line Modules, Motor Modules: AF
	– A: Air cooling
	 F: Forced cooling, drive unit inside the device
	 Line reactors, sine-wave filters, motor reactors, dv/dt filters with Voltage Peak Limiter: AN
	– A: Air cooling
	– N: Natural cooling (convection)
Climatic ambient conditions	
Storage ²⁾	• Class 1K4 acc. to IEC 60721-3-1:1997, temperature -25 +55 °C
• Transport ²⁾	• Class 2K4 according to IEC 60721-3-2:1997, temperature -40 +70 °C, max. air humidity 95 % at +40 °C
Operation	better than Class 3K3 according to IEC 60721-3-3:2002 Relative humidity: 5 95 % (no condensation) Oil mist, salt mist, ice formation, condensation, dripping water, spraying water, splashing water and water jets are not permitted
Environmental class / harmful chemical s	ubstances
Storage ²⁾	• Class 1C2 according to IEC 60721-3-1:1997
Transport ²⁾	• Class 2C2 according to IEC 60721-3-2:1997
Operation	• Class 3C2 according to IEC 60721-3-3:2002

3.3 Technical specifications

Environmental class /mechanically active	substances					
Storage ²⁾	Class 1S1 according to IEC 60721-3-1:1997					
Transport ²⁾	Class 2S1 according to IEC 60721-3-2:1997					
Operation	Class 3S1 according to IEC 60721-3-3:2002					
Organic/biological influences						
Storage ²⁾	Class 1B1 according to IEC 60721-3-1:1997					
Transport ²⁾	Class 2B1 according to IEC 60721-3-2:1997					
Operation	Class 3B1 according to IEC 60721-3-3:2002					
Degree of pollution	2 according to IEC 61800-5-1					
	The devices may be operated only in environments with degree of pollution 2 and without condensation. On control cabinets with forced air cooling, foreign particles must be filtered out of the inflow air through filter mats.					
	To prevent condensation, the devices can be warmed constantly by heaters.					
The Safety Integrated safety function:						
The components must be protected against protection IP54B according to EN 60529.	conductive contamination, e.g. by installing them in a cabinet with degree of					
Provided that conducted interference can be decreased accordingly.	e prevented at the installation site, the degree of protection for the cabinet can					
Installation altitude	> 2000 m above sea level without derating					
	• > 2000 4000 m above sea level, see derating characteristics					
Compliance with standards						
Conformity	- EMC Directive 2014/30/EU - Low-Voltage Directive 2014/35/EU - RoHS II guideline 2011/65/EU - machinery directive 2006/42/EC for functional safety - UKCA					
Standards	IEC 61800-5-1, IEC 60204-1, IEC 61800-3, IEC 60146-1-1					
Approvals (only up to 3 AC 600 V)	cULus (File Nos.: E192450, E214113 and E253831) being prepared: All Motor Modules Chassis-2 EAC, KC					

¹⁾ Depending on the system configuration, higher output frequencies are possible.

Note on the design of a UL-approved system

Note

Design of a UL-approved system

For a UL-approved system use 60/75° C copper conductors only.

²⁾ In transport packaging

3.4 Derating factors as a function of installation altitude and ambient temperature

Chassis format units

At installation altitudes > 2000 m above sea level, it must be taken into account that the air pressure, and therefore air density, decreases as the height increases. This reduces the cooling effect as well as the insulating strength of the air.

As a result of the lower cooling effect, on one hand, the ambient temperature must be reduced, and on the other hand, the power loss in the chassis unit must also be reduced by decreasing the output current; whereby ambient temperatures less than 40 °C can be factored in as countermeasure for compensation.

The following table shows the permissible output currents as a function of installation altitude and ambient temperature (the permissible compensation between installation altitude and ambient temperatures of $< 40 \, ^{\circ}\text{C}$ – air intake temperature at the air intake of the chassis unit – is taken into account in the specified values).

The values apply under the precondition that a cooling air flow through the devices is ensured as specified in the technical specifications.

As an additional measure at installation altitudes from 2000 m up to 5000 m, an isolation transformer must be used to reduce transient overvoltages in accordance with IEC 61800-5-1.

Chassis units and the associated system components are rated for an ambient temperature of 40 °C and installation altitudes up to 2000 m above sea level.

At ambient temperatures > 40 °C, the output current must be reduced. Ambient temperatures above 55 °C are not permissible.

Table 3- 2 Current derating for chassis units as a function of ambient temperature (air intake temperature at the air inlet of the chassis unit) and installation altitude

Installation altitude above sea level in m	Current derating factor (as a % of the rated current) for an ambient air temperature (air intake temperature) of							
	20 °C	25 °C	30 °C	35 °C	40 °C	45 °C	50 °C	55 °C
0 2000	100%	100%	100%	100%	100%	93.3 %	86.7 %	80.0 %
2500	100%	100%	100%	100%	96.3 %			
3000	100%	100%	100%	98.7%				
3500	100%	100%	100%					
4000	100%	100%	96.3 %					
4500	100%	97.5%						
5000	98.2%							

3.4 Derating factors as a function of installation altitude and ambient temperature

Built-in devices, Chassis-2 format

At installation altitudes > 2000 m above sea level, it must be taken into account that the air pressure, and therefore air density, decreases as the height increases. As a consequence, in addition to the reduced cooling effect, the insulating capability of the air is also reduced.

As a result of the lower cooling effect, on one hand, the ambient temperature must be reduced, and on the other hand, the power loss in the chassis unit must also be reduced by decreasing the output current; whereby ambient temperatures less than 40 °C can be factored in as countermeasure for compensation.

The following table shows the permissible output currents as a function of installation altitude and ambient temperature (the permissible compensation between installation altitude and ambient temperatures of $< 40\,^{\circ}\text{C}$ – air intake temperature at the air intake of the chassis unit – is taken into account in the specified values).

The values apply under the precondition that a cooling air flow through the devices is ensured as specified in the technical specifications.

As an additional measure at installation altitudes from 2000 m up to 5000 m, an isolation transformer must be used to reduce transient overvoltages in accordance with IEC 61800-5-1.

Built-in devices in the Chassis-2 format and the associated system components are rated for an ambient temperature of 45 °C and installation altitudes up to 1000 m above sea level.

The output current must be reduced for ambient temperatures > 45 °C. Ambient temperatures above 60 °C are not permissible.

Table 3-3 Current derating for built-in units Chassis-2 as a function of ambient temperature (air intake temperature at the air inlet of the built-in devices) and installation altitude

Installation altitude above sea level in m		Current derating factor (as a % of the rated current) for an ambient air temperature (air intake temperature) of							
	20 °C	25 °C	30 °C	35 °C	40 °C	45 °C	50 °C	55 °C	60 °C
0 1000	100%	100%	100%	100%	100%	100%	83 %	69%	54 %
1500	100%	100%	100%	100%	100%	98%	81%	67 %	52%
2000	100%	100%	100%	100%	100%	93%	78 %	65 %	50 %
2500	100%	100%	100%	100%	96 %				
3000	100%	100%	100%	99%					
3500	100%	100%	100%						
4000	100%	100%	96 %						
4500	100%	97 %							
5000	98%								

3.5 Standards

Note

Information on the listed standards

The standards listed in the table below are non-binding and do not in any way claim to be complete. The standards listed do not represent a guaranteed property of the product.

Only the statements made in the Declaration of Conformity shall be deemed binding.

Table 3-4 Fundamental, application-relevant standards in succession: EN, IEC/ISO, DIN, VDE

Standards*	Title
EN ISO 3744	Acoustics - Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free acoustic field over a reflecting plane
ISO 14118 DIN EN ISO 14118	Safety of machinery; avoiding unexpected starting
EN ISO 9001 ISO 9001 DIN EN ISO 9001	Quality management systems - requirements
ISO 12100 DIN EN ISO 12100	Safety of Machinery – General Design Guidelines – Risk Assessment and Risk Minimization
EN ISO 13849-x ISO 13849-x DIN EN ISO 13849-x	Safety of Machinery; Safety-Related Parts of Control Systems Part 1: General Basic Design Principles Part 2: Validation
EN ISO 14121-2 ISO 14121-2 DIN EN ISO 14121-2	Safety of Machinery - Risk Assessment; Part 2: Practical guidelines and process examples.
EN 55011 CISPR 11 DIN EN 55011 VDE 0875-11	Industrial, scientific and medical high-frequency devices (ISM devices) - radio interference - limit values and measuring techniques
EN 60146-1-1 IEC 60146-1-1 DIN EN 60146-1-1 VDE 0558-11	Semiconductor converters; general requirements and line-commutated converters Part 1-1: Defining the basic requirements
EN 60204-1 IEC 60204-1 DIN EN 60204-1 VDE 0113-1	Electrical equipment of machines Part 1: General definitions
EN 60228 IEC 60228 DIN EN 60228 VDE0295	Conductors for cables and insulated leads
EN 60269-1 IEC 60269-1 DIN EN 60269-1 VDE 0636-1	Low-voltage fuses Part 1: General requirements
IEC 60287-1 to -3	Cables – Calculation of the current carrying capacity Part 1: Current carrying capacity equations (100 % load factor) and calculating the losses Part 2: Thermal resistance - Part 3: Main sections for operating conditions

3.5 Standards

Standards*	Title
HD 60364-x-x IEC 60364-x-x DIN VDE 0100-x-x VDE 0100-x-x	Erection of power installations with nominal voltages up to 1000 V Part 200: Definitions Part 410: Protection for safety, protection against electric shock Part 420: Protection for safety, protection against thermal effects Part 430: Protection of cables and conductors for overcurrent Part 450: Protection for safety, protection against undervoltage Part 470: Protection for safety; use of protection for safety Part 5xx: Selecting and erecting electrical equipment Part 520: Cables, conductors, busbars Part 540: Grounding, protective conductor, potential bonding conductor Part 560: Electrical equipment for safety purposes
EN 60529 IEC 60529 DIN EN 60529 VDE 0470-1	Degrees of protection provided by enclosures (IP code)
EN 60721-3-x IEC 60721-3-x DIN EN 60721-3-x	Classification of environmental conditions Part 3-0: Classification of environmental parameters and their severities; Introduction Part 3-1: Classification of environmental parameters and their severities; Long-term storage Part 3-2: Classification of environmental parameters and their severities; Transport Part 3-3: Classification of environmental parameters and their severities; stationary use, weather protected
EN 60947-x-x IEC 60947 -x-x DIN EN 60947-x-x VDE 0660-x	Low-voltage switchgear
EN 61000-6-x IEC 61000-6-x DIN EN 61000-6-x VDE 0839-6-x	Electromagnetic compatibility (EMC) Part 6-1: Generic standard; Immunity for residential, commercial and light-industrial environments Part 6-2: Generic standards; Immunity for industrial environments Part 6-3: Generic standards; Generic standard emission for residential, commercial and light-industrial environments Part 6-4: Generic standards; Generic standard noise emission for industrial environments
EN 61140 IEC 61140 DIN EN 61140 VDE 0140-1	Protection against electric shock; Common aspects for installation and equipment
EN 61439 IEC 61439 DIN EN 61439 VDE 0660-600	Low-voltage switchgear assemblies Part 1: General definitions
EN 61800-2 IEC 61800-2 DIN EN 61800-2 VDE 0160-102	Adjustable-speed electrical power drive systems Part 2: General requirements - Rating specifications for low-voltage adjustable frequency a.c. power drive systems
EN 61800-3 IEC 61800-3 DIN EN 61800-3 VDE 0160-103	Adjustable-speed electrical power drive systems; Part 3: EMC - Requirements and specific test methods
EN 61800-5-x IEC 61800-5-x DIN EN 61800-5-x VDE 0160-105-x	Adjustable-speed electrical power drive systems Part 5: Safety requirements; Main section 1: Electrical, thermal and energy requirements Main section 2: Functional safety requirements
EN 62061 IEC 62061 DIN EN 62061 VDE 0113-50	Safety of machinery Functional safety of safety-related electrical, electronic and programmable electronic control systems
UL 50 CSA C22.2 No. 94.1	Enclosures for Electrical Equipment

Standards*	Title
UL 508 CSA C22.2 No. 142	Industrial Control Equipment Process Control Equipment
UL 508C CSA C22.2 No. 14	Power Conversion Equipment Industrial Control Equipment
UL61800-5-1 CSA 22.2 No. 274-13	Standard for Adjustable Speed Electrical Power Drive Systems - Part 5-1: Safety requirements – Electrical, thermal and energy

^{*} The technical requirements in the standards listed are not necessarily identical.

3.6 Basic structure of a drive system with SINAMICS S120

3.6.1 Structure of a drive system with SINAMICS S120 and regulated infeed




Figure 3-4 Basic structure of a drive system with SINAMICS S120 and regulated infeed

3.6.2 Structure of a drive system with SINAMICS S120 and uncontrolled infeed/regenerative feedback unit




Figure 3-5 Basic structure of a drive system with SINAMICS S120 and uncontrolled infeed/regenerative feedback

3.6.3 Structure of a drive system with SINAMICS S120 and unregulated infeed




Figure 3-6 Basic structure of a drive system with SINAMICS S120 and unregulated infeed

Line-side power components

4.1 General

Line-side power components are used to protect the connected components against transient or continuous overvoltages and ensure that prescribed limit values are adhered to.

4.2 Line filters for Basic Line Modules

4.2.1 Description

The line filters limit the conducted interference emitted by the Power Modules to permissible values.

To reduce emissions, the Line Modules are equipped as standard with a line filter in accordance with the limit values defined in category C3 (second environment). The additional line filters described here is available for use in Category C2 (first and second environment).

In conjunction with line reactors, line filters limit the conducted interference emitted by the Power Modules to limit values defined in product standard IEC 61800-3. Provided that the system has been set up in accordance with the EMC installation guidelines, the limit values at the installation location will be in accordance with the requirements for the first environment.

The line filters are suitable for TN and TT systems grounded at the neutral point.

Table 4- 1 Assignment of line filter and Basic Line Module

Basic Line Module	Rated power of the Basic Line Module	Suitable line filter					
	Line voltage 380 – 480 V 3 AC						
6SL3330-1TE34-2AA3	200 kW	6SL3000-0BE34-4AA0					
6SL3330-1TE35-3AA3	250 kW	6SL3000-0BE36-0AA0					
6SL3330-1TE38-2AA3	400 kW	6SL3000-0BE41-2AA0					
6SL3330-1TE41-2AA3	560 kW	6SL3000-0BE41-2AA0					
6SL3330-1TE41-5AA3	710 kW	6SL3000-0BE41-6AA0 1)					
6SL3330-1TE41-5AA3	710 kW	6SL3760-0MR00-0AA0 ²⁾					
6SL3330-1TE41-8AA3	900 kW	6SL3000-0BE41-6AA0					

4.2 Line filters for Basic Line Modules

Basic Line Module	Rated power of the Basic Line Module	Suitable line filter
	Line voltage 500 – 690 V 3 AC	
6SL3330-1TG33-3AA3	250 kW	6SL3000-0BG34-4AA0
6SL3330-1TG34-3AA3	355 kW	6SL3000-0BG34-4AA0
6SL3330-1TG36-8AA3	560 kW	6SL3000-0BG36-0AA0
6SL3330-1TG41-1AA3	900 kW	6SL3000-0BG41-2AA0
6SL3330-1TG41-4AA3	1100 kW	6SL3000-0BG41-2AA0
6SL3330-1TG41-8AA3	1500 kW	6SL3000-0BG41-6AA0

¹⁾ If a Motor Module Chassis-2 is not connected to the DC link, then line filter 6SL3000-0BE41-6AA0 can be used when the device is deployed in category C2 (first and second environment).

4.2.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.

ACAUTION

Burns resulting from high surface temperatures

The line filter can become very hot. Contact with the surface can result in severe burns.

- Mount the line filter so that contact is not possible. If this is not possible, attach a clearly visible and understandable warning notice at hazardous positions.
- To prevent adjacent components from suffering damage due to these high temperatures, maintain a clearance of 100 mm on all sides of the line filter.

NOTICE

Line filter damage by connecting to impermissible line supplies

The line filters are only suitable for direct connection to TN or TT systems with grounded neutral point. Line filters are designed for connection to systems with a continuous level to voltage harmonics in accordance with IEC 61000-2-4, Class 3. Connection of the line filter to other line systems may result in damage.

• Only connect the line filter to TN or TT systems with grounded neutral point and a continuous level of voltage harmonics in accordance with IEC 61000-2-4, Class 3.

²⁾ If a Motor Module Chassis-2 is connected to the DC link, then the line filter 6SL3760-0MR00-0AA0 must be used when used in category C2 (first and second environment).

NOTICE

Line filter damage due to interchanged connections

The line filter will be damaged if the input and output connections are interchanged.

- Connect the incoming line cable to LINE/NETZ L1, L2, L3.
- Connect the outgoing cable to the line reactor to LOAD/LAST L1', L2', L3'.

MARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating of components with subsequent fire and smoke. This can cause serious injury or even death. This can also result in increased failures and shorter service lives for devices/systems.

• For this reason, maintain the 100 mm clearances above and below the line filter.



WARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. ¹⁾
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - It complies with the local regulations for equipment with increased leakage current.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.

NOTICE

Damage to additional loads as a result of undesirable line harmonics

Line harmonics can occur if line filters that differ from those listed in this Equipment Manual are used. These can disturb or damage other loads connected to the line supply.

• Only use line filters that are listed in this Equipment Manual.

4.2 Line filters for Basic Line Modules

NOTICE

Damage to components by incorrectly connecting the line filter

When incorrectly connecting the line filter, these components can be destroyed or damaged.

- Only connect the Line Module to the SINAMICS line filter via the associated line reactor.
- Connect additional loads upstream of the SINAMICS line filter (if required, via a separate line filter).

Note

Motor cable length exceeded

When the maximum motor cable length of 100 m is exceeded, it can no longer be guaranteed that Class C2/C3 is maintained; for very long motor cables this can mean that the line-side or motor-side power components can overheat.

Additional information is provided in the Low Voltage Engineering Manual.

Note

Disconnect the line filter for a high-voltage test

If a high-voltage test is conducted with alternating voltage in the system, the existing line filters must be disconnected in order to obtain accurate measurements.

If a high-voltage test is carried out with a DC voltage, the connection clip of the integrated basic interference suppression module to ground in the Basic Line Module must also be removed, refer to Chapter "Electrical connection (Page 147)".

4.2.3 Dimension drawing




Figure 4-1 Dimension drawing of line filters for Basic Line Modules

4.2 Line filters for Basic Line Modules

Table 4- 2 Dimensions of line filters for Basic Line Modules (all data in mm)

	6SL3000-0BE34- 4AA0 6SL3000-0BG34- 4AA0	6SL3000-0BE36- 0AA0 6SL3000-0BG36- 0AA0	6SL3000-0BE41- 2AA0 6SL3000-0BG41- 2AA0	6SL3000-0BE41- 6AA0 6SL3000-0BG41- 6AA0	6SL3760-0MR00- 0AA0
В	360	400	425	505	425
Н	240	265	265	265	265
Т	116	140	145	145	148
a1	40	40	50	90	49.5
a2	25	25	50	50	50
a3	5	8	10	15	10
a4	15	15	20	20	20
a5	11	11	14	14	14
a6	_	_	_	40	_
b	270	310	315	315	315
h1	200	215	215	215	215
h2	100	120	142	142	142
t1	2	3	2.5	2.5	2.5
t2	78.2	90	91	91	94
n1 ¹⁾	220	240	240	240	240
n2 ¹⁾	210	250	255	255	255
n3	330	370	385	465	385
n4	-	125	127.5	127.5	127.5
d	9	12	12	12	12

¹⁾ Lengths n1 and n2 correspond to the distance between holes

4.2.4 Technical data

Table 4-3 Technical data of line filters for Basic Line Modules, 3 AC 380 ... 480 V, Part I

Article number	6SL3000-	0BE34-4AA0	0BE36-0AA0	0BE41-2AA0	0BE41-6AA0
Suitable for Basic Line Module	6SL3330-	1TE34-2AA3	1TE35-3AA3	1TE38-2AA3 1TE41-2AA3	1TE41-5AA3 ¹⁾ 1TE41-8AA3
Rated power of the Basic Line Module	kW	200	250	400 560	710 900
Rated voltage	V	3 A(C 380 -10% (-15% < 1	I min) 3 AC 480 +	10%
Rated current	А	440	600	1200	1600
Power loss	kW	0.047	0.053	0.119	0.153
Line/load connection L1, L2, L3, L1', L2', L3'		M10 connecting lugs	M10 connecting lugs	M12 connecting lugs	M12 connecting lugs
PE connection		M8	M10	M10	M10
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	360 240 116	400 265 140	425 265 145	505 265 145
Weight	kg	12.3	19.0	25.8	28.8

¹⁾ If a Motor Module Chassis-2 is not connected to the DC link, then line filter 6SL3000-0BE41-6AA0 can be used upstream of the Basic Line Module 6SL3330-1TE41-5AA3 when the device is deployed in category C2 (first and second environment).

Table 4-4 Technical data of line filters for Basic Line Modules, 3 AC 380 ... 480 V, Part II

Article number		6SL3760-0MR00- 0AA0			
Suitable for Basic Line Module	6SL3330-	1TE41-5AA3 ¹⁾			
Rated power of the Basic Line Module	kW	710			
Rated voltage	V	3 A(380 -10% (-15% <	1 min) 3 AC 480 +	10%
Rated current	Α	1200			
Power loss	kW	0.106			
Line/load connection L1, L2, L3, L1', L2', L3'		M12 connecting lugs			
PE connection		M10			
Degree of protection		IP00			
Dimensions Width Height Depth	mm mm mm	425 265 145			
Weight	kg	25			

¹⁾ If a Motor Module Chassis-2 is connected to the DC link, then the line filter 6SL3760-0MR00-0AA0 must be used upstream of the Basic Line Module 6SL33301TE41-5AA3 when used in category C2 (first and second environment).

4.2 Line filters for Basic Line Modules

Table 4-5 Technical data of line filters for Basic Line Modules, 500 ... 690 V 3 AC

Article number	6SL3000-	0BG34-4AA0	0BG36-0AA0	0BG41-2AA0	0BG41-6AA0
Suitable for Basic Line Module	6SL3330-	1TG33-3AA3 1TG34-3AA3	1TG36-8AA3	1TG41-1AA3 1TG41-4AA3	1TG41-8AA3
Rated power of the Basic Line Module	kW	250 355	560	900 1100	1500
Rated voltage	V	3 AC 500 -10% (-15% < 1 min) 3 AC 690 +10%			
Rated current	Α	440	600	1200	1600
Power loss	kW	0.047	0.053	0.119	0.182
Line/load connection L1, L2, L3, L1', L2', L3'		M10 connecting lugs	M10 connecting lugs	M12 connecting lugs	M12 connecting lugs
PE connection		M8	M10	M10	M10
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	360 240 116	400 265 140	425 265 145	505 265 145
Weight	kg	12.3	19.0	25.2	28.8

4.3 Line filters for Smart Line Modules and Active Line Modules

4.3.1 Description

The line filters limit the conducted interference emitted by the Power Modules to permissible values.

To reduce emissions, the Line Modules are equipped as standard with a line filter in accordance with the limit values defined in category C3 (second environment). The additional line filters described here is available for use in Category C2 (first and second environment).

In conjunction with line reactors and/or the Active Interface Modules, the line filters limit the conducted interference emitted by the power modules to the limit values defined in product standard IEC 61800-3. Provided that the system has been set up in accordance with the EMC installation guidelines, the limit values at the installation location will be in accordance with the requirements for the first environment.

The line filters are suitable for TN and TT systems grounded at the neutral point.

4.3.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- · When assessing the risk, take into account residual risks.

⚠ CAUTION

Burns resulting from high surface temperatures

The line filter can become very hot. Contact with the surface can result in severe burns.

- Mount the line filter so that contact is not possible. If this is not possible, attach a clearly visible and understandable warning notice at hazardous positions.
- To prevent adjacent components from suffering damage due to these high temperatures, maintain a clearance of 100 mm on all sides of the line filter.

4.3 Line filters for Smart Line Modules and Active Line Modules

NOTICE

Line filter damage by connecting to impermissible line supplies

The line filters are only suitable for direct connection to TN or TT systems with grounded neutral point. Line filters are designed for connection to systems with a continuous level to voltage harmonics in accordance with IEC 61000-2-4, Class 3. Connection of the line filter to other line systems may result in damage.

• Only connect the line filter to TN or TT systems with grounded neutral point and a continuous level of voltage harmonics in accordance with IEC 61000-2-4, Class 3.

NOTICE

Line filter damage due to interchanged connections

The line filter will be damaged if the input and output connections are interchanged.

- Connect the incoming line cable to LINE/NETZ L1, L2, L3.
- Connect the outgoing cable to the line reactor to LOAD/LAST L1', L2', L3'.



Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating of components with subsequent fire and smoke. This can cause serious injury or even death. This can also result in increased failures and shorter service lives for devices/systems.

• For this reason, maintain the 100 mm clearances above and below the line filter.



! WARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - It complies with the local regulations for equipment with increased leakage current.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.

ACAUTION

Overheating when the total length of the power cables is exceeded

Overheating and fire can result when the total length of the motor cables is exceeded.

• Ensure that the total length of the motor cables does not exceed 300 m.

NOTICE

Damage to additional loads as a result of undesirable line harmonics

Line harmonics can occur if line filters that differ from those listed in this Equipment Manual are used. These can disturb or damage other loads connected to the line supply.

• Only use line filters that are listed in this Equipment Manual.

NOTICE

Damage to components by incorrectly connecting the line filter

When incorrectly connecting the line filter, these components can be destroyed or damaged.

- Only connect the Line Module to the SINAMICS line filter via the associated line reactor or the associated Active Interface Module.
- Connect additional loads upstream of the SINAMICS line filter (if required, via a separate line filter).

Note

Motor cable length exceeded

When the maximum motor cable length of 300 m is exceeded, it can no longer be guaranteed that Class C2/C3 is maintained; for very long motor cables this can mean that the line-side or motor-side power components can overheat.

Additional information is provided in the Low Voltage Engineering Manual.

Note

Disconnect the line filter for a high-voltage test

If a high-voltage test is conducted with alternating voltage in the system, the existing line filters must be disconnected in order to obtain accurate measurements.

If a high-voltage test is carried out with a DC voltage, the connection clip of the integrated basic interference suppression module to ground in the Smart Line Module and/or in the Active Interface Module must also be removed, refer to Chapter "Electrical connection (Page 181)" or "Electrical connection (Page 99)".

4.3.3 Dimension drawing




Figure 4-2 Dimension drawing for Line filters for Smart Line Modules and Active Line Modules

Table 4- 6 Dimensions of the line filters for Smart Line Modules and Active Line Modules, 380 V ... 480 V 3 AC (all specifications in mm)

	6SL3000- 0BE33-1AA0	6SL3000- 0BE35-0AA0	6SL3760- 0MB00-0AA0	6SL3760- 0MC00-0AA0
В	360	390	425	505
Н	240	265	265	265
T	116	140	145	145
a1	40	40	50	90
a2	25	30	50	50
a3	5	8	10	15
a4	15	15	20	20
a5	11	11	14	14
a6	=	-	-	40
b	270	310	315	315
h1	200	215	215	215
h2	100	120	142	142
t1	2	2.5	2.5	2.5
t2	78.2	90	91	91
n1 ¹⁾	220	240	240	240
n2 ¹⁾	210	250	255	255
n3	330	370	385	465
n4	-	-	127.5	127.5
d	9	12	12	12

¹⁾ Lengths n1 and n2 correspond to the distance between holes

4.3 Line filters for Smart Line Modules and Active Line Modules

Table 4-7 Dimensions of the line filters for Smart Line Modules and Active Line Modules, 500 V ... 690 V 3 AC (all specifications in mm)

	6SL3760- 0ME00-0AA0	6SL3760- 0MN00-0AA0	6SL3760- 0MG00-0AA0	
В	400	425	505	
Н	365	365	365	
T	140	145	145	
a1	38	50	90	
a2	30	50	50	
a3	8	15	15	
a4	15	20	20	
a5	11	14	14	
a6	-	-	40	
b	310	315	315	
h1	315	315	315	
h2	120	142	142	
t1	3	2.5	2.5	
t2	90	91	91	
n1 ¹⁾	340	340	310	
n2 ¹⁾	250	255	255	
n3	370	385	465	·
n4	125	127.5	127.5	
d	12	12	12	

¹⁾ Lengths n1 and n2 correspond to the distance between holes

4.3.4 Technical data

Table 4-8 Technical data of the line filters for the Smart Line Modules and Active Line Modules, 3 AC 380 V ... 480 V

Article number		6SL3000- 0BE33-1AA0	6SL3000- 0BE35-0AA0	6SL3760- 0MB00-0AA0	6SL3760- 0MC00-0AA0
Suitable for Smart Line Module	6SL3330-	-	6TE35-5AA3	6TE37-3AA3	6TE41-1AA3 6TE41-3AA3 6TE41-7AA3
Suitable for Active Line Module	6SL3330-	7TE32-1AA3 7TE32-6AA3	7TE33-8AA3 7TE35-0AA3	7TE36-1AA3 7TE37-5AA3	7TE38-4AA3 7TE41-0AA3 7TE41-2AA3 7TE41-4AA3
Rated voltage	V	3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10%			
Rated current	Α	400	600	840	1405
Power loss	kW	0.042	0.06	0.058	0.111
Line supply/load connection L1, L2, L3/L1', L2', L3'		M10 connecting lugs	M10 connecting lugs	M12 connecting lugs	M12 connecting lugs
PE connection		M8	M10	M10	M10
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	360 240 116	390 265 140	425 265 145	505 265 145
Weight	kg	12.7	19.9	25.9	28.9

Table 4-9 Technical data of the line filters for the Smart Line Modules and Active Line Modules, 3 AC 500 V ... 690 V

Article number		6SL3760- 0ME00-0AA0	6SL3760- 0MN00-0AA0	6SL3760- 0MG00-0AA0	
Suitable for Smart Line Module	6SL3330-	6TG35-5AA3	6TG38-8AA3 6TG41-2AA3	6TG41-7AA3	
Suitable for Active Line Module	6SL3330-	7TG35-8AA3	7TG37-4AA3 7TG41-0AA3	7TG41-3AA3	
Rated voltage	V	3 AC 500 -10% (-15% < 1 min) 3 AC 690 +10%			
Rated current	Α	600	1025	1270	
Power loss	kW	0.063	0.063	0.097	
Line supply/load connection L1, L2, L3/L1', L2', L3'		M10 connecting lugs	M12 connecting lugs	M12 connecting lugs	
PE connection		M10	M10	M10	
Degree of protection		IP00	IP00	IP00	
Dimensions Width Height Depth	mm mm mm	400 365 140	425 365 145	505 365 145	
Weight	kg	27.0	36.7	36.7	

4.4 Line reactors for Basic Line Modules

4.4.1 Description

Line reactors limit low-frequency line harmonics and reduce the load on the semiconductors in the Basic Line Modules. A line reactor must be used in connection with a line filter or if several Basic Line Modules are operated in parallel.

If a Basic Line Module is operated singly and no line filter is used, and with an effective line impedance uk > 3%, the line reactor is not necessary.

4.4.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

ACAUTION

Burns resulting from high surface temperature

The line reactors can become very hot. You can get seriously burnt when touching the surface.

- Mount the line reactors so that contact is not possible. If this is not possible, attach clearly visible and understandable warning notices at hazardous positions.
- To prevent adjacent components from suffering damage due to these high temperatures, maintain a clearance of 100 mm on all sides of the line reactors.

NOTICE

Damage to the system caused by the use of inappropriate and not approved line reactors

Inappropriate line reactors that have not been approved can damage the Line Modules.

Line harmonics that damage/disturb other loads connected to the same line supply can also occur.

• Only use line reactors which are listed in this Manual.

Note

Malfunctions through magnetic fields

Reactors produce magnetic fields that can disturb or damage components and cables.

 Arrange the components and cables at a suitable distance (at least 200 mm) or shield the magnetic fields appropriately.

Note

Length of connection cables

The connection cables between line reactor and Line Module, as well as between line reactor and line filter, must be kept as short as possible (max. 5 m).

You must use shielded connection cables, whose cable shields are attached at both ends.

Shielding can only be omitted if the following conditions are met:

- The cables do not exceed 1 m in length.
- The cables are laid flush with the rear metal wall of the control cabinet.
- The cables are laid in a way that keeps them physically separate from signal cables.

Do not route any cables near the line reactor. If this cannot be avoided, observe a minimum distance of 200 mm.

4.4.3 Dimension drawing




Figure 4-3 Dimension drawing of line reactors for Basic Line Modules

Table 4- 10 Dimensions of line reactors for Basic Line Modules, 3 AC 380 V ... 480 V (all values in mm)

6SL3000-	0CE35-1AA0	0CE37-7AA0	0CE41-0AA0	0CE41-5AA0	0CE41-6AA0
a2	30	30	50	60	60
a3	6	6	8	12	12
a4	15	15	25	25	25
a5	14	14	14	14	14
a6	-	-	-	26	26
a7	-	-	-	17	17
14	300	300	350	460	410
15	100	100	120	152.5	152.5
h1	-	-	397	-	-
h2	180	180	252	278	278
h3	60	60	120	120	120
h4	269	269	321	435	419
n1 ¹⁾	118	118	138	155	155
n2 ¹⁾	224	224	264	356	356
n3	212.5	212.5	211.5	235	235
n4	81	81	60	60	60.5
d3	M8	M8	M8	M12	M12

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 4- 11 Dimensions of line reactors for Basic Line Modules, 3 AC 500 V ... 690 V (all values in mm)

6SL3000-	0CH32-7AA0	0CH34-8AA0	0CH36-0AA0	0CH41-2AA0	0CH41-6AA0
a2	25	30	30	60	60
a3	5	6	6	12	12
a4	12.5	15	15	25	25
a5	11	14	14	14	14
a6	-	-	-	26	26
a7	-	-	-	17	17
14	270	350	350	460	410
15	88	120	120	152.5	152.5
h1	-	=	=	-	-
h2	150	198	198	278	278
h3	60	75	75	120	120
h4	248	321	321	435	422
n1 ¹⁾	101	138	138	155	170
n2 ¹⁾	200	264	264	356	356
n3	200	232.5	232.5	235	247
n4	84.5	81	81	60.5	60.5
d3	M8	M8	M8	M12	M12

¹⁾ Lengths n1 and n2 correspond to the distance between holes

4.4.4 Technical data

Table 4- 12 Technical data of line reactors for Basic Line Modules, 3 AC 380 ... 480 V, Part 1

Article number	6SL3000-	0CE35-1AA0	0CE37-7AA0	0CE41-0AA0	0CE41-5AA0
Suitable for Basic Line Module	6SL3330-	1TE34-2AA3 1TE35-3AA3	1TE38-2AA3	1TE41-2AA3	1TE41-5AA3
Rated power of the Basic Line Module	kW	200 250	400	560	710
Rated voltage	V	3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10%			
Ithmax	Α	508	773	1060	1458
Power loss	kW	0.365	0.351	0.498	0.776
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M12 connecting lugs	M12 connecting lugs	M12 connecting lugs	M12 connecting lugs
PE connection		M6 screw	M6 screw	M6 screw	M6 screw
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	300 269 212.5	300 269 212.5	350 321 211.5	460 435 235
Weight	kg	38	51.3	69.6	118

Table 4- 13 Technical data of line reactors for Basic Line Modules, 3 AC 380 ... 480 V, Part 2

Article number	6SL3000-	0CE41-6AA0			
Suitable for Basic Line Module	6SL3330-	1TE41-8AA3			
Rated power of the Basic Line Module	kW	900			
Rated voltage	V	3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10%			10%
Ithmax	Α	1600			
Power loss	kW	0.606			
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M12 connecting lugs			
PE connection		M6 screw			
Degree of protection		IP00			
Dimensions Width Height Depth	mm mm mm	416 435 235			
Weight	kg	123			

Table 4- 14 Technical data of line reactors for Basic Line Modules, 3 AC 500 ... 690 V, Part 1

Article number	6SL3000-	0CH32-7AA0	0CH34-8AA0	0CH36-0AA0	0CH41-2AA0
Suitable for Basic Line Module	6SL3330-	1TG33-0AA3	1TG34-3AA3	1TG36-8AA3	1TG41-1AA3 1TG41-4AA3
Rated power of the Basic Line Module	kW	250	355	560	900 1100
Rated voltage	V	3 A0	C 500 -10% (-15% < 1	I min) 3 AC 690 +	10%
Ithmax	Α	270	482	597	1167
Power loss	kW	0.277	0.48	0.485	0.783
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M10 connecting lugs	M12 connecting lugs	M12 connecting lugs	M12 connecting lugs
PE connection		M6 screw	M6 screw	M6 screw	M6 screw
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	270 248 200	350 321 232.5	350 321 232.5	460 435 235
Weight	kg	27.9	55.6	63.8	147

Table 4- 15 Technical data of line reactors for Basic Line Modules, 3 AC 500 ... 690 V, Part 2

Article number	6SL3000-	0CH41-6AA0			
Suitable for Basic Line Module	6SL3330-	1TG41-8AA3			
Rated power of the Basic Line Module	kW	1500			
Rated voltage	V	3 A	C 500 -10% (-15% < 1	1 min) 3 AC 690 +	10%
Ithmax	Α	1600			
Power loss	kW	0.977			
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M12 connecting lugs			
PE connection		M6 screw			
Degree of protection		IP00			
Dimensions Width Height Depth	mm mm mm	416 435 250			
Weight	kg	134			

4.5 Line reactors for Smart Line Modules

4.5.1 Description

Line reactors limit low-frequency line harmonics and reduce the load on the semiconductors in the Smart Line Modules. For this reason, line reactors must always be provided when Smart Line Modules are used.

4.5.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

ACAUTION

Burns resulting from high surface temperature

The line reactors can become very hot. You can get seriously burnt when touching the surface.

- Mount the line reactors so that contact is not possible. If this is not possible, attach clearly visible and understandable warning notices at hazardous positions.
- To prevent adjacent components from suffering damage due to these high temperatures, maintain a clearance of 100 mm on all sides of the line reactors.

NOTICE

Damage to the system caused by the use of inappropriate and not approved line reactors

Inappropriate line reactors that have not been approved can damage the Line Modules.

Line harmonics that damage/disturb other loads connected to the same line supply can also occur.

Only use line reactors which are listed in this Manual.

Note

Malfunctions through magnetic fields

Reactors produce magnetic fields that can disturb or damage components and cables.

 Arrange the components and cables at a suitable distance (at least 200 mm) or shield the magnetic fields appropriately.

Note

Length of connection cables

The connection cables between line reactor and Line Module, as well as between line reactor and line filter, must be kept as short as possible (max. 5 m).

You must use shielded connection cables, whose cable shields are attached at both ends.

Shielding can only be omitted if the following conditions are met:

- The cables do not exceed 1 m in length.
- The cables are laid flush with the rear metal wall of the control cabinet.
- The cables are laid in a way that keeps them physically separate from signal cables.

Do not route any cables near the line reactor. If this cannot be avoided, observe a minimum distance of 200 mm.

4.5.3 Dimension drawing

Line reactor 6SL3000-0EE36-2AA0




Figure 4-4 Dimension drawing of line reactor 6SL3000-0EE36-2AA0

Table 4- 16 Dimensions (all dimensions in mm)

Α	В	С	\mathbf{D}^1	E ¹	F1	F2	G1
280	203	264	100	171	50	15	100
G2	G3	H1	H2	Н3			
_	40	51	194	_			

¹⁾ Lengths D and E correspond to the distance between holes

Line reactor 6SL3000-0EE38-8AA0




Figure 4-5 Dimension drawing of line reactor 6SL3000-0EE38-8AA0, all dimensions in mm

Line reactor 6SL3000-0EE41-4AA0




Figure 4-6 Dimension drawing of line reactor 6SL3000-0EE41-4AA0

Table 4- 17 Dimensions (all dimensions in mm)

Α	В	С	\mathbf{D}^1	E 1	F1	F2	G1
544	232	386	517	182	17	6	180
G2	G3	H1	H2	Н3	I	J	К
23	80.5	59	276	23	227	244	130.5
L	М	N	0	Р			
122	193	320	431	116			

¹⁾ Lengths D and E correspond to the distance between holes

Note

Remove the crane lifting eyes

The crane lifting eyes can be removed after installation.

Line reactor 6SL3000-0EH34-7AA0




Figure 4-7 Dimension drawing of line reactor 6SL3000-0EH34-7AA0

Table 4- 18 Dimensions (all dimensions in mm)

Α	В	С	\mathbf{D}^1	E ¹	F1	F2	G1
330	200	318	100	170	63	16.5	120
G2	G3	H1	H2	Н3			
_	32	51	194	_			

¹⁾ Lengths D and E correspond to the distance between holes

Line reactor 6SL3000-0EH37-6AA0




Figure 4-8 Dimension drawing of line reactor 6SL3000-0EE37-6AA0, all dimensions in mm

Note

Remove the crane lifting eyes

The crane lifting eyes can be removed after installation.

Line reactor 6SL3000-0EE41-4AA0




Figure 4-9 Dimension drawing of line reactor 6SL3000-0EH41-4AA0

Table 4- 19 Dimensions (all dimensions in mm)

Α	В	С	D ¹	E ¹	F1	F2	G1
566	267	383	613	190	6	16	220
G2	G3	H1	H2	Н3	I	J	K
23	88.5	79.5	236.5	23	22	426	213
L	М	N	0	Р	Q		
288	139.5	149.5	11	655	108.5		

¹⁾ Lengths D and E correspond to the distance between holes

Note

Remove the crane lifting eyes

The crane lifting eyes can be removed after installation.

4.5.4 Technical data

Table 4- 20 Technical data, line reactors for Smart Line Modules, 3 AC 380 ... 480 V

Article number	6SL3000-	0EE36-2AA0	0EE38-8AA0	0EE41-4AA0	
Suitable for Smart Line Module	6SL3330-	6TE35-5AA3 6TE37-3AA3	6TE41-1AA3	6TE41-3AA3 6TE41-7AA3	
Rated power of the Smart Line Module	kW	250 355	500	630 800	
Rated voltage	V	3 A	C 380 -10% (-15% < 1	I min) 3 AC 480 +	10%
Ithmax	Α	615	885	1430	
Power loss 50/60 Hz	kW	0.500/0.560	0.725/0.810	0.925/1.080	
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M10 connecting lugs	M10 connecting lugs	M10 connecting lugs	
PE connection		M6, 4x	M6, 4x	M6, 4x	
Degree of protection		IP00	IP00	IP00	
Dimensions Width Height Depth	mm mm mm	300 264 203	442 376 263	544 386 232	
Weight	kg	57	85.5	220	

Table 4- 21 Technical data, line reactors for Smart Line Modules, 3 AC 500 ... 690 V

Article number	6SL3000-	0EH34-7AA0	0EH37-6AA0	0EH41-4AA0	
Suitable for Smart Line Module	6SL3330-	6TG35-5AA3	6TG38-8AA3	6TG41-7AA3 6TG41-2AA3	
Rated power of the Smart Line Module	kW	450	710	1000 1400	
Rated voltage	V	3 A	C 500 -10% (-15% < 1	1 min) 3 AC 690 +	10%
Ithmax	Α	465	760	1430	
Power loss 50/60 Hz	kW	0.720/0.820	0.840/0.950	1.680/1.850	
Line/load connection 1U1, 1V1, 1W1, 1U2, 1V2, 1W2		M10 connecting lugs	M10 connecting lugs	M10 connecting lugs	
PE connection		M6, 4x	M6, 4x	M6, 4x	
Degree of protection		IP00	IP00	IP00	
Dimensions Width Height Depth	mm mm mm	360 325 229	442 370 303	655 383 288	
Weight	kg	58	145	239	

4.6.1 Description

Active Interface Modules are used in conjunction with the Active Line Modules in chassis format. The Active Interface Modules contain a Clean Power Filter with basic RI suppression, the precharging circuit for the Active Line Module, the line voltage sensing circuit and monitoring sensors.


The bypass contactor is an integral component in frame sizes FI and GI, which ensures a highly compact design. The bypass contactor must be provided separately for frame sizes HI and JI.

The vast majority of line harmonics are suppressed by the Clean Power Filter.

The Active Interface Module contains:

- Clean Power Filter
- · Line reactor
- · Precharging circuit
- Bypass contactor (frame sizes FI/GI)
- Voltage Sensing Module VSM10
- Fan

Table 4- 22 Active Interface Module



4.6.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



MARNING

Electric shock due to unconnected cable shields

Hazardous touch voltages can occur through capacitive cross-coupling due to unconnected cable shields.

Connect the cable shields at both ends to the grounded housing potential.



MARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.



Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating of components with subsequent fire and smoke. This can cause serious injury or even death. This can also result in increased failures and shorter service lives for devices/systems.

• Observe the ventilation clearances above, below and in front of the component, which are specified in the dimension drawings.

WARNING

Electric shock due to unexpectedly long discharge time

If you operate the Active Interface Module without an Active Line Module, the discharge time extends to more than 20 minutes after the supply voltage has been disconnected. As a result, dangerous voltage may unexpectedly be present at the terminals of the Active Interface Module.

Contact with live parts can result in death or serious injury.

• Only operate the Active Interface Module together with an Active Line Module.

4.6.3 Interface description

4.6.3.1 Overview




Figure 4-10 Interface overview in the Active Interface Module, frame size FI




Figure 4-11 Interface overview in the Active Interface Module, frame size GI




Figure 4-12 Interface overview in the Active Interface Module, frame size HI




Figure 4-13 Interface overview in the Active Interface Module, frame size JI

4.6.3.2 Connection example




Figure 4-14 Connection example Active Interface Module, frame sizes FI / GI




Figure 4-15 Connection example Active Interface Module, frame sizes HI / JI

NOTICE

Damage to the devices as a result of excessively long switching times of the bypass contactor

When using a bypass contactor with excessively long switching times (maximum 500 ms), the required overlap phase is not guaranteed, where both contactors are simultaneously pulled-in. As a consequence, the Active Interface Module can be overloaded and destroyed.

• Only use Siemens bypass contactors; the associated data are provided in the technical data.

NOTICE

Damage to the device due to different phase sequence in the precharging and main circuits

During the brief overlap period where both contactors are simultaneously closed, the precharging resistors of the Active Interface Module could be overloaded and destroyed due to different phase sequences in the precharging and main circuits.

• Connect the power cables to the precharging and main circuits with the same phase sequence.

4.6.3.3 Motor circuit breaker -Q101

Motor circuit breaker -Q101 is used to protect the fan. The fan is adequately protected as result of the factory setting.

In the factory setting, the motor circuit breaker is set corresponding to the following table.

Table 4- 23 Factory setting of the motor circuit breaker

Active Interface Module	Motor circuit breaker type	Set value
Size FI	3RV2011-0JA25 (0.7 1 A)	0.7 A
Size GI	3RV2011-0JA25 (0.7 1 A)	1 A
Size HI/JI	3RV2011-0GA25 (4.5 6.3 A)	5.5 A

Checking the position of the rotary knob

Check the correct position of the rotary knob before commissioning.

- When the Active Interface Module is operational, the rotary knob must be in the "ON" position.
- If the rotary knob is in the "OFF" or "TRIPPED" position, then it must be brought into the "ON" position for operation.
 - Switching from the "OFF" position to the "ON" position must be done quickly and without any interruption.
 - Starting from the "TRIPPED" position, the rotary knob must first be turned to the "OFF" position and then to the "ON" position.
 The fault that caused the motor circuit breaker to trip must first be resolved.

4.6.3.4 Line/load connection

Table 4- 24 Connections for the Active Interface Module

Terminals	Designations
X1: L1, L2, L3	Voltage:
X2: U2, V2, W2	• 3 AC 380 V -10 % (-15 % < 1 min) 3 AC 480 V +10 %
	• 3 AC 500 V -10 % (-15 % < 1 min) 3 AC 690 V +10 %
	Frequency: 47 63 Hz
	Connecting thread:
	• Frame sizes FI / GI: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)
	• Frame sizes HI / JI: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)
K4: 2/T1, 4/T2, 6/T3	Connection for pre-charging circuit directly on pre-charging contactor:
(for frame sizes HI / JI only)	• Frame size HI: 2 x 16 mm² max. (3RT1034)
5,	• Frame size JI: 2 x 35mm² max. (3RT1044)
PE connection	Connecting thread:
	• Frame sizes FI / GI: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)
	• Frame sizes HI / JI: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)

 $^{^{\}mbox{\scriptsize 1}}$) Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

4.6.3.5 DRIVE-CLiQ interface X500

Table 4- 25 DRIVE-CLiQ interface X500

Connector	PIN	Signal name	Technical specifications	
. □■B	1	TXP	Transmit data +	
▎▐█૽૽ૺ	2	TXN	Transmit data -	
الكامة ا	3	RXP	Receive data +	
	4	Reserved, do not use		
	5	Reserved, do not use		
	6	RXN	Receive data -	
	7	Reserved, do not use		
	8	Reserved, do not use		
	24 V power supply			
	B M (0 V) Electronics ground			
Blanking plate	for DRIVE-CL	iQ interfaces (50 pcs.) Article number	: 6SL3066-4CA00-0AA0	

4.6.3.6 X530 neutral point grounding

Table 4- 26 Neutral point grounding X530

	Connector	Terminal	Designation	Technical specifications
1		1	Neutral point of the voltage sensing	Jumper inserted: Grounded measurement Jumper not inserted: isolated measurement
2	2 2 2		Ground potential	

The Voltage Sensing Module is supplied with inserted jumper. When delivered, the neutral point is connected to the protective conductor via the connector jumper. Current can flow to PE. This connection is removed by removing the connector jumper. The measurement is then electrically isolated.




Figure 4-16 Internal circuit of the VSM10 Voltage Sensing Module

When the Active Interface Module is operated on an ungrounded line system (IT system), the connection clip must be removed, see "Electrical connection (Page 99)".

Note

Replacing a VSM10 Voltage Sensing Module

When replacing a Voltage Sensing Module VSM10 by one with a different article number, then inform yourself about the applicable boundary conditions.

4.6.3.7 X609 terminal strip

Table 4- 27 X609 terminal strip

Connector	Terminal	Designation	Technical specifications		
	1	P24	External 24 V DC supply		
	2	P24	Voltage: 24 VDC (20.4 28.5 V)		
	3	М	Current consumption: Max. 0.25 A		
	4	М			
	5	L	Voltage: 230 VAC (195.5 264.5 V)		
	6	L	Current consumption: Max. 10 A		
	7	N	Fan operating currents, see "Technical	data"	
	8	N			
	9	Pre-charge contactor-A1	Voltage: 230 VAC (195.5 264.5 V)	To Active Line Module, X9:5	
	10	Pre-charge contactor–A2	Current consumption: Max. 4 A	To Active Line Module, X9:6	
	11	Bypass contactor-A1	Voltage: 230 VAC (195.5 264.5 V)	To Active Line Module, X9:3	
	12	Bypass contactor–A2	Current consumption: Max. 6 A	To Active Line Module, X9:4	
	13	Contactor feedback 1 *	Voltage: 230 VAC (195.5 264.5 V)		
	14	Contactor feedback 2 *	Max. permissible current: 6 A		
Max. connectable cross-section: 2.5 mm ²					

^{*} Series connection NO contact of pre-charge contactor and bypass contactor (only for frame size FI, GI)

NOTICE

Device failure due to overtemperature caused by incorrect wiring of Active Interface Modules with frame size HI and JI

During operation, Active Interface Modules of frame sizes HI and JI require a signal at terminals X609:11 and X609:12 to control the fans. If this signal is not present during operation, the fans do not rotate and the module is shut down on overtemperature.

• Connect the signals at terminals X609:11 and X609:12 to the Active Interface Modules of frame sizes HI and JI to control the fans.

4.6.3.8 Meaning of the LED on the Voltage Sensing Module (VSM) in the Active Interface Module

Table 4- 28 Description of the LED on the Voltage Sensing Module (VSM) in the Active Interface Module

LED	Color	State	Description		
RDY		Off	The electronics power supply is missing or out of tolerance.		
	Green	Continu- ous light	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.		
	Orange	Continu- ous light	DRIVE-CLiQ communication is being established.		
	Red	Continu- ous light	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.		
	Green/red	Flashing 0.5 Hz	Firmware is being downloaded.		
		2 Hz flash- ing light	Firmware download is complete. Waiting for POWER ON.		
	Green / orange or red / or- ange	2 Hz flash- ing light	Component recognition via LED is activated (p0144). Remark: Both options depend on the LED status when module recognition is activated via p0144 = 1.		

4.6.4 Dimension drawing

Dimension drawing, frame size FI




Figure 4-17 Dimension drawing for Active Interface Module, frame size FI Side view, front view

Dimension drawing, frame size GI




Figure 4-18 Dimension drawing for Active Interface Module, frame size GI Side view, front view

Dimension drawing, frame size HI




Figure 4-19 Dimension drawing for Active Interface Module, frame size HI Side view, rear view

Dimension drawing, frame size JI




Figure 4-20 Dimension drawing for Active Interface Module, frame size JI Side view, rear view

4.6.5 Electrical connection

The Active Interface Module is electrically connected in accordance with the connection examples shown in section "Interface description".

Removing the connection clip of the integrated basic interference suppression module to ground

The connection of the integrated basic interference suppression module to ground must be disconnected if the device is operated on one of the following line system configurations:

- Non-grounded line supply (IT supply system)
- · Line supply with grounded line conductor

The connection is disconnected by removing the connection clip of the integrated basic interference suppression module to ground.

Note

Warning label on the connection clip

A yellow warning label is attached to each connection clip so that it is easier to find.

• The warning label must be removed from the connection clip (by pulling it off) if the connection clip is to remain in the device.



Figure 4-21 Warning label on the connection clip

NOTICE

Damage to the device by not removing the connection clip

Failure to remove the connection clip of the integrated basic interference suppression module to ground for a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor can cause significant damage to the device.

• For a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor, remove the connection clip of the integrated basic interference suppression module to ground.




Figure 4-22 Removing the connection clip of the basic interference suppression module to ground for frame size FI




Figure 4-23 Removing the connection clip of the basic interference suppression module to ground for frame size GI




Figure 4-24 Removing the connection clip of the basic interference suppression module to ground for frame size HI





Figure 4-25 Removing the connection clip of the basic interference suppression module to ground for frame size JI

Removing the connector jumper on the VSM10 Voltage Sensing Module

When operating the Active Interface Module on an ungrounded line supply (IT system), at the Voltage Sensing Module (VSM10), remove the connector jumper in terminal X530 at the lower side of the component.

Use two screwdrivers or another suitable tool to relieve the holding springs in the terminal and then withdraw the connector jumper.





Terminal X530 with connector jumper

Relieve the springs and withdraw the connector jumper

Note

Replacing a VSM10 Voltage Sensing Module

When replacing a Voltage Sensing Module VSM10 by one with a different article number, then inform yourself about the applicable boundary conditions.

4.6.6 Technical data

Table 4-29 Technical data for Active Interface Modules, 3 AC 380 V ... 480 V, Part 1

Article number	6SL3300-	7TE32-6AAx ¹⁾	7TE32-6AAx ¹⁾	7TE33-8AAx ¹⁾	7TE35-0AAx ¹⁾
Suitable for Active Line Module Rated power of Active Line Module	6SL3330- kW	7TE32-1AA3 132	7TE32-6AA3 160	7TE33-8AA3 235	7TE35-0AA3 300
Rated input current of the Active Line Module	А	210	260	380	490
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage	VACrms Hz VDC VAC	3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10% 47 63 Hz 24 (20.4 28.8) 230 (195.5 264.5)			
DC link capacitance of the drive line-up, max.	μF	41600	41600	76800	76800
Current consumption - Electronics current consumption (24 V DC) - Fan supply, 230 V AC,	A	0.17	0.17	0.17	0.17
50/60 Hz, max Max. pre-charging current (max. 3 s)	A	57	57	57	57
Bypass contactor		included	included	included	included
Current drawn by the bypass contactor (230 V AC) - Making current - Holding current	A A	1.25 0.6	1.25 0.6	2.5 1.2	2.5 1.2
Max. ambient temperature - Without derating - With derating	°C	40 55	40 55	40 55	40 55
Power loss, max. ²⁾ - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	2.1 2.1	2.2 2.2	3.0 3.0	3.9 3.9
Cooling air requirement	m³/s	0.24	0.24	0.47	0.47
Line/load connection		Flat connector for screw			
L1, L2, L3 / U2, V2, W2		M10	M10	M10	M10
PE connection		M10 screw	M10 screw	M10 screw	M10 screw
Max. conductor cross-sections - Line connection (L1, L2, L3) - Load connection (U2, V2, W2) - PE connection	mm² mm² mm²	2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185
Degree of protection		IP20	IP20	IP20	IP20
Dimensions - Width - Height - Depth	mm mm mm	325 1400 355	325 1400 355	325 1533 544	325 1533 544
Frame size		FI	FI	GI	GI
Weight	kg	135	135	190	190

¹⁾ x = 0: with KTY84 temperature sensor, x = 1: with PT1000 temperature sensor.

²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.

Table 4- 30 Technical data for Active Interface Modules, 3 AC 380 V ... 480 V, Part 2

Article number	6SL3300-	7TE38-4AAx ¹⁾	7TE38-4AAx ¹⁾	7TE41-4AAx ¹⁾	7TE41-4AAx ¹⁾		
Suitable for Active Line Module	6SL3330-	7TE36-1AA3	7TE37-5AA3	7TE41-0AA3	7TE41-2AA3		
Rated power of Active Line Module	kW	380	7TE38-4AA3 450 / 500	630	7TE41-4AA3 800 / 900		
Rated input current of the Active Line Module	А	605	745 / 840	985	1260 / 1405		
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage	voltage VACrms Hz vonics power supply VAC			3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10% 47 63 Hz 24 (20.4 28.8) 230 (195.5 264.5)			
DC link capacitance of the drive line-up, max.	μF	134400	134400	230400	230400		
Current consumption - Electronics current consumption (24 V DC) - Fan supply, 230 V AC,	A	0.17	0.17	0.17	0.17		
50/60 Hz, max. - Max. pre-charging current (max. 3 s)	A	178	178	178	178		
Bypass contactor ³⁾		3RT1476- 6AP36	3WA1110- 4AE03-4EQ0	3WA1112- 4AE03-4EQ0	3WA1116- 4AE03-4EQ0		
Max. ambient temperature - Without derating - With derating	°C °C	40 55	40 55	40 55	40 55		
Power loss, max. ²⁾ - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	5.5 5.5	6.1 6.1	7.5 7.5	8.5 8.5		
Cooling air requirement	m³/s	0.40	0.40	0.40	0.40		
Line/load connection		Flat connector for screw					
L1, L2, L3 / U2, V2, W2		M12	M12	M12	M12		
PE connection		M12 screw	M12 screw	M12 screw	M12 screw		
Max. conductor cross-sections - Line connection (L1, L2, L3) - Load connection (U2, V2, W2) - PE connection	mm² mm² mm²	4 x 240 4 x 240 2 x 240	4 x 240 4 x 240 2 x 240	6 x 240 6 x 240 4 x 240	6 x 240 6 x 240 4 x 240		
Degree of protection		IP00	IP00	IP00	IP00		
Dimensions - Width - Height - Depth	mm mm mm	305 1750 544	305 1750 544	505 1750 544	505 1750 544		
Frame size		HI	HI	JI	JI		
Weight	kg	390	390	480	480		

 $^{^{1)}}$ x = 0: with KTY84 temperature sensor, x = 1: with PT1000 temperature sensor.

²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.

³⁾ Bypass contactor is not included, must be provided separately.

Table 4- 31 Technical data for Active Interface Modules, 3 AC 500 ... 690 V

Article number	6SL3300-	7TG35-8AAx ¹⁾	7TG37-4AAx ¹⁾	7TG41-3AAx ¹⁾	7TG41-3AAx ¹⁾
Suitable for Active Line Module	6SL3330-	7TG35-8AA3	7TG37-4AA3	7TG41-0AA3	7TG41-3AA3
Rated power of Active Line Module	kW	630	800	1100	1400
Rated input current of the Active Line Module	А	575	735	1025	1270
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage	VACrms Hz VDC VAC	3 AC 5	24 (20.4	1 min) 3 AC 690 63 Hz I 28.8) 5 264.5)	0 +10%
DC link capacitance of the drive line-up, max.	μF	59200	153600	153600	153600
Current consumption - Electronics current consumption (24 V DC) - Fan supply, 230 V AC, max Max. pre-charging current (max. 3 s)	A A A	0.17 4.6 141	0.17 4.9 141	0.17 4.9 141	0.17 4.9 141
Bypass contactor 3)		3RT1476- 6AP36	3RT1476- 6AP36 (3 x)	3WA1220- 4AE03-4EQ0-Z Z=B12	3WA1220- 4AE03-4EQ0-Z Z=B16
Max. ambient temperature - Without derating - With derating	°C °C	40 55	40 55	40 55	40 55
Power loss, max. ²⁾ - at 50 Hz 690 V - at 60 Hz 575 V	kW kW	6.8 6.8	9.0 9.0	9.2 9.2	9.6 9.6
Cooling air requirement	m³/s	0.40	0.40	0.40	0.40
Line/load connection			Flat connec	tor for screw	
L1, L2, L3 / U2, V2, W2		M12	M12	M12	M12
PE connection		M12 screw	M12 screw	M12 screw	M12 screw
Max. conductor cross-sections - Line connection (L1, L2, L3) - Load connection (U2, V2, W2) - PE connection	mm² mm² mm²	4 x 240 4 x 240 2 x 240	6 x 240 6 x 240 4 x 240	6 x 240 6 x 240 4 x 240	6 x 240 6 x 240 4 x 240
Degree of protection		IP00	IPO0	IP00	IP00
Dimensions - Width - Height - Depth	mm mm mm	305 1750 544	505 1750 544	505 1750 544	505 1750 544
Frame size		HI	JI	JI	JI
Weight	kg	390	430	530	530

¹⁾ x = 0: with KTY84 temperature sensor, x = 1: with PT1000 temperature sensor.

²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.

³⁾ Bypass contactor is not included, must be provided separately.

4.7.1 Description

Active Interface Modules Chassis-2 contain a Clean Power Filter. The filter structure permits operation with higher pulse frequencies, which in turn allows line harmonics to be reduced even further; additional information on this topic is available on request.

Basic RI suppression, line voltage sensing and temperature monitoring sensors are also included.

The precharging input circuit that is necessary for operation, comprised of resistors, a precharging contactor and a main contactor, must be provided separately. The precharging contactor is controlled from the Active Line Module Chassis-2.

The vast majority of line harmonics are suppressed by the Clean Power Filter.

The Active Interface Module contains:

- Clean Power Filter
- Line reactor
- Voltage Sensing Module VSM10
- Fan




Figure 4-26 Active Interface Module Chassis-2

Active Infeed Chassis-2

An Active Line Module Chassis-2 is offered and supplied with the associated Active Interface Module Chassis-2 as a package, and is called "Active Infeed".

The article numbers of the individual components (Active Interface Module Chassis-2 and Active Line Module Chassis-2) are listed in the table below:

Table 4-32 Active Infeed Chassis-2, article numbers of the individual components

Active Infeed Chassis-2	Rated power	Active Interface Module Chassis-2	Active Line Module Chassis-2
6SL3341-7TE35-6AA0	355 kW	6SL3301-7TE36-4AA0	6SL3331-7TE35-6AA0
6SL3341-7TE36-4AA0	400 kW	6SL3301-7TE36-4AA0	6SL3331-7TE36-4AA0
6SL3341-7TE37-5AA0	450 kW	6SL3301-7TE41-0AA0	6SL3331-7TE37-5AA0
6SL3341-7TE38-4AA0	500 kW	6SL3301-7TE41-0AA0	6SL3331-7TE38-4AA0
6SL3341-7TE38-8AA0	560 kW	6SL3301-7TE41-0AA0	6SL3331-7TE38-8AA0
6SL3341-7TE41-0AA0	630 kW	6SL3301-7TE41-0AA0	6SL3331-7TE41-0AA0
6SL3341-7TE41-2AA0	710 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-2AA0
6SL3341-7TE41-3AA0	800 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-3AA0
6SL3341-7TE41-4AA0	900 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-4AA0

4.7.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



! WARNING

Electric shock due to unconnected cable shields

Hazardous touch voltages can occur through capacitive cross-coupling due to unconnected cable shields.

Connect the cable shields at both ends to the grounded housing potential.



MARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - 1) Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.



Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating of components with subsequent fire and smoke. This can cause serious injury or even death. This can also result in increased failures and shorter service lives for devices/systems.

• Observe the cooling clearances above and in front of the component, which are specified in the dimension drawings.



Electric shock due to unexpectedly long discharge time

If you operate the Active Interface Module without an Active Line Module, the discharge time extends to more than 20 minutes after the supply voltage has been disconnected. As a result, dangerous voltage may unexpectedly be present at the terminals of the Active Interface Module.

Contact with live parts can result in death or serious injury.

• Only operate the Active Interface Module together with an Active Line Module.

4.7.3 Interface description

4.7.3.1 Overview




Figure 4-27 Active Interface Module Chassis-2 interface overview

4.7.3.2 Connection example




Figure 4-28 Connection example for Active Interface Module Chassis-2

NOTICE

Damage to the devices as a result of excessively long switching times of the bypass contactor

When using a main contactor with excessively long switching times (maximum 500 ms), the required overlap phase is not guaranteed, where both contactors are simultaneously pulled-in. As a consequence, the Active Interface Module Chassis-2 can be overloaded and destroyed.

- Only use Siemens main contactors; the associated data can be found in Chapter "Precharging input circuit for Active Interface Modules Chassis-2 (Page 124)".
- Wire the control and feedback of the contactors to the Active Line Module Chassis-2 to ensure a correct control sequence.

NOTICE

Damage to the device due to different phase sequence in the precharging and main circuits

Different phase sequences in the pre-charging and main circuits can overload and destroy the pre-charging resistors during the brief overlap period, where both contactors are simultaneously closed.

• Connect the power cables to the precharging and main circuits with the same phase sequence.

4.7.3.3 Motor circuit breaker -Q101

Motor circuit breaker -Q101 is used to protect the fan.

The fan is adequately protected as result of the factory setting.

In the factory setting, the motor circuit breaker is set corresponding to the following table.

Table 4- 33 Factory setting of the motor circuit breaker

Active Interface Module	Motor circuit breaker type	Set value
Frame size FS2, FS4, FS4+	3RV2011-0GA25 (4.5 6.3 A)	4.5 A

Checking the position of the rotary knob

Check the correct position of the rotary knob before commissioning.

- When the Active Interface Module is operational, the rotary knob must be in the "ON" position.
- If the rotary knob is in the "OFF" or "TRIPPED" position, then it must be brought into the "ON" position for operation.
 - Switching from the "OFF" position to the "ON" position must be done quickly and without any interruption.
 - Starting from the "TRIPPED" position, the rotary knob must first be turned to the "OFF" position and then to the "ON" position.
 - The fault that caused the motor circuit breaker to trip must first be resolved.

4.7.3.4 Line/load connection

Table 4- 34 Connections for Active Interface Modules Chassis-2

Terminals	Designations
X1: U1, V1, W1 X2: U2, V2, W2	Voltage: 380 V 3 AC -10% (-15% < 1 min) 480 V 3 AC +10% Frequency: 47 63 Hz Connection: 2 holes 13.5 x 20.5 mm (M12, 50 Nm) flat connector for busbar connection The following cross-sections are recommended when using copper busbars to establish the connection:
	Frame size FS2: 80 mm x 6 mm
Frame size FS4: 80 mm x 8 mm	
	Frame size FS4+: 80 mm x 8 mm
PE connection	Connecting thread: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)

^{1)} Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

4.7.3.5 DRIVE-CLiQ interface X500

Table 4- 35 DRIVE-CLiQ interface X500

Connector	PIN	Signal name	Technical specifications
. B	1	TXP	Transmit data +
	2	TXN	Transmit data -
¹ E #	3	RXP	Receive data +
	4	Reserved, do not use	
	5	Reserved, do not use	
	6	RXN	Receive data -
	7	Reserved, do not use	
	8	Reserved, do not use	
	Α	+ (24 V) 24 V power supply	
	В	M (0 V) Electronics ground	
Blanking plate	for DRIVE-CI	iQ interfaces (50 pcs.) Article number	: 6SL3066-4CA00-0AA0

Note

Cable glands and cable holders

There are two cable glands in the front cover in front of terminal X500 and on the side cover. There are cable holders for securing the cables above the transparent covers.

4.7.3.6 X530 neutral point grounding

Table 4- 36 Neutral point grounding X530

	Connector	Terminal	Designation	Technical specifications
1		1	Neutral point of the voltage sensing	Jumper inserted: Grounded measurement Jumper not inserted: isolated measurement
2		2	Ground potential	

The Voltage Sensing Module is supplied with inserted jumper. When delivered, the neutral point is connected to the protective conductor via the connector jumper. Current can flow to PE. This connection is removed by removing the connector jumper. The measurement is then electrically isolated.




Figure 4-29 Internal circuit of the VSM10 Voltage Sensing Module

When the Active Interface Module is operated on an ungrounded line system (IT system), the connection clip must be removed, see "Electrical connection (Page 122)".

4.7.3.7 X609 terminal strip

Table 4- 37 X609 terminal strip

Connector	Terminal	Designation	Technical specifications			
	PE	PE	PE connection			
8 3 8	1	P24	External 24 V DC supply			
	2	P24	Voltage: 24 VDC (20.4 28.5 V)			
5 C	3	М	Current consumption: Max. 0.25 A			
	4	М				
	5	L	Voltage: 230 VAC (195.5 264.5 V)			
	6	L	Current consumption: Max. 10 A			
	7	N	Fan operating currents, see "Technical data"			
	8	N	7			
	9	Control of fan contactor	Voltage: 230 VAC (195.5 264.5 V) to Active Line Modu Current consumption: max. 4 A Chassis-2, X9:HS1			
	10	Control of fan contactor		to Active Line Module Chassis-2, X9:HS2		
	11	NC	Reserved, do not use			
	12	NC	Reserved, do not use			
	13	NC	Reserved, do not use			
	14	NC	Reserved, do not use			
	PE	PE	PE connection			
Max. connectal	ole cross-sect	tion: 2.5 mm ²				

NOTICE

Damage to the device as there is no isolating transformer for the fan power supply at terminal X609:5 ... 8

If an appropriate isolating transformer is not connected upstream of the fan power supply, then this can cause significant damage to the device.

- When using an external 230 V AC supply for the fan, carefully ensure that the following conditions are complied with:
 - Use an isolating transformer whose secondary is grounded on one side.
 - The harmonic load must be less or equal to what is stipulated in IEC 61000-2-4.
 - The line quality must be in compliance with IEC 61000-4-11 and IEC 61000-2-4.

Note

Cable gland and cable holder

Under terminal strip X609, there is a cable gland in the front cover and cable holders for securing the cables.

NOTICE

Device failure due to overtemperature caused by faulty wiring

During operation, Active Interface Modules require a signal to terminal X609:9 and X609:10 for fan activation. If this signal is not present during operation, the fans do not rotate and the module is shut down on overtemperature.

• Connect the signals to terminal X609:9 and X609:10 on the Active Interface Module Chassis-2 to control the fan.

4.7.3.8 Meaning of the LED on the Voltage Sensing Module (VSM) in the Active Interface Module

Table 4-38 Description of the LED on the Voltage Sensing Module (VSM) in the Active Interface Module

LED	Color	State	Description		
RDY		Off	The electronics power supply is missing or out of tolerance.		
	Green	Continu- ous light	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.		
	Orange	Continu- ous light	DRIVE-CLiQ communication is being established.		
	Red	Continu- ous light	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.		
	Green/red	Flashing 0.5 Hz	Firmware is being downloaded.		
		2 Hz flash- ing light	Firmware download is complete. Waiting for POWER ON.		
	Green / orange or red / or- ange	2 Hz flash- ing light	Component recognition via LED is activated (p0144). Remark: Both options depend on the LED status when module recognition is activated via p0144 = 1.		

4.7.4 Dimension drawing

Dimension drawing Active Interface Module Chassis-2

The mandatory cooling clearances are indicated by the dotted line.




Figure 4-30 Dimension drawing Active Interface Module Chassis-2. Rear view, side view, front view

4.7.5 Installation


The Active Interface Module Chassis-2 is secured at the top and bottom of the device using 3 M10 screws, which are screwed onto the rear mounting panel of the control cabinet.

Then the Active Interface Module Chassis-2 is fastened to the mounting surface of the control cabinet using a mounting bracket.

Mounting dimensions in the control cabinet

Refer to the following diagrams for the mounting dimensions when installing the Active Interface Module Chassis-2 in a control cabinet.

Front view of the control cabinet



- ① Side panel of the control cabinet
- ② Support surface for the Active Interface Module Chassis-2


Figure 4-31 Installation front view

Note

Tolerances for holes tapped in the rear mounting panel

If the specified tolerances for the threaded holes of the rear mounting panel of the control cabinet cannot be adhered to, then compensating fastening elements should be used to facilitate screwing on the Active Interface Modules Chassis-2.

Top view of the control cabinet mounting surface



- 1 Side panel of the control cabinet
- ② Rear mounting panel
- 3 Fastening points to mount the lateral holding plate to simplify installation

Figure 4-32 Installation top view

Notes on installing the Active Interface Module Chassis-2 in the control cabinet

Observe the following notes when installing the Active Interface Module Chassis-2 in the control cabinet:

- You can also mount the lateral holding plates of the Active Interface Module Chassis-2 on the pallet horizontally. This creates a horizontal surface on which you can roll the device into the control cabinet.
- You can use the recessed grips in the center of the device for pulling or pushing the Active Interface Module Chassis-2 into the control cabinet.
 Do not use the grip at the bottom on the fan box for this purpose as it has not been designed for this purpose.
- Due to the considerable weight of the device, ensure that a stable mounting footprint is available for the Active Interface Module Chassis-2 and that there are no obstacles in the rolling area (such as screws).

• Only roll the device horizontally into the control cabinet.

Never roll the device up or down an inclined ramp, as the high weight and center of gravity of the device pose a serious risk of injury.

MWARNING

Risk of injury when rolling along an inclined ramp

Serious injury can occur when rolling along an inclined ramp as a result of the high weight and the center of gravity.

- Only roll the device horizontally.
- You must remove the fan unit to screw the device to the rear mounting panel.

Attaching the mounting bracket

Secure the mounting bracket of the Active Interface Module Chassis-2 on the mounting surface of the control cabinet.

When positioning the long holes (12 mm x 17 mm), ensure that no additional pressure is applied to the rollers of the Active Interface Modules Chassis-2 during installation.

Tighten the M10 screws to a torque of 50 Nm.




Figure 4-33 Attaching the mounting bracket (diagram showing an example)

4.7.6 Electrical connection

The Active Interface Module Chassis-2 is electrically connected in accordance with the connection examples shown in section "Interface description".

Removing the connection clip of the integrated basic interference suppression module to ground

The connection of the integrated basic interference suppression module to ground must be disconnected if the device is operated on one of the following line system configurations:

- Non-grounded line supply (IT supply system)
- Line supply with grounded line conductor

The connection is disconnected by removing the connection clip of the integrated basic interference suppression module to ground.

Note

Warning label on the connection clip

A yellow warning label is mounted on the connection clip to make it easier to find.

• The warning label must be removed from the connection clip (by pulling it off) if the connection clip is to remain in the device.



Figure 4-34 Warning label on the connection clip

NOTICE

Damage to the device by not removing the connection clip

Failure to remove the connection clip of the integrated basic interference suppression module to ground for a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor can cause significant damage to the device.

 For a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor, remove the connection clip of the integrated basic interference suppression module to ground.





Figure 4-35 Removing the connection clip of the basic interference suppression module to ground in the Active Interface Module, Chassis-2

Removing the connector jumper on the VSM10 Voltage Sensing Module

When operating the Active Interface Module Chassis-2 on a non-grounded line supply (IT system), at the Voltage Sensing Module (VSM10), remove the plug-in jumper in terminal X530 at the lower side of the component.

Use two screwdrivers or another suitable tool to relieve the holding springs in the terminal and then withdraw the plug-in jumper.





Terminal X530 with connector jumper

Relieve the springs and withdraw the connector jumper

4.7.7 Pre-charging input circuit for Active Interface Modules Chassis-2

Description

The precharging input circuit ensures there is a current-limited precharging of the DC link capacitors of the Active Line Module Chassis-2 and the connected Motor Modules during the switch-on procedure.

After pre-charging is complete, the main contactor is closed and the pre-charging input circuit is bridged, then the Active Interface Module Chassis-2 is connected directly to the supply system.

The precharging circuit comprises a precharging contactor, precharging resistors and a main contactor; the circuit must be protected against overcurrent using suitable protection elements.

The precharging is monitored via feedback from the contactors to the Active Line Module Chassis-2.

To achieve or to increase the permissible DC link capacitance, the precharging resistors must or can be connected in parallel in each phase.

The specifications regarding connecting precharging resistors in parallel and the DC link capacitance are included in the technical data of the Active Line Module Chassis-2.

NOTICE

Damage to the units if the pre-charging input circuit is faulty

If the pre-charging input circuit is not correctly set up, the Active Line Module Chassis-2 connected to the Active Interface Module Chassis-2 can be destroyed during switch-on.

• The pre-charging input circuit must be implemented according to the following circuit and the notes for dimensioning the various components.




Figure 4-36 Connection example for Active Interface Module Chassis-2




Figure 4-37 Active Interface Module Chassis-2 pre-charging input circuit

Precharging contactor

The precharging contactor must be able to conduct the maximum precharging current for approx. 1 second and be able to switch ohmic-capacitive loads.

To protect against overvoltage when opening, the contactor should be equipped with a varistor, corresponding to the manufacturer's recommendations.

The precharging contactor is controlled via terminal -X9: VL1, VL2 of the Active Line Modules Chassis-2. The switching capacity of the floating relay contact is described here: X9 terminal strip (Page 235).

An additional normally closed (NC contact) of the precharging contactor must be routed to terminal -X47:1 to guarantee the feedback signal. The 24 V DC supply can be taken from terminal strip -X42.

The following contactors are recommended:

- For a version with one precharging resistor for each phase, a Sirius 3RT2027 is recommended.
- For a version with two precharging resistors connected in parallel for each phase, a Sirius 3RT2037 contactor is recommended.
- For a version with three precharging resistors connected in parallel for each phase, a Sirius 3RT2037 contactor is recommended.

Precharging resistors

The precharging resistors are used to limit the current while precharging.

Table 4- 39 Technical data of the precharging resistors

Category	Unit	3 AC 380 480 V
Rated voltage	V	690 V AC
Frequency	Hz	47 63
Resistance value	Ω	2.2 ±10%
Pulse energy 1)	Ws	18000
Precharging current ²⁾ - one resistor per phase - two resistors per phase in parallel - three resistors per phase in parallel	A A A	91 182 274
Ambient temperature	°C	60
Conductor cross-section	mm²	2.5
Article number		6SL3000-0KE12-2AA0

¹⁾ The pulse energy may only occur every 3 minutes

As the precharging resistors can get hot, sufficient cooling and clearance to adjacent components must be ensured in operation.




Figure 4-38 Dimension drawing, precharging resistor

Fuses

The pre-charging input circuit components are protected against overload using fuses.

²⁾ Line current available at the start of the precharging (initial rms value) at 400 V

The following fuses are recommended:

- For versions with one precharging resistor for each phase, 3NE1 817-0 (50 A) fuses are recommended.
- For versions with two precharging resistors connected in parallel for each phase, 3NE1 021-0 fuses (100 A) are recommended.
- For versions with three precharging resistors connected in parallel for each phase, 3NE1 021-0 fuses (100 A) are recommended.

Main contactor

A contactor or a circuit breaker is used as main contactor. This is used to connect the Active Interface Modules Chassis-2 to the supply system.

The following components are recommended.

Table 4- 40 Recommended components for the main contactor

Active Interface Mod- ule 6SL3301-	Active Line Module 6SL3331-	Rated power	Rated cur- rent	Main contactor
7TE36-4AA0	7TE35-6AA0	355 kW	560 A	3RT1466-6AP36 (3 x)
7TE36-4AA0	7TE36-4AA0	400 kW	635 A	3RT1466-6AP36 (3 x)
7TE41-0AA0	7TE37-5AA0	450 kW	745 A	3WA1220-4AE03-4EQ0-Z Z=B10
7TE41-0AA0	7TE38-4AA0	500 kW	840 A	3WA1220-4AE03-4EQ0-Z Z=B10
7TE41-0AA0	7TE38-8AA0	560 kW	900 A	3WA1220-4AE03-4EQ0-Z Z=B10
7TE41-0AA0	7TE41-0AA0	630 kW	985 A	3WA1220-4AE03-4EQ0-Z Z=B12
7TE41-4AA0	7TE41-2AA0	710 kW	1110 A	3WA1220-4AE03-4EQ0-Z Z=B12
7TE41-4AA0	7TE41-3AA0	800 kW	1260 A	3WA1220-4AE03-4EQ0-Z Z=B16
7TE41-4AA0	7TE41-4AA0	900 kW	1405 A	3WA1220-4AE03-4EQ0-Z Z=B16

The main contactor is controlled via terminal -X9: HS1, HS2 of the Active Line Modules Chassis-2. The switching capacity of the floating relay contact is described here: X9 terminal strip (Page 235).

An additional normally open contact (NO contact) of the main contactor must be routed to terminal -X47:3 to guarantee the feedback signal. The 24 V DC supply can be taken from terminal strip -X42.

4.7.8 Technical data

Table 4- 41 Technical data for Active Interface Modules, 380 V ... 480 V 3 AC

Article number	6SL3301-	7TE36-4AA0	7TE41-0AA0	7TE41-4AA0
Suitable for the Active Line Module Chassis-2	6SL3331-	7TE35-6AA0 7TE36-4AA0	7TE37-5AA0 7TE38-4AA0 7TE38-8AA0 7TE41-0AA0	7TE41-2AA0 7TE41-3AA0 7TE41-4AA0
Rated power of the Active Line Module	kW	355 / 400	450 / 500 / 560 / 630	710 / 800 / 900
Rated input current of the Active Line Module	A	560 / 635	745 / 840 / 900 / 985	1110 / 1260 / 1405
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage	VACrms Hz VDC VAC	3 AC 3	47 24 (20.4	1 min) 3 AC 480 +10% 63 Hz 28.8) 5 264.5)
Current consumption - Electronics current consumption (24 V DC) - Fan supply, 230 V AC, 50/60 Hz, max.	A A	0.2	0.2	0.2
Max. ambient temperature - Without derating - With derating	° C	45 60	45 60	45 60
Power loss, max. 1) - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	6.9 6.9	9.9 9.9	14.5 14.5
Cooling air requirement	m³/s	0.61	0.61	0.61
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	73.5	73.5	73.5
Line/load connection U1, V1, W1 / U2, V2, W2			Flat connection	n for M12 screw
PE connection		M10 screw	M10 screw	M10 screw
Max. connection cross-sections - Mains connection (U1, V1, W1) - Load connection (U2, V2, W2) - PE connection	mm² mm² mm²	Rail Rail 4 x 240	Rail Rail 4 x 240	Rail Rail 4 x 240
Degree of protection		IP00	IP00	IPOO
Dimensions - Width - Height - Depth	mm mm mm	501 1676.5 533	501 1676.5 533	501 1676.5 533
Frame size		FS2	FS4	FS4+
Weight	kg	358	456	548

¹⁾ The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.

Line Modules 5

5.1 Introduction

The drive line-up is connected to the power supply network via the Line Modules.

Line Infeeds comprise a Line Module and the associated line connection and generate a DC voltage from the connected line voltage that is used to power the connected Motor Modules.

The Line Modules and Interface Modules are suitable for direct operation on TN, IT and TT systems.

General characteristics of the Line Modules

- Supply voltage:
 - 3 AC 380 V -10% (-15% < 1 min) to 3 AC 480 V +10%
 - 3 AC 500 V -10% (-15% < 1 min) to 3 AC 690 V +10%
- Line frequency: 47 to 63 Hz
- Suitable for TN, TT, and IT supply systems
- Operating status and error status via LEDs

5.2 Basic Line Modules


5.2.1 Description

Basic Line Modules are used for the power infeed into the DC link.

They are suitable for applications in which no regenerative energy is produced, or in which the energy exchange takes place between the motor- and the generator-driven axes in the DC link.

The DC link voltage is greater than the rms value of the rated line voltage by a factor of 1.35 (under partial load) or 1.32 (under full load).

Table 5-1 Overview of Basic Line Modules



Components of the Basic Infeed

A Basic Infeed comprises a Basic Line Module and an external line connection, which comprises a line filter and a line reactor.

Operating principle

One or more Motor Modules can be connected to the power supply system via the Basic Line Module. The Basic Line Module provides the DC link voltage for the Motor Modules.

The Basic Line Module is suitable for direct operation on TN, IT and TT systems.

Parallel connection of Basic Line Modules to increase power rating

Up to four Basic Line Modules with the same power rating can be connected in parallel in order to increase power.

The following rules must be observed when connecting Basic Line Modules in parallel:

- Up to 4 identical Basic Line Modules can be connected in parallel.
- A common Control Unit is required whenever the modules are connected in parallel.
- For multiple infeeds, power must be supplied to the systems from a common infeed point (i.e. different line supplies are not permitted).
- A line reactor must be series-connected to every parallel-connected Basic Line Module.
- The upstream line contactors of the individual precharging circuits must switch-on jointly and simultaneously.
- A derating factor of 7.5 % must be taken into consideration, regardless of the number of modules connected in parallel.

The following rules must be observed when connecting Basic Line Modules of frame size GD in parallel:

- Each Basic Line Module must be precharged via a separate precharging circuit.
- The circuit breakers of the respective precharging circuits must switch-on jointly and simultaneously; this can be performed via a monitoring function of the circuit breaker feedback signals.

Note

Different power units cannot be connected in parallel.

It is only possible to connect Basic Line Modules in parallel if all power units have the same hardware version.

It is not possible to connect Basic Line Modules with Article No. 6SL3330-1Txxx-xAA0 and Article No. 6SL3330-1Txxx-xAA3 in parallel.

5.2 Basic Line Modules

5.2.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



♠ DANGER

Electric shock due to a high DC link voltage

As long as the Line Module is connected to the line supply, the DC link is charged with a high voltage. Contact with components leads to death or serious injury.

• Disconnect and isolate the Line Module from the line supply when carrying out installation and maintenance work.



/ WARNING

Electric shock or fire due to overcurrent protective devices that trip too late

Overcurrent protective devices that do not trip or trip too late can cause an electric shock or fire.

To protect personnel and for fire protection purposes, at the infeed point, the short-circuit rating and loop impedance must correspond to the specifications in the documentation in order for the installed overcurrent protection devices to trip within the specified time.



MARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - 1) Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.

MARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in more downtimes and reduced service lives of Line Modules.

• Observe the ventilation clearances above, below and in front of the Line Modules, which are specified in the dimension drawings.

ACAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

• Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

5.2.3 Interface description

5.2.3.1 Overview




Figure 5-1 Basic Line Module, frame size FB




Figure 5-2 Basic Line Module, frame sizes GB, GD

5.2.3.2 Connection example




Figure 5-3 Connection example for Basic Line Module, frame sizes FB, GB,




Figure 5-4 Connection example, Basic Line Module, frame size GD

NOTICE

Damage to the device due to different phase sequence in the precharging and main circuits

During the brief overlap period where both contactors are simultaneously closed, the precharging resistors of the Basic Line Module could be overloaded and destroyed due to different phase sequences in the precharging and main circuits.

• Connect the power cables to the precharging and main circuits with the same phase sequence.

5.2 Basic Line Modules

5.2.3.3 Line/load connection

Table 5- 2 Line/load connection of the Basic Line Module

Terminals	Technical specifications				
U1, V1, W1	Voltage:				
3 AC power input	• 3 AC 380 V -10% (-15% < 1 min) 3 AC 480 V +10%				
	• 3 AC 500 V -10% (-15% < 1 min) 3 AC 690 V +10%				
	Frequency: 47 63 Hz				
	Connecting thread:				
	• Frame size FB: M10 / 25 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				
	• Frame sizes GB, GD: M12 / 50 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				
DCPA, DCNA	Voltage:				
Connection for Braking Module	• 513 648 VDC				
	• 675 932 VDC				
	Connections:				
	Frame sizes FB, GB, GD: Threaded bolts M6 / 6 Nm for cable lugs according to DIN 46234 / DIN 46235 ¹⁾				
DCP, DCN	Voltage:				
DC power output	• 513 648 VDC				
	• 675 932 VDC				
	Connecting thread:				
	• Frame size FB: M10 / 25 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				
	• Frame sizes GB, GD: M12 / 50 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				
PE connection	Connecting thread:				
	• Frame size FB: M10 / 25 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				
	• Frame sizes GB, GD: M12 / 50 Nm for cable lugs according to DIN 46234 / DIN 46235 1)				

^{1)} Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

5.2.3.4 X9 terminal strip

Table 5-3 Terminal strip X9 for Basic Line Modules, frame sizes FB, GB

	Terminal	Signal name	Technical specifications		
	1	P24V	External 24 V DC supply Voltage: 24 VDC (20.4 28.8 V) Current consumption: Max. 1.1 A		
	2	М			
	3	Reserved, do not use			
	4				
	5	Line contactor control	240 VAC: Max. 8 A		
	6		30 VDC: Max. 1 A isolated		
Max. connectable cross-section: 2.5 mm ²					

Table 5-4 Terminal strip X9 for Basic Line Modules, frame size GD

	Terminal	Signal name	Technical specifications		
	1	P24V	External 24 V DC supply Voltage: 24 VDC (20.4 28.8 V) Current consumption: Max. 1.1 A		
	2	М			
	3	Line contactor control	240 VAC: Max. 8 A		
	4		30 VDC: Max. 1 A isolated		
	5	Precharge contactor	240 VAC: Max. 8 A		
	6	control	30 VDC: Max. 1 A isolated		
Max. connectable cross-section: 2.5 mm ²					

NOTICE

Damage to the device due to incorrect connection of terminal strip X9

If the connections for the "Line contactor control" and the "Precharging contactor control" are swapped, the device can be destroyed when it is switched on.

• Note the different connection assignments for terminal strip X9 for the various modules.

5.2.3.5 X41 EP terminal / temperature sensor connection

Table 5- 5 Terminal strip X41

Connector	Terminal	Function	Technical specifications		
1 2 3 4	1	EP M1 (Enable Pulses)	Supply voltage: 24 VDC (20.4 28.8 V) Current consumption: 10 mA		
	2	EP +24 V (Enable Pulses)			
	3	- Temp	Temperature sensor connection KTY84- 1C130 / PT1000 / PTC		
	4	+ Temp			
Max. connectable cross-section: 1.5 mm ²					

5.2 Basic Line Modules



MARNING

Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to motor in the event of incorrectly connected KTY temperature sensor

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

Connect a KTY temperature sensor with the correct polarity.

Note

The temperature sensor connection can be used for motors that are equipped with a KTY84-1C130, PT1000 or PTC measuring sensor in the stator windings.

Note

Connection to terminals 1 and 2

For operation, 24 VDC must be connected to terminal 2 and ground to terminal 1. Pulse suppression is activated when removed.

5.2.3.6 X42 terminal strip

Table 5- 6 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications
O [1]	1	P24L	Voltage supply for Control Unit, Sensor Module and
Q [2]2	2		Terminal Module (18 to 28.8 V) maximum load current: 3 A
	3	М	maximum load current: 3 A
0412	4		
Max. connecta	able cross-sec	tion: 2.5 mm ²	

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

5.2.3.7 DRIVE-CLiQ interfaces X400, X401, X402

Table 5-7 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications
₽₽B	1	TXP	Transmit data +
▎▐█૽૽ૺ	2	TXN	Transmit data -
1 =	3	RXP	Receive data +
	4	Reserved, do not use	
	5	Reserved, do not use	
	6	RXN	Receive data -
	7	Reserved, do not use	
	8	Reserved, do not use	
	Α	+ (24 V)	24 V power supply
	В	M (0 V)	Electronics ground
Blanking plate	for DRIVE-CLi	Q interfaces (50 pcs.) Article number:	6SL3066-4CA00-0AA0

5.2.3.8 Meaning of the LEDs on the Control Interface Module in the Basic Line Module

Table 5-8 Meaning of the LEDs "READY" and "DC LINK" on the Control Interface Module in the Basic Line Module

LED state		Description				
READY	DC LINK					
Off	Off	The electronics power supply is missing or out of tolerance.				
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.				
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.				
	Red	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.				
Orange	Orange	DRIVE-CLiQ communication is being established.				
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.				
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.				
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.				
Flashing light 2 Hz: green/orange or red/orange	1)	Detection of the components via LED is activated (p0124). Note: Both options depend on the LED status when module recognition is activated via $p0124 = 1$.				

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 5-9 Meaning of the LED "POWER OK" on the Control Interface Module in the Basic Line Module

LED	Color	Status	Description
POWER OK	Green	Off	DC link voltage or control voltage at -X9 too low.
		On	The component is ready for operation.
Flashing light		, ,	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



MARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

5.2.4 Dimension drawing

Dimension drawing, frame size FB

The mandatory ventilation clearances are indicated by the dotted line.




Figure 5-5 Dimension drawing, Basic Line Module, frame sizes FB, side view, front view

5.2 Basic Line Modules

Dimension drawing, frame sizes GB, GD

The mandatory ventilation clearances are indicated by the dotted line.




Figure 5-6 Dimension drawing, Basic Line Module, frame sizes GB, GD. Side view, rear view

5.2.5 Electrical connection

Removing the connection clip of the integrated basic interference suppression module to ground

The connection of the integrated basic interference suppression module to ground must be disconnected if the device is operated on one of the following line system configurations:

- Non-grounded line supply (IT supply system)
- Line supply with grounded line conductor

The connection is disconnected by removing the connection clip of the integrated basic interference suppression module to ground.

Note

Warning label on the connection clip

A yellow warning label is attached to each connection clip so that it is easier to find.

• The warning label must be removed from the connection clip (by pulling it off) if the connection clip is to remain in the device.



Figure 5-7 Warning label on the connection clip

NOTICE

Damage to the device by not removing the connection clip

Failure to remove the connection clip of the integrated basic interference suppression module to ground for a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor can cause significant damage to the device.

• For a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor, remove the connection clip of the integrated basic interference suppression module to ground.

5.2 Basic Line Modules




Figure 5-8 Removing the connection clip of the basic interference suppression module to ground for frame size FB





Figure 5-9 Removing the connection clip of the basic interference suppression module to ground for frame sizes GB, GD

Adjusting the fan voltage (-T10)

The power supply for the device fans (1 AC 230 V) in the Basic Line Module (-T10) is taken from the line supply using transformers. The installation position of the transformers is indicated in the interface descriptions.

The transformers are fitted with primary taps so that they can be fine-tuned to the line supply voltage.

If necessary, the connection fitted in the factory, shown with a dashed line, must be reconnected to the actual line voltage.






Figure 5-10 Setting terminals for the fan transformers (3 AC 380 ... 480 V / 3 AC 500 ... 690 V)

The supply voltage assignments for making the appropriate setting on the fan transformer are indicated in the following tables (factory presetting: 480 V / 0 V or 690 V / 0 V).

Note

With the 3 AC 500 V to 690 V fan transformer, a jumper is inserted between the "600 V" terminal and "CON" terminal. The "600 V" and "CON" terminals are for internal use.



Fire due to overheating resulting from insufficient equipment fan voltage

If the terminals are not reconnected to the actual line voltage, overheating and human danger due to smoke and fire may result.

This can also cause the fan fuses to blow due to overload.

• Set the terminals in accordance with the actual line voltage.

Table 5- 10 Line voltage assignment for the setting at the fan transformer (3 AC 380 ... 480 V)

Line voltage	Tap at the fan transformer (-T10)
380 V ± 10%	380 V
400 V ± 10%	400 V
440 V ± 10%	440 V
480 V ± 10%	480 V

Table 5- 11 Line voltage assignment for the setting at the fan transformer (3 AC 500 ... 690 V)

Line voltage	Tap at the fan transformer (-T10)
500 V ± 10%	500 V
525 V ± 10%	525 V
575 V ± 10%	575 V
600 V ± 10%	600 V
660 V ± 10%	660 V
690 V ± 10%	690 V

5.2.6 Precharging circuit for the Basic Line Modules, frame size GD

Description

When switching on, the pre-charging input circuit ensures that the DC link capacitors of the Basic Line Module and the connected Motor Modules are precharged with current limiting.

After pre-charging has been completed, the circuit breaker is closed and the pre-charging input circuit bypassed; the Basic Line Module is then directly connected to the line supply.

The pre-charging input circuit comprises a precharging contactor and precharging resistors; the circuit must be protected against overcurrent using suitable protection measures.

To increase the permissible DC link capacitance, the precharging resistors can also be connected in parallel in each phase.

NOTICE

Damage to the units if the pre-charging input circuit is faulty

When it is switched on, the Basic Line Module can be destroyed if the pre-charging input circuit is not correctly implemented.

• For Basic Line Modules, frame size GD, the precharging input circuit must be implemented according to the following circuit and the notes for dimensioning the various components.

5.2 Basic Line Modules




Figure 5-11 Connection example, Basic Line Module, frame size GD

Precharging contactor

The precharging contactor must be able to conduct the maximum precharging current for approx. 1 second (see the technical data) - and be able to switch ohmic-capacitive loads.

To protect against overvoltage when opening, the contactor should be equipped with a varistor, corresponding to the manufacturer's recommendations.

The precharging contactor is controlled via terminal -X9:5/6 of the Basic Line Module.

For a version with one precharging resistor for each phase, a Sirius 3RT2027 is recommended.

For a version with two precharging resistors connected in parallel for each phase, a Sirius 3RT2037 contactor is recommended.

Precharging resistors

The precharging resistors are used to limit the current while precharging.

Table 5- 12 Technical data of the precharging resistors

Category	Unit	3 AC 380 480 V	3 AC 500 690 V
Rated voltage	V	690 V AC	690 V AC
Frequency	Hz	47 63	47 63
Resistance value	Ω	2.2 ±10%	4.0 ±10%
Pulse energy 1)	Ws	18000	18000
Precharging current ²⁾ - one resistor per phase - two resistors per phase in parallel	A A	91 182	86 172
Ambient temperature	° C	60	60
Conductor cross-section	mm²	2.5	2.5
Article number		6SL3000-0KE12-2AA0	6SL3000-0KH14-0AA0

¹⁾ The pulse energy may only occur every 3 minutes

As the precharging resistors can get hot, sufficient cooling and clearance to adjacent components must be ensured in operation.




Figure 5-12 Dimension drawing, precharging resistor

²⁾ Line current present at the start of the precharging (initial rms value)

5.2 Basic Line Modules

Fuses

The pre-charging input circuit components are protected against overload using fuses.

For versions with one precharging resistor for each phase, 3NE1 817-0 (50 A) fuses are recommended.

For versions with two precharging resistors connected in parallel for each phase, 3NE1 021-0 fuses (100 A) are recommended.

Circuit breaker

The circuit breaker is used to connect the Basic Line Module to the supply system.

A 3WA1220 circuit breaker is recommended.

The circuit breaker is controlled via terminal -X9:3/4 of the Basic Line Module:

5.2.7 Technical data

5.2.7.1 Basic Line Modules, 380 ... 480 V 3 AC

Table 5-13 Technical data for Basic Line Modules, 3 AC 380 V ... 480 V, Part 1

Article number	6SL3330-	1TE34-2AA3	1TE35-3AA3	1TE38-2AA3	1TE41-2AA3
Rated power - For In_DC (50 Hz, 400 V) - For IH_DC (50 Hz, 400 V) - For In_DC (60 Hz, 460 V) - For IH_DC (60 Hz, 460 V)	kW kW HP HP	200 160 305 245	250 200 385 305	400 315 615 485	560 450 860 690
DC link current - Rated current In_DC - Base-load current IH_DC - Maximum current Imax_DC	A A A	420 328 630	530 413 795	820 640 1230	1200 936 1800
Input current - Rated current In_E - Maximum current Imax_E - Maximum precharging current (max. 3 s)	A A A	365 547 internal	460 690 internal	710 1065 internal	1010 1515 internal
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage - DC link voltage	VACrms 3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10% Hz VDC 24 (20.4 28.8) VAC 230 (195.5 264.5) VDC 1.35 x Uline (partial load) / 1.32 x Uline (full load)				
Current consumption - Electronics current consumption (24 V DC) - Fan power consumption (230 V AC)	A A	1.1	1.1	1.1	1.1
Max. ambient temperature - Without derating - With derating	°C	40 55	40 55	40 55	40 55

Article number	6SL3330-	1TE34-2AA3	1TE35-3AA3	1TE38-2AA3	1TE41-2AA3
DC link capacitance - Basic Line Module - Drive line-up, max.	μ F μ F	7200 57600	9600 76800	14600 116800	23200 185600
Power loss, max. 1) - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	1.9 1.9	2.1 2.1	3.2 3.2	4.6 4.6
Cooling air requirement	m³/s	0.17	0.17	0.17	0.36
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	66 / 68	66 / 68	66 / 68	71 / 73
Line/load connection			Flat connec	tor for screw	
		M10	M10	M10	M12
Max. conductor cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection	mm² mm² mm²	2 x 240 2 x 240 2 x 240	2 x 240 2 x 240 2 x 240	2 x 240 2 x 240 2 x 240	6 x 185 6 x 185 4 x 240
Max. cable length (total of all motor cables and DC link) - Shielded - Unshielded	m m	2600 3900	2600 3900	2600 3900	4000 6000
Degree of protection		IP00	IP00	IP00	IP00
Dimensions - Width - Height - Depth	mm mm mm	310 1164 352	310 1164 352	310 1164 352	310 1653 550
Frame size		FB	FB	FB	GB
Weight	kg	96	96	96	214
Recommended fuse ^{2) 3)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1333-2 1 450 2	3NE1334-2 1 500 3	3NE1438-2 1 800 3	3NE1435-2 2 560 3
Minimum short-circuit current 4)	kA	4.4	5.2	10	12.4

¹⁾ The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.

²⁾ To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.

Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.

⁴⁾ Minimum current required so that protective devices reliably respond and trip.

5.2 Basic Line Modules

Table 5- 14 Technical data for Basic Line Modules, 3 AC 380 V ... 480 V, Part 2

Article number	6SL3330-	1TE41-5AA3	1TE41-8AA3		
Rated power - For In_DC (50 Hz, 400 V) - For IH_DC (50 Hz, 400 V) - For In_DC (60 Hz, 460 V) - For IH_DC (60 Hz, 460 V)	kW kW HP HP	710 560 1090 860	900 705 1390 1090		
DC link current - Rated current In_DC - Base-load current IH_DC - Maximum current Imax_DC	A A A	1500 1170 2250	1880 1467 2820		
Input current - Rated current In_E - Maximum current Imax_E - Maximum precharging current (max. 3 s)	A A A	1265 1897 internal	1630 2380 308		
Supply voltages - Line voltage - Line frequency - Electronics power supply - Fan supply voltage - DC link voltage	VACrms Hz VDC VAC VDC	3 AC 380 -10% (-15% < 1 min) 3 AC 480 +10% 47 63 Hz 24 (20.4 28.8) 230 (195.5 264.5) 1.35 x Uline (partial load) / 1.32 x Uline (full load)			
Current consumption - Electronics current consumption (24 V DC) - Fan power consumption (230 V AC)	A A	1.1	1.1		
Max. ambient temperature - Without derating - With derating	°C °C	40 55	40 55		
DC link capacitance - Basic Line Module - Drive line-up, max.	μF μF	29000 232000	34800 139200/ 278400 ⁵⁾		
Power loss, max. 1) - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	5.5 5.5	6.9 6.9		
Cooling air requirement	m³/s	0.36	0.36		
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	71 / 73	71 / 73		
Line/load connection			Flat connec	tor for screw	
		M12	M12		
Max. conductor cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection	mm² mm² mm²	6 x 185 6 x 185 4 x 240	6 x 185 6 x 185 4 x 240		
Max. cable length (total of all motor cables and DC link) - Shielded - Unshielded	m m	4000 6000	4800 7200		
Degree of protection		IP00	IP00		
Dimensions - Width - Height - Depth	mm mm mm	310 1653 550	310 1653 550		
Frame size		GB	GD		
Weight	kg	214	214		

Article number	6SL3330-	1TE41-5AA3	1TE41-8AA3	
Recommended fuse ^{2) 3)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1437-2 2 710 3	3NE1435-2 3 560 3	
Minimum short-circuit current 4)	kA	18.4	18.6	

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- ²⁾ To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- ⁴⁾ Minimum current required so that protective devices reliably respond and trip.
- ⁵⁾ The first value applies for one precharging resistor for each phase, the second value for two precharging resistors connected in parallel for each phase

5.2.7.2 Basic Line Modules, 500 ... 690 V 3 AC

Table 5- 15 Technical data for Basic Line Modules, 500 V ... 690 V 3 AC, Part 1

Article number	6SL3330-	1TG33-0AA3	1TG34-3AA3	1TG36-8AA3	1TG41-1AA3
Rated power - For In_Dc (50 Hz, 690 V)	kW	250	355	560	900
- For I _{H_DC} (50 Hz, 690 V)	kW	195	280	440	710
- For In_pc (50 Hz, 500 V) - For IH pc (50 Hz, 500 V)	kW kW	175 165	250 235	390 365	635 595
- For In_DC (60 Hz, 575 V)	HP	250	350	600	900
- For I _{H_DC} (60 Hz, 575 V)	HP	200	300	450	800
DC link current					
- Rated current In_DC	Α	300	430	680	1100
- Base-load current Iн_Dc	Α	234	335	530	858
- Maximum current I _{max_DC}	Α	450	645	1020	1650
Input current		260	275	F7F	025
- Rated current In_E	A	260 390	375 563	575	925
- Maximum current I _{max_E} - Maximum precharging current (max. 3 s)	A A	internal	internal	863 internal	1388 internal
. 3 3	A	Internal	Internal	Internal	Internal
Supply voltages - Line voltage	VACrms	3 AC 50	00 -10% (-15% <	1 min) 3 AC 60	ı∩ ±10%
- Line frequency	Hz	371030		63 Hz	0 1 10 /0
- Electronics power supply	VDC			· 28.8)	
- Fan supply voltage	VAC			5 264.5)	
- DC link voltage	VDC	1.35 x	Uline (partial load		ll load)
Current consumption					
- Electronics current consumption	Α	1.1	1.1	1.1	1.1
(24 V DC)					
- Fan power consumption	Α	1.1	1.1	1.1	4.5
(230 V AC)					
Max. ambient temperature	0.0	40	40	40	40
- Without derating	°C	40	40	40	40 55
- With derating		55	55	55	55
DC link capacitance		2200	4000	7200	11600
- Basic Line Module - Drive line-up, max.	μF μF	3200 25600	4800 38400	7300 58400	11600 92800
·	μΓ	23000	36400	36400	92800
Power loss, max. 1) - at 50 Hz 690 V	kW	1.5	2.1	3.0	5.4
- at 60 Hz 575 V	kW	1.5	2.1	3.0	5.4
Cooling air requirement	m³/s	0.17	0.17	0.17	0.36
Sound pressure level	,5				0.00
L _{pA} (1 m) at 50/60 Hz	dB(A)	66 / 68	66 / 68	66 / 68	71 / 73
Line/load connection			Flat connec	tor for screw	
		M10	M10	M10	M12
Max. conductor cross-sections		-	-	-	
- Line connection (U1, V1, W1)	mm²	2 x 240	2 x 240	2 x 240	6 x 185
- DC link connection (DCP, DCN)	mm²	2 x 240	2 x 240	2 x 240	6 x 185
- PE connection	mm²	2 x 240	2 x 240	2 x 240	4 x 240
Max. cable length					
(total of all motor cables and DC link)					
- Shielded	m	1500	1500	1500	2250
- Unshielded	m	2250	2250	2250	3375
Degree of protection		IP00	IP00	IP00	IP00

Article number	6SL3330-	1TG33-0AA3	1TG34-3AA3	1TG36-8AA3	1TG41-1AA3
Dimensions - Width - Height - Depth	mm mm mm	310 1164 352	310 1164 352	310 1164 352	310 1653 550
Frame size		FB	FB	FB	GB
Weight	kg	96	96	96	214
Recommended fuse ^{2) 3)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1230-2 1 315 2	3NE1333-2 1 450 2	3NE1436-2 1 630 3	3NE1334-2 2 500 3
Minimum short-circuit current 4)	kA	3	4.4	8	10.4

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- ²⁾ To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- ⁴⁾ Minimum current required so that protective devices reliably respond and trip.

5.2 Basic Line Modules

Table 5- 16 Technical data for Basic Line Modules, 500 V ... 690 V 3 AC, Part 2

Table 5 10 Technical data for basic line wic	1	T	1	T	
Article number	6SL3330-	1TG41-4AA3	1TG41-8AA3		
Rated power					
- For In_DC (50 Hz, 690 V)	kW	1100	1500		
- For IH_DC (50 Hz, 690 V)	kW	910	1220		
- For In_DC (50 Hz, 500 V)	kW	810	1085		
- For IH_DC (50 Hz, 500 V)	kW	755	1015		
- For In_DC (60 Hz, 575 V)	HP	1250	1500		
- For I _{H_DC} (60 Hz, 575 V)	HP	1000	1250		
DC link current	1.	4.400	4000		
- Rated current In_DC	A	1400	1880		
- Base-load current IH_DC	A	1092	1467		
- Maximum current I _{max_DC}	Α	2100	2820		
Input current	1.	1100	4500		
- Rated current In_E	A	1180	1580		
- Maximum current I _{max_E}	A	1770	2370		
- Maximum precharging current (max. 3 s)	Α	internal	234		
Supply voltages					
- Line voltage	VACrms	3 AC 50	00 -10% (-15% < 1		0 +10%
- Line frequency	Hz			63 Hz	
- Electronics power supply	VDC			28.8)	
- Fan supply voltage	VAC	4.25		5 264.5)	
- DC link voltage	V DC	1.35 X	Uline (partial load)	II load)
Current consumption					
- Electronics current consumption (24 V DC)	Α	1.1	1.1		
- Fan power consumption	Α	4.5	4.5		
(230 V AC)					
Max. ambient temperature					
- Without derating	°C	40	40		
- With derating	°C	55	55		
DC link capacitance					
- Basic Line Module	μF	15470	19500		
- Drive line-up, max.	μF	123760	78000/		
			156000 ⁵⁾		
Power loss, max. 1)					
- at 50 Hz 690 V	kW	5.8	7.3		
- at 60 Hz 575 V	kW	5.8	7.3		
Cooling air requirement	m³/s	0.36	0.36		
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	71 / 73	71 / 73		
Line/load connection			Flat connect	tor for screw	
		M12	M12		
Max. conductor cross-sections					
- Line connection (U1, V1, W1)	mm²	6 x 185	6 x 185		
- DC link connection (DCP, DCN)	mm ²	6 x 185	6 x 185		
- PE connection	mm ²	4 x 240	4 x 240		
Max. cable length					
(total of all motor cables and DC link)					
- Shielded	m	2250	2750		
- Unshielded	m	3375	4125		
Degree of protection		IPO0	IPO0		
Dimensions		11 00	11 00		
- Width	mm	310	310		
- Width - Height	mm	1653	1653		
- neight - Depth	mm	550	550		
-	1				
Frame size		GB	GD		

Article number	6SL3330-	1TG41-4AA3	1TG41-8AA3	
Weight	kg	214	214	
Recommended fuse ^{2) 3)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1436-2 2 630 3	3NE1435-2 3 560 3	
Minimum short-circuit current 4)	kA	16	18.6	

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- 2) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 4) Minimum current required so that protective devices reliably respond and trip.
- The first value applies for one precharging resistor for each phase, the second value for two precharging resistors connected in parallel for each phase

5.2.7.3 Overload capability

The Basic Line Modules have an overload reserve.

The criterion for overload is that the Basic Line Module is operated as a maximum with its base load current before and after the overload occurs (a load duration of 300 s is used as a basis here).

High overload

The base load current for a high overload I_{H_DC} is based on a duty cycle of 150% for 60 s; the max. current I_{max_DC} can flow for 5 s.




Figure 5-13 High overload

5.3 Smart Line Modules


5.3.1 Description

Smart Line Modules are infeed/regenerative feedback units. Like the Basic Line Module, they supply energy to the connected Motor Modules, but unlike the Basic Line Module, they can feed back regenerative energy.

The infeed occurs over a diode jumper, while stable, line-commutated regenerative feedback takes place via IGBTs with 100% continuous energy regeneration.

The DC link voltage is greater than the rms value of the rated line voltage by a factor of 1.32 (under partial load) or 1.30 (under full load).

Table 5- 17 Overview of Smart Line Modules



Components of the Smart Infeed

A Smart Infeed comprises a Smart Line Module and an external line connection, which comprises bypass contactor, precharging input circuit, fuse, and line reactor.




Figure 5-14 Overview of Smart Infeed

Operating principle

One or more Motor Modules can be connected to the power supply system via the Smart Line Module. The Smart Line Module provides the DC link voltage for the Motor Modules. The regenerative feedback capability of the Smart Line Module can be deactivated by parameterization.

The Smart Line Module is suitable for direct operation on TN, IT and TT systems.

In generator operation, the Smart Line Module feeds regenerative power back into the line supply. An integrated Voltage Sensing Module 10 (VSM10) is used for sensing the line voltage for regenerative feedback

The Smart Line Module is used for:

- Machines with medium dynamic requirements
- · Infrequent braking cycles and high braking energy

5.3 Smart Line Modules

Parallel connection of Smart Line Modules to increase power rating

Up to four Smart Line Modules with the same power rating can be connected in parallel in order to increase power.

The following rules must be observed when connecting Smart Line Modules in parallel:

- Up to four identical Smart Line Modules can be connected in parallel.
- A common Control Unit is required whenever the modules are connected in parallel.
- For multiple infeeds, power must be supplied to the systems from a common infeed point (i.e. different line supplies are not permitted).
- A line reactor must be series-connected to every parallel-connected Smart Line Module.
- A derating factor of 7.5 % must be taken into consideration, regardless of the number of modules connected in parallel.

Note

Different power units cannot be connected in parallel.

It is only possible to connect Smart Line Modules in parallel if all power units have the same hardware version.

It is not possible to connect Smart Line Modules with Article No. 6SL3330-6Txxx-xAA0 and Article No. 6SL3330-6Txxx-xAA3 in parallel.

NOTICE

Converter error due to missing circuit breaker wiring

If the leading contact of the circuit breaker is not wired to the OFF2 signal from the Control Unit, the SINAMICS control reacts with the "Overvoltage" or "Undervoltage" error if the circuit breaker is triggered.

• Connect the signal from the leading contact of the circuit breaker to the OFF2 signal from the Control Unit. In this way, the SINAMICS control is able to delete pulses from the Smart Line Modules in good time, before the circuit breaker is opened.

5.3.2 Safety information

MARNING

Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



DANGER

Electric shock due to a high DC link voltage

As long as the Line Module is connected to the line supply, the DC link is charged with a high voltage. Contact with components can result in death or serious injury.

 Disconnect and isolate the Line Module from the line supply when carrying out installation and maintenance work.



/ WARNING

Electric shock or fire due to overcurrent protective devices that trip too late

Overcurrent protective devices that do not trip or trip too late can cause an electric shock or fire.

• To protect personnel and for fire protection purposes, at the infeed point, the short-circuit rating and loop impedance must correspond to the specifications in the documentation in order for the installed overcurrent protection devices to trip within the specified time.

5.3 Smart Line Modules



MWARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.

MARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in more downtimes and reduced service lives of Line Modules.

• Observe the ventilation clearances above, below and in front of the Line Modules, which are specified in the dimension drawings.

♠ CAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.

NOTICE

Material damage caused by the failure to remove linkage levers for devices of frame sizes HX and JX

The failure to remove linkage levers from devices of frame sizes HX and JX can cause damage to the device as a result of undershooting the necessary voltage clearances.

For devices of frame sizes HX and JX, remove the linkage levers marked in red once the
devices have been installed.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

• Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

Note

Operation on line supplies where energy recovery is not possible

In line supply systems without energy recovery capability (e.g. a diesel generator), device faults can occur as the braking energy cannot be dissipated.

- For line supplies without regenerative feedback capability (e.g. diesel generator), deactivate the regenerative feedback capability of the Line Modules using the appropriate parameter (see SINAMICS S120/S150 List Manual).
- The braking energy must then be dissipated via an additional Braking Module with braking resistor in the drive line-up.

5.3.3 Interface description

5.3.3.1 Overview




Figure 5-15 Smart Line Module, frame size GX




Figure 5-16 Smart Line Module, frame size HX

5.3 Smart Line Modules




Figure 5-17 Smart Line Module, frame size JX

5.3.3.2 Connection example




Figure 5-18 Smart Line Module wiring diagram

5.3 Smart Line Modules

NOTICE

Damage to the device due to different phase sequence in the precharging and main circuits

If the precharging and main circuits have different phase sequences, the precharging resistors could be overloaded and destroyed during the brief overlap period where both contactors are simultaneously closed.

• Wire the precharging and main circuits with the same phase sequence.

5.3.3.3 Line/load connection

Table 5- 18 Line/load connection of the Smart Line Module

Terminals	Technical specifications		
U1, V1, W1	Voltage:		
3 AC power input	• 3 AC 380 V -10 % (-15 % < 1 min) 3 AC 480 V +10 %		
	• 3 AC 500 V -10 % (-15 % < 1 min) 3 AC 690 V +10 %		
	Frequency: 47 63 Hz		
	Connecting thread:		
	• Frame size GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		
DCPA, DCNA	Voltage:		
Connection for Brak- ing Module	• 500 630 V DC		
mig Wodale	• 650 900 V DC		
	Connections:		
	Frame size GX: Threaded bolts M6 / 6 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		
	Frame sizes HX / JX: Connection for connection clip		
DCP, DCN	Voltage:		
DC power output	• 500 630 V DC		
	• 650 900 V DC		
	Connections:		
	• Frame size GX: Thread M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		
	• Frame sizes HX / JX: d = 12 mm (M12/50 Nm) flat connector for busbar		
PE connection	Connecting thread:		
PE1, PE2	• Frame size GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)		

^{1)} Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

5.3.3.4 X9 terminal strip

Table 5- 19 Terminal strip X9

	Terminal	Signal name	Technical specifications
(a) [i]	1	P24V	External 24 V DC supply
	2	М	Voltage: 24 VDC (20.4 28.8 V) Current consumption: max. 1.7 A
	3	Bypass contactor con-	240 V AC: 8 A max.
5 5	4	trol	24 VDC: max. 1 A isolated
2	5	Not assigned	
	6		
	7	Checkback signal pre-	Voltage: 230 VAC
	8	charge contactor	Maximum permissible current: 6 A isolated
			Contact closed: Contactor is de-energized
			Contact open: Contactor is energized
	L1	Connection of pre-	3 AC 380 3 AC 480 V or
	L2	charging circuit and fan	3 AC 500 3 AC 690 V
	L3	supply	Current consumption: See Technical data

Max. connectable cross-section:

- terminal 1 ... 8: 2.5 mm²
- terminals L1 ... L3: 16 mm²

NOTICE

Damage to devices if the bypass contactor is incorrectly controlled

When it is switched on, the Smart Line Module can be destroyed if the bypass contactor is not correctly controlled.

• Only control the bypass contactor using terminals X9:3/4, as is shown in the previous connection example.

5.3.3.5 X41 EP terminal / temperature sensor connection

Table 5- 20 Terminal strip X41

Connector	Terminal	Function	Technical specifications
0000	1	EP M1 (Enable Pulses)	Supply voltage: 24 VDC (20.4 28.8 V)
	2	EP +24 V (Enable Pulses)	Current consumption: 10 mA
0000	3	- Temp	Temperature sensor connection KTY84-
	4	+ Temp	1C130 / PT1000 / PTC
Max. connecta	ble cross-sect	ion: 1.5 mm ²	





Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to motor in the event of incorrectly connected KTY temperature sensor

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

• Connect a KTY temperature sensor with the correct polarity.

NOTICE

Looping the circuit breaker into the EP terminal circuit for infeed units capable of energy recovery

If the upstream circuit breakers are not controlled from the SINAMICS drive group in the case of infeed units capable of energy recovery, then this can have a damaging reaction on the section that has been shut down when the circuit breaker is opened. As a consequence, under certain circumstances, the components connected in the line supply section involved could be damaged as a result of overvoltage.

• If, for infeed units capable of energy recovery, the upstream circuit breaker is not controlled from the SINAMICS drive group, then an auxiliary contact of the circuit breaker should be looped into the circuit associated with the EP terminals.

Note

The temperature sensor connection can be used for motors that are equipped with a KTY84-1C130, PT1000 or PTC measuring sensor in the stator windings.

Note

Connection to terminals 1 and 2

For operation, 24 VDC must be connected to terminal 2 and ground to terminal 1. Pulse suppression is activated when removed.

5.3.3.6 X42 terminal strip

Table 5- 21 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications
O [1]	1	P24L	Voltage supply for Control Unit, Sensor Module and
Q □2 >	2		Terminal Module (18 to 28.8 V)
	3	М	maximum load current: 3 A
OUTP	4		
Max. connectable cross-section: 2.5 mm ²			

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

5.3 Smart Line Modules

5.3.3.7 DRIVE-CLiQ interfaces X400, X401, X402

Table 5- 22 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications		
. □■B	1	TXP	Transmit data +		
▎▐█૽૽ૺ	2	TXN	Transmit data -		
¹ E J	3	RXP	Receive data +		
	4	Reserved, do not use			
	5	Reserved, do not use			
	6	RXN Receive data -			
	7	Reserved, do not use			
	8	Reserved, do not use			
	Α	+ (24 V) 24 V power supply			
	В	M (0 V) Electronics ground			
Blanking plate	Blanking plate for DRIVE-CLiQ interfaces (50 pcs.) Article number: 6SL3066-4CA00-0AA0				

5.3.3.8 Meaning of the LEDs on the Control Interface Module in the Smart Line Module

Table 5-23 Meaning of the LEDs "READY" and "DC LINK" on the Control Interface Module in the Smart Line Module

LED state		Description	
READY	DC LINK		
Off	Off	The electronics power supply is missing or out of tolerance.	
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is t place.	
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.	
	Red	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.	
Orange	Orange	DRIVE-CLiQ communication is being established.	
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have be reconfigured.	
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.	
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.	
Flashing light 2 Hz: green/orange or red/orange	1)	Detection of the components via LED is activated (p0124). Note: Both options depend on the LED status when module recognition is activated via p0124 = 1.	

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 5- 24 Meaning of the LED "POWER OK" on the Control Interface Module in the Smart Line Module

LED	Color	Status	Description
POWER OK	Green	Off	DC link voltage or control voltage at -X9 too low.
		On	The component is ready for operation.
		Flashing light	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



MARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

5.3.4 Dimension drawing

Dimension drawing, frame size GX

The mandatory cooling clearances are indicated by the dotted line.




Figure 5-19 Dimension drawing Smart Line Module, frame size GX Front view, side view

Dimension drawing, frame size HX




Figure 5-20 Dimension drawing Smart Line Module, frame size HX Side view, rear view

Dimension drawing, frame size JX




Figure 5-21 Dimension drawing Smart Line Module, frame size JX Side view, rear view

5.3.5 Electrical connection

Removing the connection clip of the integrated basic interference suppression module to ground

The connection of the integrated basic interference suppression module to ground must be disconnected if the device is operated on one of the following line system configurations:

- Non-grounded line supply (IT supply system)
- · Line supply with grounded line conductor

The connection is disconnected by removing the connection clip of the integrated basic interference suppression module to ground.

Note

Warning label on the connection clip

A yellow warning label is attached to each connection clip so that it is easier to find.

• The warning label must be removed from the connection clip (by pulling it off) if the connection clip is to remain in the device.



Figure 5-22 Warning label on the connection clip

NOTICE

Damage to the device by not removing the connection clip

Failure to remove the connection clip of the integrated basic interference suppression module to ground for a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor can cause significant damage to the device.

• For a non-grounded line supply (IT supply system) or a line supply with a grounded line conductor, remove the connection clip of the integrated basic interference suppression module to ground.

With frame sizes HX and JX, you must remove the left-hand fan before removing the connection clip (see "Replacing components").




Figure 5-23 Removing the connection clip of the basic interference suppression module to ground for frame size GX




Figure 5-24 Removing the connection clip of the basic interference suppression module to ground for frame size HX





Figure 5-25 Removing the connection clip of the basic interference suppression module to ground for frame size JX

Removing the connector jumper on the VSM10 Voltage Sensing Module

When operating the Smart Line Module on an ungrounded line supply (IT system), at the Voltage Sensing Module (VSM10), remove the connector jumper in terminal X530 at the lower side of the component.

Use two screwdrivers or another suitable tool to relieve the holding springs in the terminal and then withdraw the connector jumper.



Note

Replacing a VSM10 Voltage Sensing Module

When replacing a Voltage Sensing Module VSM10 by one with a different article number, then inform yourself about the applicable boundary conditions.

Adjusting the fan voltage (-T10)


The power supply for the device fans (1 AC 230 V) in the Smart Line Module (-T10) is taken from the line supply using transformers. The installation position of the transformers is indicated in the interface descriptions.

The transformers are fitted with primary taps so that they can be fine-tuned to the line supply voltage.

If necessary, the connection fitted in the factory, shown with a dashed line, must be reconnected to the actual line voltage.

Note

Smart Line Modules, frame size JX, have two integrated transformers (-T10 and -T20). The two primary-side terminals on each of these devices must be adjusted together.






Figure 5-26 Setting terminals for the fan transformers (3 AC 380 ... 480 V / 3 AC 500 ... 690 V)

The supply voltage assignments for making the appropriate setting on the fan transformer are indicated in the following tables (factory presetting: 480 V / 0 V or 690 V / 0 V).

Note

With the 3 AC 500 V to 690 V fan transformer, a jumper is inserted between the "600 V" terminal and "CON" terminal. The jumper between terminal "600 V" and "CON" is for internal use.



Fire due to overheating resulting from insufficient equipment fan voltage

If the terminals are not reconnected to the actual line voltage, overheating and human danger due to smoke and fire may result.

This can also cause the fan fuses to blow due to overload.

• Set the terminals in accordance with the actual line voltage.

Table 5-25 Line voltage assignment for the setting at the fan transformer (3 AC 380 ... 480 V)

Line voltage	Tap at the fan transformer (-T10)
380 V ± 10%	380 V
400 V ± 10%	400 V
440 V ± 10%	440 V
480 V ± 10%	480 V

Table 5- 26 Line voltage assignment for the setting at the fan transformer (3 AC 500 ... 690 V)

Line voltage	Tap at the fan transformer (-T10)
500 V ± 10%	500 V
525 V ± 10%	525 V
575 V ± 10%	575 V
600 V ± 10%	600 V
660 V ± 10%	660 V
690 V ± 10%	690 V

5.3.6 Technical data

5.3.6.1 Smart Line Modules, 3 AC 380 ... 480 V

Table 5- 27 Technical data for Smart Line Modules, 3 AC 380 V ... 480 V, Part 1

Article number	6SL3330-	6TE35-5AA3	6TE37-3AA3	6TE41-1AA3	6TE41-3AA3
Rated output - For In_DC (50 Hz, 400 V) - For In_DC (50 Hz, 400 V) - For In_DC (60 Hz, 460 V) - For In_DC (60 Hz, 460 V)	kW kW HP HP	250 235 385 360	355 315 545 485	500 450 770 695	630 555 970 855
DC link current - Rated current In_DC - Base-load current IH_DC - Maximum current Imax_DC	A A A	550 490 825	730 650 1095	1050 934 1575	1300 1157 1950
Infeed/regenerative feedback current - Rated current In_E - Maximum current Imax_E	A A	463 694	614 921	883 1324	1093 1639
Supply voltages - Line voltage - Line frequency - Electronics power supply - DC link voltage	VACrms Hz VDC VDC			63 Hz 28.8)	
Current consumption - Electronics current consumption (24 V DC) - Fan power consumption (at 400 V AC)	A A	1.35 1.8	1.35 1.8	1.4 3.6	1.5 5.4
Bypass contactor 1)				3WA1110- 4AE03-4EQ0	3WA1112- 4AE03-4EQ0
Max. precharging current (max. 3 s)	Α	33	33	98	98
Max. ambient temperature - Without derating - With derating	°C °C	40 55	40 55	40 55	40 55
DC link capacitance - Smart Line Module - Drive line-up, max.	μF μF	8400 42000	12000 60000	16800 67200	18900 75600
Power loss, max. ²⁾ - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	3.7 3.7	4.7 4.7	7.1 7.1	11.0 11.0
Cooling air requirement	m³/s	0.36	0.36	0.78	1.08
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	69 / 73	69 / 73	70 / 73	70 / 73
Line/load connection			Flat connect	tor for screw	1
		M10	M10	M12	M12
Max. connection cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection PE1 - PE connection PE2	mm² mm² mm² mm²	2 x 240 2 x 240 2 x 240	2 x 240 2 x 240 2 x 240	4 x 240 Busbar 1 x 240 2 x 240	6 x 240 Busbar 1 x 240 3 x 240
Max. cable length (total of all motor cables and DC link) - Shielded - Unshielded	m m	4000 6000	4000 6000	4800 7200	4800 7200
Degree of protection		IP00	IP00	IP00	IP00

Article number	6SL3330-	6TE35-5AA3	6TE37-3AA3	6TE41-1AA3	6TE41-3AA3
Dimensions - Width - Height - Depth	mm mm mm	310 1420 550	310 1420 550	503 1475 550	704 1480 550
Frame size		GX	GX	HX	JX
Weight, approx.	kg	150	150	294	458
Recommended fuse 3) 4) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1435-2 1 560 3	3NE1437-2 1 710 3	3NE1334-2 2 500 3	3NE1436-2 2 630 3
Minimum short-circuit current 5)	kA	6.2	9.2	10.4	16

- 1) Bypass contactor is not included, must be provided separately.
- ²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.
- 3) To design a UL-approved system, it is absolutely essential to only use the specified fuses
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 5) Minimum current required for reliable triggering of the provided protective devices.

Table 5- 28 Technical data for Smart Line Modules, 3 AC 380 V ... 480 V, Part 2

Table 5- 28 Technical data for Smart Line Mi	T	1	1	Т	T
Article number	6SL3330-	6TE41-7AA3			
Rated output - For In_DC (50 Hz, 400 V) - For IH_DC (50 Hz, 400 V) - For In_DC (60 Hz, 460 V) - For IH_DC (60 Hz, 460 V)	kW kW HP HP	800 730 1230 1125			
DC link current - Rated current In_DC - Base-load current IH_DC - Maximum current Imax_DC	A A A	1700 1513 2550			
Infeed/regenerative feedback current - Rated current In_E - Maximum current Imax_E	A A	1430 2145			
Supply voltages - Line voltage - Line frequency - Electronics power supply - DC link voltage	VACrms Hz VDC VDC			63 Hz 28.8)	
Current consumption - Electronics current consumption (24 V DC) - Fan power consumption (at 400 V AC)	A A	1.7 5.4			
Bypass contactor 1)		3WA1116- 4AE03-4EQ0			
Max. precharging current (max. 3 s)	А	98			
Max. ambient temperature - Without derating - With derating	°C °C	40 55			
DC link capacitance - Smart Line Module - Drive line-up, max.	μ F μ F	28800 115200			
Power loss, max. ²⁾ - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	11.5 11.5			
Cooling air requirement	m³/s	1.08			
Sound pressure level L _{PA} (1 m) at 50/60 Hz	dB(A)	70 / 73			
Line/load connection			Flat connec	tor for screw	
		M12			
Max. connection cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection PE1 - PE connection PE2	mm² mm² mm² mm²	6 x 240 Busbar 1 x 240 3 x 240			
Max. cable length (total of all motor cables and DC link) - Shielded - Unshielded	m m	4800 7200			
Degree of protection		IPO0			
Dimensions - Width - Height - Depth	mm mm mm	704 1480 550			
Frame size		JX		_	
Weight, approx.	kg	458			

Article number	6SL3330-	6TE41-7AA3		
Recommended fuse ^{3) 4)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1448-2 2 850 3		
Minimum short-circuit current 5)	kA	21		

- 1) Bypass contactor is not included, must be provided separately.
- ²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.
- 3) To design a UL-approved system, it is absolutely essential to only use the specified fuses
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 5) Minimum current required for reliable triggering of the provided protective devices.

5.3.6.2 Smart Line Modules, 3 AC 500 ... 690 V

Table 5- 29 Technical data for Smart Line Modules, 3 AC 500 to 690 V

Article number	6SL3330-	6TG35-5AA3	6TG38-8AA3	6TG41-2AA3	6TG41-7AA3
Rated power					
- For In_DC (50 Hz, 690 V)	kW	450	710	1000	1400
- For In_Dc (50 Hz, 690 V)	kW	405	665	885	1255
- For In DC (50 Hz, 500 V)	kW	320	525	705	995
- For In_Dc (50 Hz, 500 V)	kW	295	480	640	910
- For In_DC (60 Hz, 575 V)	HP	500	790	1115	1465
- For In_Dc (60 Hz, 575 V)	HP	450	740	990	1400
DC link current					
- Rated current In DC	Α	550	900	1200	1700
- Base-load current Iн_DC	Α	490	800	1068	1513
- Maximum current Imax_DC	Α	825	1350	1800	2550
Infeed/regenerative feedback current					
- Rated current In_E	Α	463	757	1009	1430
- Maximum current Imax_E	Α	694	1135	1513	2145
Supply voltages				I.	I.
- Line voltage	VACrms	3 AC 5	00 -10% (-15% <	1 min) 3 AC 69	90 +10%
- Line frequency	Hz]		63 Hz	
- Electronics power supply	VDC			4 28.8)	
- DC link voltage	VDC	1.32 x	K Uline (partial load		ıll load)
Current consumption			<u>"</u>	ĺ	
- Electronics current consumption (24 VDC)	Α	1.35	1.4	1.5	1.7
- Fan power consumption	A	1.4 / 1.0	2.9 / 2.1	4.3 / 3.1	4.3 / 3.1
(at 500 VAC / 690 VAC)	, .	,			
Bypass contactor 1)				3WA1220-	3WA1220-
bypass contactor /				4AE03-4EQ0-Z	4AE03-4EQ0-Z
				Z=B12	Z=B16
Max. precharging current (max. 3 s)	Α	41	122	122	122
Max. ambient temperature					
- Without derating	°C	40	40	40	40
- With derating	°C	55	55	55	55
DC link capacitance	1				
- Smart Line Module	μF	5600	7400	11100	14400
- Drive line-up, max.	μF	28000	29600	44400	57600
Power loss, max. ²⁾	†				
- at 50 Hz 690 V	kW	4.3	6.5	12.0	13.8
- at 60 Hz 575 V	kW	4.3	6.5	12.0	13.8
Cooling air requirement	m³/s	0.36	0.78	1.08	1.08
Sound pressure level	† · · · · ·	1			
L _{pA} (1 m) at 50/60 Hz	dB(A)	69 / 73	70 / 73	70 / 73	70 / 73
	1 45(71)	0,1,5			, 51 / 5
Line/load connection		1110		tor for screw	1,440
		M10	M12	M12	M12
Max. connection cross-sections					
- Line connection (U1, V1, W1)	mm²	2 x 240	4 x 240	6 x 240	6 x 240
- DC link connection (DCP, DCN)	mm²	2 x 240	Busbar	Busbar	Busbar
- PE connection PE1	mm²	2 x 240	1 x 240	1 x 240	1 x 240
- PE connection PE2	mm²	-	2 x 240	3 x 240	3 x 240
Max. cable length					
(total of all motor cables and DC link)					
- Shielded	m	2250	2750	2750	2750
- Unshielded	m	3375	4125	4125	4125
Orisinciaca	1111	3373	1123		

Article number	6SL3330-	6TG35-5AA3	6TG38-8AA3	6TG41-2AA3	6TG41-7AA3
Dimensions - Width - Height - Depth	mm mm mm	310 1420 550	503 1475 550	704 1480 550	704 1480 550
Frame size		GX	HX	JX	JX
Weight, approx.	kg	150	294	458	458
Recommended fuse ^{3) 4)} - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1435-2 1 560 3	3NE1448-2 1 850 3	3NE1435-2 2 560 3	3NE1448-2 2 850 3
Minimum short-circuit current 5)	kA	6.2	10.5	12.4	21

- 1) Bypass contactor is not included, must be provided separately.
- ²⁾ The specified power loss is the maximum value at 100 % utilization level. The value in normal operation is lower.
- 3) To design a UL-approved system, it is absolutely essential to only use the specified fuses
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 5) Minimum current required for reliable triggering of the provided protective devices.

5.3.6.3 Overload capability

The Smart Line Modules have an overload reserve.

The criterion for overload is that the Smart Line Module is operated as a maximum with its base load current before and after the overload occurs (a load duration of 300 s is used as a basis here).

High overload

The base load current for a high overload I_{H_DC} is based on a duty cycle of 150% for 60 s; the max. current I_{max_DC} can flow for 5 s.





Figure 5-27 High overload

5.4.1 Description

The self-commutating infeed / regenerative feedback units act as step-up converters and generate a controlled DC link voltage that is 1.5x greater (factory setting) than the rated line voltage. In this way, the connected Motor Modules are isolated from the line voltage. This improves the dynamic response and control quality because line tolerances and fluctuations do not affect the motor voltage.

Active Line Module can be used to implement reactive power compensation by specifying an additive reactive current.

Table 5- 30 Overview of Active Line Modules



Active Infeed components

An Active Infeed comprises an Active Interface Module and an Active Line Module.

The bypass contactor is fitted in the relevant Active Interface Module on Active Infeeds which feature an Active Line Module of frame size FX or GX. The Active Interface Modules and Active Line Modules of these frame sizes have degree of protection IP20.




Figure 5-28 Overview of Active Infeed (frame sizes FI/FX and GI/GX)

In the case of an Active Infeed with an Active Line Module of frame sizes HX or JX, the bypass contactor is not included in the associated Active Interface Module, but must be provided separately. The Active Interface Modules and Active Line Modules of these frame sizes have degree of protection IP00.




Figure 5-29 Overview of Active Infeed (frame sizes HI/HX and JI/JX)

Operating principle

One or more Motor Modules can be connected to the power supply system via the Active Line Module. The Active Line Module provides a constant DC link voltage for the Motor Modules. This ensures that they are not influenced by line voltage fluctuations. The regenerative feedback capability of the Active Line Module can be deactivated by parameterization.

The Active Line Module is suitable for direct operation on TN, IT and TT systems.

When the motors operate as generators, the Active Line Module feeds regenerative power back into the line supply.

The Active Line Module is used for:

- Machines with high dynamic drive requirements
- · Frequent braking cycles and high braking energy

Parallel connection of Active Line Modules to increase power rating

Up to four Active Line Modules with the same power rating can be connected in parallel in order to increase power.

The following rules must be observed when connecting Active Line Modules in parallel:

- Up to 4 identical Active Line Modules can be connected in parallel.
- Each Active Line Module requires its own Active Interface Module.
- A common Control Unit is required whenever the modules are connected in parallel.
- For multiple infeeds, power must be supplied to the systems from a common infeed point (i.e. different line supplies are not permitted).
- A derating factor of 5 % must be taken into consideration, regardless of the number of modules connected in parallel.

Note

Different power units cannot be connected in parallel.

It is only possible to connect Active Line Modules in parallel if all power units have the same hardware version.

It is not possible to connect Active Line Modules with Article No. 6SL3330-7Txxx-xAA0 and Article No. 6SL3330-7Txxx-xAA3 in parallel.

It is not possible to connect Active Line Modules with Article No. 6SL3330-7Txxx-xAA3 and Article No. 6SL3330-7Txxx-xAA6 in parallel.

5.4.2 Safety information

MARNING

Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



DANGER

Electric shock due to a high DC link voltage

As long as the Line Module is connected to the line supply, the DC link is charged with a high voltage. Contact with components can result in death or serious injury.

 Disconnect and isolate the Line Module from the line supply when carrying out installation and maintenance work.



/ WARNING

Electric shock or fire due to overcurrent protective devices that trip too late

Overcurrent protective devices that do not trip or trip too late can cause an electric shock or fire.

• To protect personnel and for fire protection purposes, at the infeed point, the short-circuit rating and loop impedance must correspond to the specifications in the documentation in order for the installed overcurrent protection devices to trip within the specified time.



MWARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.

MARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in more downtimes and reduced service lives of Line Modules.

• Observe the ventilation clearances above, below and in front of the Line Modules, which are specified in the dimension drawings.

♠ CAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.

NOTICE

Material damage caused by the failure to remove linkage levers for devices of frame sizes HX and JX

The failure to remove linkage levers from devices of frame sizes HX and JX can cause damage to the device as a result of undershooting the necessary voltage clearances.

For devices of frame sizes HX and JX, remove the linkage levers marked in red once the
devices have been installed.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

Note

Operation on line supplies where energy recovery is not possible

In line supply systems without energy recovery capability (e.g. a diesel generator), device faults can occur as the braking energy cannot be dissipated.

- For line supplies without regenerative feedback capability (e.g. diesel generator), deactivate the regenerative feedback capability of the Line Modules using the appropriate parameter (see SINAMICS S120/S150 List Manual).
- The braking energy must then be dissipated via an additional Braking Module with braking resistor in the drive line-up.

5.4.3 Interface description

5.4.3.1 Overview




Figure 5-30 Active Line Module, frame size FX




Figure 5-31 Active Line Module, frame size GX




Figure 5-32 Active Line Module, frame size HX




Figure 5-33 Active Line Module, frame size JX

5.4.3.2 Connection example




Figure 5-34 Active Line Module wiring diagram

5.4.3.3 Line/load connection

Table 5- 31 Line/load connection of the Active Line Module

Terminals	Technical specifications				
U1, V1, W1	Voltage:				
3 AC power input	• 3 AC 380 V -10 % (-15 % < 1 min) 3 AC 480 V +10 %				
	• 3 AC 500 V -10 % (-15 % < 1 min) 3 AC 690 V +10 %				
	Frequency: 47 63 Hz				
	Connecting thread:				
	• Frame sizes FX / GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
DCPA, DCNA	Voltage:				
Connection for Braking Module	• 570 720 V DC				
Module	• 750 1035 V DC				
	Connections:				
	• Frame sizes FX / GX: Threaded bolts M6 / 6 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	Frame sizes HX / JX: Connection for connection clip				
DCP, DCN	Voltage:				
DC power output	• 570 720 V DC				
	• 750 1035 V DC				
	Connections:				
	Frame sizes FX / GX: Thread M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: d = 12 mm (M10 / 25 Nm) flat connector for busbar connection				
PE connection	Connecting thread:				
PE1, PE2	• Frame sizes FX / GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				

^{1)} Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

5.4.3.4 X9 terminal strip

Table 5-32 Terminal strip X9

	Terminal	Signal name	Technical specifications
	1	P24V	External 24 V DC supply
5	2	М	Voltage: 24 VDC (20.4 28.8 V) Current consumption: max. 1.7 A
	3	Bypass contactor control	for Active Interface Module, X609:11
	4		for Active Interface Module, X609:12
	5	Pre-charge contactor con-	for Active Interface Module, X609:9
[∥ ⊕]	6	trol	for Active Interface Module, X609:10
	L1	Connection for fan supply	380 480 VAC / 500 690 VAC
	L2	(frame sizes HX and JX only)	Current consumption: See Technical data

Max. connectable cross-section:

Note

Connecting fan supply, with frame sizes FX and GX

The fan supply for frame sizes FX and GX is connected directly to fuse holders -F10 and -F11.

5.4.3.5 X41 EP terminal / temperature sensor connection

Table 5- 33 Terminal strip X41

Connector	Terminal	Function	Technical specifications			
0000	1	EP M1 (Enable Pulses)	Supply voltage: 24 VDC (20.4 28.8 V)			
	2	EP +24 V (Enable Pulses)	Current consumption: 10 mA			
0000	3	- Temp	Temperature sensor connection KTY84-			
	4	+ Temp	1C130 / PT1000 / PTC			
Max. connecta	Max. connectable cross-section: 1.5 mm ²					





Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

⁻ terminal 1 ... 6: 2.5 mm²

⁻ terminals L1, L2: 35 mm²

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to motor in the event of incorrectly connected KTY temperature sensor

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

Connect a KTY temperature sensor with the correct polarity.

NOTICE

Looping the circuit breaker into the EP terminal circuit for infeed units capable of energy recovery

If the upstream circuit breakers are not controlled from the SINAMICS drive group in the case of infeed units capable of energy recovery, then this can have a damaging reaction on the section that has been shut down when the circuit breaker is opened. As a consequence, under certain circumstances, the components connected in the line supply section involved could be damaged as a result of overvoltage.

If, for infeed units capable of energy recovery, the upstream circuit breaker is not
controlled from the SINAMICS drive group, then an auxiliary contact of the circuit breaker
should be looped into the circuit associated with the EP terminals.

Note

The temperature sensor connection can be used for motors that are equipped with a KTY84-1C130, PT1000 or PTC measuring sensor in the stator windings.

Note

Connection to terminals 1 and 2

For operation, 24 VDC must be connected to terminal 2 and ground to terminal 1. Pulse suppression is activated when removed.

5.4.3.6 X42 terminal strip

Table 5- 34 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications
© □1 b	1	P24L	Voltage supply for Control Unit, Sensor Module and
Q [2]2	2		Terminal Module (18 to 28.8 V) maximum load current: 3 A
	3	M	maximum load current: 3 A
0412	4		
Max. connecta	hle cross-sect	ion: 2.5 mm ²	

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

5.4.3.7 DRIVE-CLiQ interfaces X400, X401, X402

Table 5- 35 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications	
	1	TXP	Transmit data +	
	2	TXN	Transmit data -	
	3	RXP	Receive data +	
	4	Reserved, do not use		
	5	Reserved, do not use		
	6	RXN	Receive data -	
	7	Reserved, do not use		
	8	Reserved, do not use		
	Α	+ (24 V)	24 V power supply	
	В	M (0 V)	Electronics ground	
Blanking plate for DRIVE-CLiQ interfaces (50 pcs.) Article number: 6SL3066-4CA00-0AA0				

5.4.3.8 Meaning of the LEDs on the Control Interface Module in the Active Line Module

Table 5-36 Meaning of the LEDs "READY" and "DC LINK" on the Control Interface Module in the Active Line Module

LED state		Description	
READY	DC LINK		
Off	Off	The electronics power supply is missing or out of tolerance.	
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.	
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.	
	Red	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.	
Orange	Orange	DRIVE-CLiQ communication is being established.	
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.	
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.	
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.	
Flashing light 2 Hz: green/orange or red/orange	Note:		

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 5- 37 Meaning of the LED "POWER OK" on the Control Interface Module in the Active Line Module

LED	Color	Status	Description
POWER OK	Green	Off	DC link voltage or control voltage at -X9 too low.
On The component is ready for operation		The component is ready for operation.	
		Flashing light	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



/ WARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

5.4.4 Dimension drawing

Dimension drawing, frame size FX




Figure 5-35 Dimension drawing Active Line Module, frame size FX Front view, side view

Dimension drawing, frame size GX




Figure 5-36 Dimension drawing Active Line Module, frame size GX Front view, side view

Dimension drawing, frame size HX




Figure 5-37 Dimension drawing Active Line Module, frame size HX Side view, rear view

Dimension drawing, frame size JX




Figure 5-38 Dimension drawing Active Line Module, frame size JX Side view, rear view

5.4.5 Electrical connection

Adjusting the fan voltage (-T10)


The power supply for the device fans (1 AC 230 V) in the Active Line Module (-T10) is taken from the main line supply using transformers. The locations of the transformers are indicated in the interface descriptions.

The transformers are fitted with primary taps so that they can be fine-tuned to the line supply voltage.

If necessary, the connection fitted in the factory, shown with a dashed line, must be reconnected to the actual line voltage.

Note

Active Line Modules, frame size JX, have two integrated transformers (-T10 and -T20). The two primary-side terminals on each of these devices must be adjusted together.






Figure 5-39 Setting terminals for the fan transformers (3 AC 380 ... 480 V / 3 AC 500 ... 690 V)

The supply voltage assignments for making the appropriate setting on the fan transformer are indicated in the following tables (factory presetting: 480 V / 0 V or 690 V / 0 V).

Note

With the 3 AC 500 to 690 V fan transformer, a jumper is inserted between the "600 V" terminal and "CON" terminal. The jumper between terminal "600 V" and "CON" is for internal use.



Fire due to overheating resulting from insufficient equipment fan voltage

If the terminals are not reconnected to the actual line voltage, overheating and human danger due to smoke and fire may result.

This can also cause the fan fuses to blow due to overload.

• Set the terminals in accordance with the actual line voltage.

Table 5- 38 Line voltage assignment for the setting at the fan transformer (3 AC 380 ... 480 V)

Line voltage	Tap at the fan transformer (-T10)
380 V ± 10%	380 V
400 V ± 10%	400 V
440 V ± 10%	440 V
480 V ± 10%	480 V

Table 5- 39 Line voltage assignment for the setting at the fan transformer (3 AC 500 ... 690 V)

Line voltage	Tap at the fan transformer (-T10)
500 V ± 10%	500 V
525 V ± 10%	525 V
575 V ± 10%	575 V
600 V ± 10%	600 V
660 V ± 10%	660 V
690 V ± 10%	690 V

5.4.6 Technical data

5.4.6.1 Active Line Modules, 380 ... 480 V 3 AC

Table 5-40 Technical data for Active Line Modules, 3 AC 380 ... 480 V, Part 1

Article number	6SL3330-	7TE32-1AA3	7TE32-6AA3	7TE33-8AA3	7TE35-0AA3
Rated power - For In_Dc (50 Hz, 400 V) - For Ih_Dc (50 Hz, 400 V) - For In_Dc (60 Hz, 460 V) - For Ih_Dc (60 Hz, 460 V)	kW	132	160	235	300
	kW	115	145	210	270
	HP	200	250	400	500
	HP	150	200	300	400
DC link current - Rated current In_DC - Base-load current IH_DC - Maximum current Imax_DC	A	235	291	425	549
	A	209	259	378	489
	A	352	436	637	823
Infeed/regenerative feedback current - Rated current In_E - Maximum current Imax_E	A	210	260	380	490
	A	315	390	570	735
Supply voltages - Line voltage - Line frequency - Electronics power supply - DC link voltage	VACrms Hz VDC VDC	3 AC 380 -10 % (-15 % < 1 min) 3 AC 480 +10 % 47 63Hz 24 (20.4 28.8) 1.5 x Uline		80 +10 %	
Pulse frequency	kHz	4	4	4	4
Current consumption - Electronics current consumption (24 V DC) - Total fan current consumption (at 400 V AC)	A	1.1	1.1	1.35	1.35
	A	0.63	1.13	1.8	1.8

Article number	6SL3330-	7TE32-1AA3	7TE32-6AA3	7TE33-8AA3	7TE35-0AA3
Max. ambient temperature - Without derating - With derating	°C °C	40 55	40 55	40 55	40 55
DC link capacitance - Active Line Module - Drive line-up, max.	μF μF	4200 41600	5200 41600	7800 76800	9600 76800
Power loss ¹⁾ - At 50 Hz 400 V - At 60 Hz 460 V	kW kW	2.2 2.3	2.7 2.9	3.9 4.2	4.8 5.1
Cooling air requirement	m³/s	0.17	0.23	0.36	0.36
Sound pressure level ²⁾ L _{pA} (1 m) at 50/60 Hz	dB(A)	64 / 67	71 / 71	69 / 73	69 / 73
Line/load connection				tor for screw	Table
		M10	M10	M10	M10
Max. connection cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection PE1 - PE connection PE2	mm² mm² mm² mm²	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 240 2 x 240 2 x 240 2 x 240	2 x 240 2 x 240 2 x 240 2 x 240
Max. cable length ^{3) 4)} (total of all motor cables and DC link) - Shielded - Unshielded	m m	2700 4050	2700 4050	2700 4050	2700 4050
Degree of protection		IP20	IP20	IP20	IP20
Dimensions - Width - Height - Depth	mm mm mm	326 1400 356	326 1400 356	326 1533 545	326 1533 545
Frame size		FX	FX	GX	GX
Weight	kg	95	95	136	136
Recommended fuse 5) 6) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1230-2 1 315 2	3NE1331-2 1 350 2	3NE1334-2 1 500 3	3NE1436-2 1 630 3
Minimum short-circuit current 7)	kA	6.2	10.5	10.5	8

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- 2) Total sound pressure level of Active Interface Module and Active Line Module.
- The cable lengths are valid for use in the IT supply system. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- When used in the TN system and when operating the connected Motor Modules with increased pulse frequency, you will receive the permitted cable lengths upon request.
- 5) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) Minimum current required for reliable triggering of the designated protective devices.

Table 5- 41 Technical data for Active Line Modules, 3 AC 380 ... 480 V, Part 2

Article number	6SL3330-	7TE36-1AA3	7TE37-5AA3	7TE38-4AA3	7TE41-0AA3
Rated power					
- For In_DC (50 Hz, 400 V)	kW	380	450	500	630
- For IH_DC (50 Hz, 400 V)	kW	335	400	465	545
- For In_DC (60 Hz, 460 V)	HP	600	600	700	900
- For Ін_Dc (60 Hz, 460 V)	HP	500	600	700	800
DC link current					
- Rated current In_DC	Α	678	835	940	1103
- Base-load current Ін_рс	Α	603	700	837	982
- Maximum current I _{max_DC}	А	1017	1252	1410	1654
Infeed/regenerative feedback current					
- Rated current In_E	Α	605	745	840	985
- Maximum current Imax_E	Α	907	1117	1260	1477
Supply voltages					
- Line voltage	VACrms	3 AC 380	0 -10 % (-15 % <	1 min) 3 AC 48	80 +10 %
- Line frequency	Hz		47	63Hz	
- Electronics power supply	V DC			28.8)	
- DC link voltage	VDC			Uline	
Pulse frequency	kHz	2.5	2.5	2.5	2.5
Current consumption					
- Electronics current consumption (24 V DC)	Α	1.4	1.4	1.4	1.5
- Total fan current consumption (at	Α	3.6	3.6	3.6	5.4
400 V AC)					
Max. ambient temperature					
- Without derating	°C	40	40	40	40
- With derating	°C	55	55	55	55
DC link capacitance					
- Active Line Module	μF	12600	15600	16800	18900
- Drive line-up, max.	μF	134400	134400	134400	230400
Power loss 1)					
- At 50 Hz 400 V	kW	6.2	7.3	7.7	10.1
- At 60 Hz 460 V	kW	6.6	7.7	8.2	10.8
Cooling air requirement	m³/s	0.78	0.78	0.78	1.08
Sound pressure level 2)					
L _{pA} (1 m) at 50/60 Hz	dB(A)	70 / 73	70 / 73	70 / 73	71 / 73
Line/load connection			Flat connec	tor for screw	
		M12	M12	M12	M12
Max. connection cross-sections					
- Line connection (U1, V1, W1)	mm²	4 x 240	4 x 240	4 x 240	6 x 240
- DC link connection (DCP, DCN)	mm²	Busbar	Busbar	Busbar	Busbar
- PE connection PE1	mm²	1 x 240	1 x 240	1 x 240	1 x 240
- PE connection PE2	mm²	2 x 240	2 x 240	2 x 240	3 x 240
Max. cable length ^{3) 4)}		-			-
(total of all motor cables and DC link)					
- Shielded	m	3900	3900	3900	3900
- Unshielded	m	5850	5850	5850	5850
Degree of protection		IPO0	IPOO	IP00	IP00
Dimensions					
- Width	mm	503	503	503	704
- Height	mm	1475	1475	1475	1480
- Depth	mm	540	540	540	550
Frame size	-	HX	HX	HX	JX
Weight	ka	290	290	290	450
weignt	kg	230	230	270	1420

Article number	6SL3330-	7TE36-1AA3	7TE37-5AA3	7TE38-4AA3	7TE41-0AA3
Recommended fuse 5) 6) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1438-2 1 800 3	3NE1333-2 2 450 2	3NE1334-2 2 500 3	3NE1436-2 2 630 3
Minimum short-circuit current 7)	kA	9.2	8.8	10.4	16

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- 2) Total sound pressure level of Active Interface Module and Active Line Module.
- The cable lengths are valid for use in the IT supply system. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- When used in the TN system and when operating the connected Motor Modules with increased pulse frequency, you will receive the permitted cable lengths upon request.
- ⁵⁾ To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) Minimum current required for reliable triggering of the designated protective devices.

Table 5- 42 Technical data for Active Line Modules, 3 AC 380 V ... 480 V, Part 3

Article number	6SL3330-	7TE41-2AA3	7TE41-4AA3		
Rated power					
- For In DC (50 Hz, 400 V)	kW	800	900		
- For In_dc (50 Hz, 400 V)	kW	690	780		
- For In_DC (60 Hz, 460 V)	HP	1000	1250		
- For In_Dc (60 Hz, 460 V)	HP	900	1000		
DC link current					
- Rated current In_DC	Α	1412	1574		
- Base-load current Ін_рс	Α	1255	1401		
- Maximum current Imax_DC	Α	2120	2361		
Infeed/regenerative feedback current					
- Rated current In_E	Α	1260	1405		
- Maximum current Imax_E	Α	1890	2107		
Supply voltages					
- Line voltage	VACrms	3 AC 38	0 -10 % (-15 % <	1 min) 3 AC 48	30 +10 %
- Line frequency	Hz		47	63Hz	
- Electronics power supply	VDC		24 (20.4	28.8)	
- DC link voltage	VDC		1.5 x	(Uline	
Pulse frequency	kHz	2.5	2.5		
Current consumption					
- Electronics current consumption (24 V DC)	Α	1.7	1.7		
- Total fan current consumption (at	Α	5.4	5.4		
400 V AC)					
Max. ambient temperature					
- Without derating	°C	40	40		
- With derating	°C	55	55		
DC link capacitance					
- Active Line Module	μF	26100	28800		
- Drive line-up, max.	μF	230400	230400		
Power loss 1)					
- At 50 Hz 400 V	kW	12.1	13.3		
- At 60 Hz 460 V	kW	13	14.2		
Cooling air requirement	m³/s	1.08	1.08		
Sound pressure level ²⁾					
L _{pA} (1 m) at 50/60 Hz	dB(A)	71 / 73	71 / 73		
Line/load connection			Flat connect	tor for screw	
		M12	M12		
May connection cross sections		.VI 12	.VI I Z		
Max. connection cross-sections	mm²	6 y 240	6 x 240		
- Line connection (U1, V1, W1)	mm² mm²	6 x 240			
- DC link connection (DCP, DCN)		Busbar	Busbar		
- PE connection PE1 - PE connection PE2	mm² mm²	1 x 240 3 x 240	1 x 240 3 x 240		
	111111	3 X Z4U	3 X Z4U		
Max. cable length 3) 4)					
(total of all motor cables and DC link)		2000	2000		
- Shielded - Unshielded	m	3900 5850	3900 5850		
	m		1		
Degree of protection		IP00	IP00		
Dimensions		704	704		
- Width	mm	704	704		
- Height	mm	1480	1480		
- Depth	mm	550	550		
Frame size		JX	JX		
Weight	kg	450	450		

Article number	6SL3330-	7TE41-2AA3	7TE41-4AA3	
Recommended fuse 5) 6) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1448-2 2 850 3	3NE1448-2 2 850 3	
Minimum short-circuit current 7)	kA	21	21	

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- 2) Total sound pressure level of Active Interface Module and Active Line Module.
- The cable lengths are valid for use in the IT supply system. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- When used in the TN system and when operating the connected Motor Modules with increased pulse frequency, you will receive the permitted cable lengths upon request.
- ⁵⁾ To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) Minimum current required for reliable triggering of the designated protective devices.

5.4.6.2 Active Line Modules, 500 ... 690 V 3 AC

Table 5- 43 Technical data for Active Line Modules, 3 AC 500 V ... 690 V

Article number	6SL3330-	7TG35-8AA3	7TG37-4AA3	7TG41-0AA3	7TG41-3AA3
Rated power					
- For In_DC (50 Hz, 690 V)	kW	630	800	1100	1400
- For Iн_Dc (50 Hz, 690 V)	kW	620	705	980	1215
- For In_DC (50 Hz, 500 V)	kW	447	560	780	965
- For Iн_Dc (50 Hz, 500 V)	kW	450	510	710	880
- For In_DC (60 Hz, 575 V)	HP	675	900	1250	1500
- For IH_DC (60 Hz, 575 V)	HP	506	600	1000	1250
DC link current					
- Rated current In_DC	Α	644	823	1148	1422
- Base-load current Ін_рс	Α	573	732	1022	1266
- Maximum current Imax_DC	А	966	1234	1722	2133
Infeed/regenerative feedback current					
- Rated current In_E	Α	575	735	1025	1270
- Maximum current Imax_E	Α	862	1102	1537	1905
Supply voltages					
- Line voltage	VACrms	3 AC 5	00 -10% (-15% <	1 min) 3 AC 69	90 +10%
- Line frequency	Hz			. 63Hz	
- Electronics power supply	VDC		24 (20.4	4 28.8)	
- DC link voltage	VDC	1.5 x Uline			
Pulse frequency	kHz	2.5	2.5	2.5	2.5
Current consumption					
- Electronics current consumption (24 V DC)	Α	1.4	1.5	1.7	1.7
- 500 V AC	A	3.0	4.4	4.4	4.4
- 690 V AC	Α	2.1	3.1	3.1	3.1
Max. ambient temperature					
- Without derating	°C	40	40	40	40
- With derating	°C	55	55	55	55
DC link capacitance					
- Active Line Module	μF	7400	11100	14400	19200
- Drive line-up, max.	μF	59200	153600	153600	153600
Power loss 1)					
- at 50 Hz 690 V	kW	6.8	10.2	13.6	16.5
- at 60 Hz 575 V	kW	6.2	9.6	12.9	15.3
Cooling air requirement	m³/s	0.78	1.08	1.08	1.08
Sound pressure level ²⁾					
L _{pA} (1 m) at 50/60 Hz	dB(A)	70 / 73	71 / 73	71 / 73	71 / 73
Line/load connection	()		1	tor for screw	1
Line/load confilection		M12	M12		M12
		IVIIZ	IVI I Z	M12	IVI I Z
Max. connection cross-sections	2	4 240	6240	c 240	C 240
- Line connection (U1, V1, W1)	mm² mm²	4 x 240	6 x 240	6 x 240	6 x 240
- DC link connection (DCP, DCN)	mm²	Busbar	Busbar	Busbar	Busbar
- PE connection PE1 - PE connection PE2	mm ²	1 x 240 2 x 240	1 x 240 3 x 240	1 x 240 3 x 240	1 x 240 3 x 240
	1111111	2 X 24U	J X Z4U	J X Z4U	J X Z4U
Max. cable length 3) 4)					
(total of all motor cables and DC link) - Shielded	l m	2250	2250	2250	2250
- Shielded - Unshielded	m	2250 3375	2250 3375	2250 3375	2250 3375
	m				
Degree of protection		IP00	IP00	IP00	IP00

Article number	6SL3330-	7TG35-8AA3	7TG37-4AA3	7TG41-0AA3	7TG41-3AA3
Dimensions - Width - Height - Depth	mm mm mm	503 1475 540	704 1480 550	704 1480 550	704 1480 550
Frame size		HX	JX	JX	JX
Weight	kg	290	450	450	450
Recommended fuse 5) 6) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269		3NE1447-2 1 670 3	3NE1448-2 1 850 3	3NE1436-2 2 630 3	3NE1438-2 2 800 3
Minimum short-circuit current 7)	kA	8.4	10.5	16	20

- 1) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- ²⁾ Total sound pressure level of Active Interface Module and Active Line Module.
- The cable lengths are valid for use in the IT supply system. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- When used in the TN system and when operating the connected Motor Modules with increased pulse frequency, you will receive the permitted cable lengths upon request.
- 5) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- Only 3NE1 fuses should be used to protect the devices. These must be located as close as possible to the converter. The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) Minimum current required for reliable triggering of the designated protective devices.

5.4.6.3 Overload capability

The Active Line Modules have an overload reserve.

The criterion for overload is that the Active Line Module is operated as a maximum with its base load current before and after the overload occurs (a load duration of 300 s is used as a basis here).

High overload

The base load current for a high overload I_{H_DC} is based on a duty cycle of 150% for 60 s; the max. current I_{max_DC} can flow for 5 s.




Figure 5-40 High overload

5.5 Active Line Modules Chassis-2

5.5.1 Description

The self-commutating infeed / regenerative feedback units act as step-up converters and generate a controlled DC link voltage that is 1.5x greater (factory setting) than the rated line voltage. In this way, the connected Motor Modules are isolated from the line voltage. This improves the dynamic response and control quality because line tolerances and fluctuations do not affect the motor voltage.

Active Line Module can be used to implement reactive power compensation by specifying an additive reactive current.



Figure 5-41 Active Line Module Chassis-2, frame size FS4

Active Infeed Module Chassis-2 components

An Active Infeed Chassis-2 comprises an Active Interface Module Chassis-2 and an Active Line Module Chassis-2.

For an Active Infeed Chassis-2 with an Active Line Module Chassis-2, the precharging input circuit (precharging contactor, precharging resistors, main contactor) must be provided separately. The Active Interface Modules Chassis-2 and Active Line Modules Chassis-2 have degree of protection IP00.




Figure 5-42 Active Infeed Chassis-2 overview

The article numbers of the individual components (Active Interface Module Chassis-2 and Active Line Module Chassis-2) are listed in the table below:

Table 5-44 Active Infeed Chassis-2, article numbers of the individual components

Active Infeed Chassis-2	Rated power	Active Interface Module Chassis-2	Active Line Module Chassis-2
6SL3341-7TE35-6AA0	355 kW	6SL3301-7TE36-4AA0	6SL3331-7TE35-6AA0
6SL3341-7TE36-4AA0	400 kW	6SL3301-7TE36-4AA0	6SL3331-7TE36-4AA0
6SL3341-7TE37-5AA0	450 kW	6SL3301-7TE41-0AA0	6SL3331-7TE37-5AA0
6SL3341-7TE38-4AA0	500 kW	6SL3301-7TE41-0AA0	6SL3331-7TE38-4AA0
6SL3341-7TE38-8AA0	560 kW	6SL3301-7TE41-0AA0	6SL3331-7TE38-8AA0
6SL3341-7TE41-0AA0	630 kW	6SL3301-7TE41-0AA0	6SL3331-7TE41-0AA0
6SL3341-7TE41-2AA0	710 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-2AA0
6SL3341-7TE41-3AA0	800 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-3AA0
6SL3341-7TE41-4AA0	900 kW	6SL3301-7TE41-4AA0	6SL3331-7TE41-4AA0

5.5 Active Line Modules Chassis-2

Operating principle

One or more Motor Modules can be connected to the power supply system via the Active Line Module. The Active Line Module provides a constant DC link voltage for the Motor Modules. This ensures that they are not influenced by line voltage fluctuations. The regenerative feedback capability of the Active Line Module can be deactivated by parameterization.

The Active Line Module is suitable for direct operation on TN, IT and TT systems.

When the motors operate as generators, the Active Line Module feeds regenerative power back into the line supply.

The Active Line Module is used for:

- Machines with high dynamic drive requirements
- Frequent braking cycles and high braking energy

Parallel connection of Active Line Modules Chassis-2 to increase power rating

To increase the power, a parallel connection of up to six Active Line Modules Chassis-2 with the same output is possible.

For a parallel connection of Active Line Modules Chassis-2, the following rules must be observed:

- Up to 6 identical Active Line Modules Chassis-2 can be connected in parallel.
- Each Active Line Module Chassis-2 requires its own Active Interface Module Chassis-2.
- Parallel connection can only be implemented using one common Control Unit.
 For more than 4 power units, these must be distributed as symmetrically as possible between at least two DRIVE-CLiQ ports (e.g. 3x 2 Active Line Modules Chassis-2 in series, or a minimum of 2x 3 Active Line Modules Chassis-2 in series).
- For multiple infeeds, power must be supplied to the systems from a common infeed point (i.e. different line supplies are not permitted).
- The Active Line Modules Chassis-2 must supply a shared DC link.
- A derating factor of 5 % must be taken into consideration, regardless of the number of modules connected in parallel.

Note

Different power units cannot be connected in parallel.

It is only possible to connect power units in parallel if all power units have the same hardware version.

It is not possible to connect Active Line Modules (Article No. 6SL3330-7Txxx-xAAx) and Active Line Modules Chassis-2 (Article No. 6SL3331-7Txxx-xAA0) in parallel.

Using Active Line Modules Chassis-2 in line supplies according to standard IEC 61000-2-4, Class 2

When using Active Line Modules Chassis-2 in line supplies in conformance with Standard IEC 61000-2-4, Class 2, the following conditions must be carefully observed:

- Class 2 of IEC 61000-2-4 is complied with for the step-up factor set in the factory (= 1.5) and an Rsc > 20 and a pulse frequency of 4 kHz.
- For a step-up factor ≥1.5, the pulse frequency of Active Line Modules Chassis-2 must be set to 8 kHz.

When used in the TN system and during operation of the Active Line Module Chassis 2 or the connected Motor Module with increased pulse frequency, you will receive the permitted cable lengths upon request.

Note

When complying with the limit values according to standard IEC 61000-2-4, Class 2 and Class 3, the evaluation of the conductor-conductor voltage in a frequency range of <9 kHz is assumed.

Use of the Active Line Modules Chassis-2 in weak grids

When the Active Line Modules Chassis-2 are used in weak grids (Rsc < 20), the band-stop filter must be activated (parameter p5200.0 = 1) to suppress increased line harmonic distortions.

Note

Activation of the band-stop filter

The "Additional control" function module must be activated to enable the band-stop filter. For additional information, see "SINAMICS S120 Function Manual Drive Functions".

After the band-stop filter is activated, no further settings are necessary. It can be operated using the factory parameterization.

When using an Active Line Modules Chassis-2 on strong grids ($R_{SC} > 20$), the band-stop filter should not be activated (parameter p5200.0 = 0) to avoid unfavorable overshoots. For more information, see Low Voltage Engineering Manual.

5.5.2 Safety information

MWARNING

Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



♠ DANGER

Electric shock due to a high DC link voltage

As long as the Line Module is connected to the line supply, the DC link is charged with a high voltage. Contact with components can result in death or serious injury.

• Disconnect and isolate the Line Module from the line supply when carrying out installation and maintenance work.



/ WARNING

Electric shock or fire due to overcurrent protective devices that trip too late

Overcurrent protective devices that do not trip or trip too late can cause an electric shock or fire.

To protect personnel and for fire protection purposes, at the infeed point, the short-circuit rating and loop impedance must correspond to the specifications in the documentation in order for the installed overcurrent protection devices to trip within the specified time.



MARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.



Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in more downtimes and reduced service lives of Line Modules.

• Adhere to the ventilation clearances above and beside the Line Modules that are specified in the dimension drawings.

ACAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.



ACAUTION

Burns resulting from high surface temperatures

Depending on the ambient temperature, the temperature on the enclosure of the device can exceed >60 °C. Contact with the surface can result in severe burns.

• Before starting to work on the device, check the temperature of the enclosure.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

5.5 Active Line Modules Chassis-2

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

• Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

Note

Fan can start automatically

When the power supply is available, the fan can start automatically as a function of the ambient temperature.

Note

Operation on line supplies where energy recovery is not possible

In line supply systems without energy recovery capability (e.g. a diesel generator), device faults can occur as the braking energy cannot be dissipated.

- For line supplies without regenerative feedback capability (e.g. diesel generator), deactivate the regenerative feedback capability of the Line Modules using the appropriate parameter (see SINAMICS S120/S150 List Manual).
- The braking energy must then be dissipated via an additional Braking Module with braking resistor in the drive line-up.

NOTICE

Operation only with firmware V5.2 HF4 or higher.

The Active Line Module Chassis-2 can be damaged if operated with unsuitable firmware.

Only operate the Active Line Module Chassis-2 with a firmware V5.2 HF4 or higher.

5.5.3 Interface description

5.5.3.1 Overview





Figure 5-43 Active Line Module Chassis-2

5.5.3.2 Connection example



① The DC link fuses must be provided on the plant/system side, see Chapter "Technical data (Page 252)".

Figure 5-44 Connection example for Active Line Modules Chassis-2

5.5.3.3 Line/load connection

Table 5- 45 Line/load connection of Active Line Module Chassis-2

Terminals	Technical specifications
U1, V1, W1 3 AC power input	Voltage: • 380 V 3 AC -10% (-15% < 1 min) 480 V 3 AC +10% Frequency: 47 63 Hz Connecting thread: • Frame size FS2, FS2+, FS4, FS4+: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)
DCP, DCN DC power output	 Voltage: 570 720 V DC Connections: Frame size FS2, FS2+, FS4, FS4+: d = 14 mm (M12 / 50 Nm) flat connector for busbar connection When connecting using copper busbars, the same cross-sections should be used as the connecting busbars of the device itself: Frame size FS2: 70 mm x 4 mm Frame size FS2+: 70 mm x 6 mm Frame size FS4, FS4+: 80 mm x 8 mm
PE connection	The DC link must be protected (fused) on the plant/system side. Connecting thread: • Frame size FS2, FS2+, FS4+: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)

¹⁾ Dimensions for connecting alternative cable lugs, see "Cable lugs for devices with Chassis-2 design" in the Annex.

MARNING

Electric shock if unsuitable screws are used for the mains connections

The plastic enclosure behind the mains connections can be damaged if screws longer than 40 mm are used. This represents danger to life, and equipment can be damaged.

- Only use the original M12x40 screws with spring lock washers to connect the line cables.
- If you have to replace screws, then only use screws with the same length. Always use a spring washer.

5.5.3.4 X51 connection, fan power supply

Table 5- 46 Terminal strip X51, fan power supply connection

Connector	Terminal	Function	Technical specifications
	L1	L1	Supply voltage: 3 AC 380 V 480 V
L1 L2 L3 PE	L2	L2	Frequency: 47 63 Hz
	L3	L3	Max. load current: 1.8 A
	PE	PE	Connection is connected to the fan housing.
Max. connectable cross-section: 6.0 mm ²			

A 3-pole 16 A miniature circuit breaker, with a tripping characteristic Class C is recommended to protect the fan power supply.

Note

After installation, screw on the connector.

Note

Connect the PE connection with the PE connection of the electrical cabinet.

Note

For installation altitudes exceeding 2000 m, an isolating transformer must be connected upstream of the fan power supply.

NOTICE

Damage to the fan when pulling the connector under load

The fan can become damaged if the connector is pulled under load (while the fan is rotating).

Do not pull the connector under load.

5.5.3.5 X9 terminal strip

Table 5- 47 Terminal strip X9

Connector	Terminal	Signal name	Technical specifications	
	VL1	Pre-charge contactor control	240 V AC: 8 A max. 24 VDC: max. 1 A	
	VL2		isolated relay contact	
	NC	NC	Reserved, do not use	
	HS1	Main contactor	240 V AC: 8 A max.	
	HS2	control	24 VDC: max. 1 A isolated relay contact	
	P24V	P24V	External 24 V DC supply	
	M		Voltage: 24 V DC (20.4 28.8 V)	
	IVI	M	Current consumption: max. 1.6 Å	
Max. connectable cross-section: 2.5 mm ²				

5.5.3.6 X41 EP terminal / temperature sensor connection

Table 5-48 Terminal strip X41

Connector	Terminal	Function	Technical specifications
	1 EP +24 V (enable pulses)		Supply voltage: 24 VDC (20.4 28.8 V) Current consumption: 10 mA
	2	EP M1 (enable pulses)	
	3	+Temp	Temperature sensor connection: KTY84-
	4	-Temp	1C130/Pt1000/PTC
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

At terminals 1 and 2, the terminal strip has a yellow marking, it is coded at terminal 4; please use the corresponding connector from the accessory pack.



WARNING

Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to the motor in the event of incorrectly connected KTY temperature sensor at terminals X41:3,4

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

Connect a KTY temperature sensor with the correct polarity.

NOTICE

Looping the circuit breaker into the EP terminal circuit for infeed units capable of energy recovery

If the upstream circuit breakers are not controlled from the SINAMICS drive group in the case of infeed units capable of energy recovery, then this can have a damaging reaction on the section that has been shut down when the circuit breaker is opened. As a consequence, under certain circumstances, the components connected in the line supply section involved could be damaged as a result of overvoltage.

• If, for infeed units capable of energy recovery, the upstream circuit breaker is not controlled from the SINAMICS drive group, then an auxiliary contact of the circuit breaker should be looped into the circuit associated with the EP terminals.

Note

The temperature sensor connection at terminals X41:3,4 can be used for motors that are equipped with a KTY84-1C130, Pt1000 or PTC measuring sensor in the stator windings.

Note

Connection to terminals 1 and 2

For operation, 24 V DC must be connected to terminal 1 and ground to terminal 2. Pulse inhibit is activated when withdrawn.

5.5.3.7 X42 terminal strip

Table 5-49 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications
	1	P24L	Power supply for Control Unit, Sensor Module
	2		and Terminal Module (18 28.8 V) maximum load current: 3 A
	3	M	maximum load current. 3 A
	4		
Max. connectable cross-section: 2.5 mm ²			

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

5.5.3.8 X46 terminal strip

Table 5- 50 Terminal strip X46

Connector	Terminal	Function	Technical specifications
	1	NC	Reserved, do not use
	2	NC	Reserved, do not use
	3	NC	Reserved, do not use
	4	NC	Reserved, do not use
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 1; please use the corresponding connector from the accessory pack.

Note

The interface is provided with the Motor Module for connecting the Safe Brake Adapter.

5.5.3.9 X47 contactor feedback signal

Table 5- 51 Terminal strip X47, contactor feedback signal

Connector	Terminal	Signal name	Technical specifications
	1	VL_R	Precharging contactor feedback signal
	2	М	Supply voltage: 24 V DC Max. Load current: 10 mA
	3	HS_R	Main contactor feedback signal
	4	М	Supply voltage: 24 V DC Max. Load current: 10 mA
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 3; please use the corresponding connector from the accessory pack.

The monitoring of the precharging and main contactors of the Active Line Module Chassis-2 is activated in the factory settings.

Fault messages

- F30060 (A) Condition monitoring for the precharging contactor
- F30061 (A): Condition monitoring for the main contactor

5.5.3.10 X49 terminal block

Table 5- 52 Terminal strip X49

Connector	Terminal	Function	Technical specifications
	1	LAMPPWR	Supply voltage: 24 V DC
	2	М	Max. Load current: 100 mA
			If the power unit has a fault condition, then voltage is available at the terminals.
	3	NC	Reserved, do not use
	4	NC	Reserved, do not use
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 6; please use the corresponding connector from the accessory pack.

Note

Function of the "LAMPPWR" signal

By connecting a signal lamp, the "LAMPPWR" terminal can be used in large cabinet groups for signaling the power unit in which a problem exists. Once there is a fault in the respective power supply unit, a voltage of 24 V DC is output at the output.

Note: During a firmware update, the output alternates between 0 V and 24 V.

5.5.3.11 DRIVE-CLiQ interfaces X400, X401, X402

Table 5-53 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications
₽₽B	1	TXP	Transmit data +
	2	TXN	Transmit data -
¹█₽₹	3	RXP	Receive data +
	4	Reserved, do not use	
	5	Reserved, do not use	
	6	RXN	Receive data -
	7	Reserved, do not use	
	8	Reserved, do not use	
	Α	+ (24 V) 24 V power supply	
	B M (0 V) Electronics ground		
Blanking plate	for DRIVE	-CLiQ interfaces (50 pcs.) Article n	umber: 6SL3066-4CA00-0AA0

5.5.3.12 Test points for 1 mm test probes

On the connectors X41, X46, X47 and X49 you will find test points for 1 mm test probes on the sides, see ① in the following figure.




Figure 5-45 Test points for 1 mm test probes

5.5.3.13 Meaning of the LEDs on the Active Line Module

Table 5- 54 Significance of the "READY" and "DC LINK" LEDs on the Active Line Module Chassis-2

LED state		Description		
READY	DC LINK			
Off	Off	The electronics power supply is missing or out of tolerance.		
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.		
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.		
Red The component is ready for operation and cyclic DRIVE-CLiQ place.		The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.		
Orange	Orange	DRIVE-CLiQ communication is being established.		
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.		
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.		
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.		
Flashing light 2 Hz: green/orange or red/orange	1)	Detection of the components via LED is activated (p0124). Note: Both options depend on the LED status when module recognition is activated via $p0124 = 1$.		

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 5- 55 Meaning of the "PWR ON" LED on the Active Line Module Chassis-2

LED	Color	Status	Description
PWR ON	Green	Off	DC link voltage or supply voltage at -X9 too low.
		On	The component is ready for operation.
	Red	Flashing light	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



MARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

5.5.4 Dimension drawing

Dimension drawing, frame size FS2

The mandatory cooling clearances are indicated by the dotted line.




Figure 5-46 Dimension drawing, Active Line Module Chassis-2, frame size FS2. Side view, front view

Dimension drawing, frame size FS2+

The mandatory cooling clearances are indicated by the dotted line.




Figure 5-47 Dimension drawing, Active Line Module Chassis-2, frame size FS2+. Side view, front view

Dimension drawing, frame size FS4, FS4+

The mandatory cooling clearances are indicated by the dotted line.




Figure 5-48 Dimension drawing, Active Line Module Chassis-2, frame size FS4, FS4+. Side view, front view

5.5.5 Installation

The Active Line Module Chassis-2 is secured using two M10 bolts on the top of the device, which are screwed onto the rear mounting panel of the control cabinet.

Then the Active Line Module Chassis-2 is fastened to the mounting surface of the control cabinet using a mounting bracket.



When installing the device without using a suitable mounting aid, the device may be damaged or cause injury.

When installing the Active Line Module in a control cabinet without using a suitable mounting aid, the Active Line Module may be damaged or cause injury.

• When installing the Active Line Module in a control cabinet, use a suitable mounting aid so that the device can be horizontally rolled into the control cabinet.

CAUTION

Injury or damage to the device if it topples or rolls away.


During installation, the Active Line Module can topple over or roll away. This can result in injuries or damage to the device.


• Secure the Active Line Module so that it cannot topple over or roll away.

Mounting dimensions in the control cabinet

Refer to the following diagrams for the mounting dimensions when installing the Active Line Module Chassis-2 in a control cabinet.

Front view of the control cabinet






- ① Side panel of the control cabinet
- ② Support surface for the Active Line Module

Note

Tolerances for holes tapped in the rear mounting panel

If the specified tolerances for the threaded holes of the rear mounting panel of the control cabinet cannot be adhered to, then compensating fastening elements should be used to facilitate screwing in the Active Line Module.

Top view of the control cabinet mounting surface



- ① Side panel of the control cabinet
- ② Rear mounting panel

Figure 5-49 Installation top view

Attaching the mounting bracket

First, fasten the mounting bracket to the mounting surface of the control cabinet (1), then to the fastening points on the Active Line Module (2).

When mounting, ensure that no additional pressure is applied to the rollers of the Active Line Module by observing the positions of the elongated holes (11 mm x 15 mm).

Tighten the M10 screws to a torque of 50 Nm.




Figure 5-50 Attaching the mounting bracket (diagram showing an example)

5.5.6 Electrical connection

Attaching the PE connections

The 3 PE connections must be attached before installing the Active Line Module. The connecting busbars are included in the accessory pack.

Secure each PE connection with 2 screws on the Active Line Module, torque 25 Nm.




Figure 5-51 Attaching the PE connections

Attaching the PE connections

The shielding connections are used to connect the cable shields of the shielded signal cables on the Active Line Module.

Attach the support plate for the shield connections at the intended position. You can break off individual parts from the 6-part support plate corresponding to your specific requirements, torque 3 Nm.






Figure 5-52 Attaching the PE connections

In the delivery kit of the Active Line Module, there are 3 shield clamps for cable diameters 3 ...6 mm and 6 ...8 mm.

Use the respective shielding clamps corresponding to the cables to be shielded.



Attach shield clip



Snap in shield clip




Figure 5-53 Installed signal cable with strain relief and shielding

5.5.7 Technical data

5.5.7.1 Active Line Modules Chassis-2, 380 ... 480 V 3 AC

Table 5- 56 Technical data for Active Line Modules Chassis-2, 3 AC 380 ... 480 V, Part 1

Article number	6SL3331-	7TE35-6AA0	7TE36-4AA0	7TE37-5AA0	7TE38-4AA0
Rated power - For In_DC (50 Hz, 400 V) - For IL_DC (50 Hz, 400 V) - For In_DC (60 Hz, 460 V) - For IL_DC (60 Hz, 460 V)	kW kW HP HP	355 300 500 400	400 350 550 500	450 400 650 550	500 450 700 650
DC link current - Rated current In_DC - Base-load current IL_DC - Maximum current Imax_DC	A A A	630 571 857	710 649 974	835 760 1140	940 854 1281
Infeed/regenerative feedback current - Rated current In_E - Maximum current Imax_E	A A	560 773	635 878	745 1028	840 1155
Supply voltages - Line voltage - Line frequency - Electronics power supply - DC link voltage	VACrms Hz VDC VDC	3 AC 380 -10 % (-15 % < 1 min) 3 AC 480 +1 47 63Hz 24 (20.4 28.8) 1.5 x Uline		80 +10 %	
Pulse frequency 1)	kHz	4	4	4	4
Current consumption - Electronics current consumption (24 V DC) - Total fan current consumption (at 400 V AC)	A A	1.3 1.8	1.3 1.8	1.3 1.8	1.3 1.8
Max. ambient temperature - Without derating - With derating	°C	45 60	45 60	45 60	45 60
DC link capacitance - Active Line Module - Drive line-up, max at 400 V / 50 Hz ²⁾ - at 480 V / 60 Hz ²⁾	μF μF μF	16450 130000/400000/not permissi- ble 95000/250000/not permissi-		18800 130000/400000/not permiss ble 95000/250000/not permissi	
Power loss ³⁾ - At 50 Hz 400 V - At 60 Hz 460 V	kW kW	4.47 4.48	4.47 4.48	5.89 5.90	6.79 6.80
Cooling air requirement	m³/s	0.64	0.64	0.64	0.64
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5	72.5	72.5	72.5
Connections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection		4 x M12 2 x M12 4 x M12	4 x M12 2 x M12 4 x M12	4 x M12 2 x M12 4 x M12	4 x M12 2 x M12 4 x M12
Max. conductor cross-sections - Line connection (U1, V1, W1) - DC link connection (DCP, DCN) - PE connection	mm² mm² mm²	4 x 240 busbar 4 x 240	4 x 240 busbar 4 x 240	4 x 240 busbar 4 x 240	4 x 240 busbar 4 x 240

Article number	6SL3331-	7TE35-6AA0	7TE36-4AA0	7TE37-5AA0	7TE38-4AA0
Max. cable length ^{4) 5)} (total of all motor cables and DC link)					
- Shielded	m	3900	3900	3900	3900
- Unshielded	m	5850	5850	5850	5850
Degree of protection		IP00	IP00	IP00	IP00
Dimensions					
- Width	mm	280	280	280	280
- Height	mm	1248	1248	1248	1248
- Depth	mm	542	542	542	542
Frame size		FS2	FS2	FS2+	FS2+
Weight	kg	119	119	122	122
Recommended AC fuse acc. to IEC ⁶⁾ - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE1438-2 1 800 3	3NE1438-2 1 800 3	3NE1333-2 2 ⁹⁾ 450 2	3NE1334-2 2 ⁹⁾ 500 2
Recommended DC fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE3333 2 ⁹⁾ 450 2	3NE3334-0B 2 ⁹⁾ 500 2	3NE3335 2 ⁹⁾ 560 2	3NE3336 2 9) 630 2
Recommended AC fuse according to UL 6) 7) - Rated current	Α	3NE1438-2 800	3NE1438-2 800	3NB3350- 1KK26 1000	3NB3350- 1KK26 1000
Recommended DC fuse according to UL 7) Type 3NB1/3NB2		3NB2350- 4KK16	3NB2350- 4KK16	3NB2355- 4KK16	3NB2355- 4KK16
- Rated current	A	1000	1000	1400	1400
Minimum short-circuit current 8)	kA	18	18	14	16

- 1) Derating for higher pulse frequencies on request.
- The maximum DC link capacitances of the drive line-up are specified as a function of the number of precharging resistors (2.2 Ω) connected in parallel per phase: 1 precharging resistor/2 precharging resistors/3 precharging resistors.
- 3) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- The cable lengths are valid for use in IT supply systems. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- When used in TN systems and during operation of the Active Line Module Chassis-2 or the connected Motor Module with increased pulse frequency, you can obtain the permitted cable lengths on request.
- 6) Only 3NE1 or 3NB3 fuses should be used to protect the devices. These must be located as close as possible to the converter.
 - The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- 8) Minimum current required for reliable triggering of the protective devices.
- 9) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.

5.5 Active Line Modules Chassis-2

Table 5- 57 Technical data for Active Line Modules Chassis-2, 3 AC 380 ... 480 V, Part 2

Article number	6SL3331-	7TE38-8AA0	7TE41-0AA0	7TE41-2AA0
Rated power				
- For In_DC (50 Hz, 400 V)	kW	560	630	710
- For IL_DC (50 Hz, 400 V)	kW	500	560	630
- For In_DC (60 Hz, 460 V)	HP	800	900	1050
- For IL_DC (60 Hz, 460 V)	HP	700	800	900
DC link current				
- Rated current In_DC	Α	1010	1100	1245
- Base-load current IL_DC	Α	915	1004	1131
- Maximum current I _{max_DC}	Α	1373	1506	1697
Infeed/regenerative feedback current				
- Rated current In_E	Α	900	985	1110
- Maximum current I _{max_E}	Α	1238	1358	1530
Supply voltages				
- Line voltage	VACrms	3 AC 380) -10 % (-15 % <	1 min) 3 AC 480 +10 %
- Line frequency	Hz			63Hz
- Electronics power supply	V DC			28.8)
- DC link voltage	VDC		1.5 >	(Uline
Pulse frequency 1)	kHz	4	4	4
Current consumption				
- Electronics current consumption (24 V DC)	Α	1.3	1.3	1.3
- Total fan current consumption (at 400 V AC)	Α	1.8	1.8	1.8
Max. ambient temperature				
- Without derating	°C	45	45	45
- With derating	°C	60	60	60
DC link capacitance				
- Active Line Module	μF		259	900
- Drive line-up, max.				
- at 400 V / 50 Hz ²⁾	μF			000/630000
- at 480 V / 60 Hz ²⁾	μF		95000/250	000/450000
Power loss 3)				
- At 50 Hz 400 V	kW	7.13	7.86	9.43
- At 60 Hz 460 V	kW	7.14	7.87	9.44
Cooling air requirement	m³/s	0.64	0.64	0.64
Sound pressure level				
L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5	72.5	72.5
Connections				
- Line connection (U1, V1, W1)		6 x M12	6 x M12	6 x M12
- DC link connection (DCP, DCN)		4 x M12	4 x M12	4 x M12
- PE connection		6 x M12	6 x M12	6 x M12
Max. conductor cross-sections	2	6 246	6 246	6 340
- Line connection (U1, V1, W1)	mm²	6 x 240	6 x 240	6 x 240
- DC link connection (DCP, DCN)	mm²	Busbar	Busbar	Busbar
- PE connection	mm²	6 x 240	6 x 240	6 x 240
Max. cable length 4) 5)				
(total of all motor cables and DC link)		2000	2000	2000
- Shielded	m	3900	3900	3900
- Unshielded	m	5850	5850	5850
Degree of protection		IPOO	IP00	IPOO
Dimensions		200	200	200
- Width	mm	280	280	280
- Height	mm	1491	1491	1491
- Depth	mm	542	542	542
Frame size		FS4	FS4	FS4
Weight	kg	162	162	162

Article number	6SL3331-	7TE38-8AA0	7TE41-0AA0	7TE41-2AA0
Recommended AC fuse acc. to IEC ⁶⁾ - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE1435-2 2 ⁹⁾ 560 3	3NE1436-2 2 ⁹⁾ 630 3	3NE1448-2 2 ⁹⁾ 850 3
Recommended DC fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE3337-8 2 ⁹⁾ 710 2	3NE3338-8 2 ⁹⁾ 800 2	3NE3338-8 2 ⁹⁾ 800 2
Recommended AC fuse according to UL 6) 7) - Rated current	А	3NB3351- 1KK26 1100	3NB3352- 1KK26 1250	3NB3358- 1KK26 1700
Recommended DC fuse according to UL 7) Type 3NB1/3NB2 - Rated current	А	3NB2355- 4KK16 1400	3NB2355- 4KK16 1400	3NB2357- 4KK16 1600
Minimum short-circuit current 8)	kA	18	20	30

- 1) Derating for higher pulse frequencies on request.
- The maximum DC link capacitances of the drive line-up are specified as a function of the number of precharging resistors (2.2 Ω) connected in parallel per phase: 1 precharging resistor/2 precharging resistors/3 precharging resistors.
- 3) The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- The cable lengths are valid for use in IT supply systems. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- ⁵⁾ When used in TN systems and during operation of the Active Line Module Chassis-2 or the connected Motor Module with increased pulse frequency, you can obtain the permitted cable lengths on request.
- 6) Only 3NE1 or 3NB3 fuses should be used to protect the devices. These must be located as close as possible to the converter.
 - The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- 8) Minimum current required for reliable triggering of the protective devices.
- 9) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.

5.5 Active Line Modules Chassis-2

Table 5- 58 Technical data for Active Line Modules Chassis-2, 3 AC 380 ... 480 V, Part 3

Article number	6SL3331-	7TE41-3AA0	7TE41-4AA0
Rated power			
- For In_DC (50 Hz, 400 V)	kW	800	900
- For IL_DC (50 Hz, 400 V)	kW	700	800
- For In_DC (60 Hz, 460 V)	HP	1150	1300
- For IL_DC (60 Hz, 460 V)	HP	1000	1150
DC link current			
- Rated current In_DC	Α	1415	1575
- Base-load current IL_DC	Α	1287	1432
- Maximum current I _{max_DC}	Α	1931	2147
Infeed/regenerative feedback current			
- Rated current In_E	Α	1260	1405
- Maximum current Imax_E	Α	1740	1935
Supply voltages			
- Line voltage	VACrms	3 AC 380) -10 % (-15 % < 1 min) 3 AC 480 +10 %
- Line frequency	Hz		47 63Hz
- Electronics power supply	VDC		24 (20.4 28.8)
- DC link voltage	VDC		1.5 x Uline
Pulse frequency 1)	kHz	4	4
Current consumption			
- Electronics current consumption (24 V DC)	Α	1.3	1.3
- Total fan current consumption (at 400 V AC)	Α	1.8	1.8
Max. ambient temperature			
- Without derating	°C	45	45
- With derating	°C	60	60
DC link capacitance			
- Active Line Module	μF	408	800
- Drive line-up, max.			
- at 400 V / 50 Hz ²⁾	μF		0000/630000
- at 480 V / 60 Hz ²⁾	μF	95000/2500	000/450000
Power loss 3)			
- At 50 Hz 400 V	kW	10.5	11.6
- At 60 Hz 460 V	kW	11.4	12.5
Cooling air requirement	m³/s	0.64	0.64
Sound pressure level			
L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5	72.5
Connections			
- Line connection (U1, V1, W1)		6 x M12	6 x M12
- DC link connection (DCP, DCN)		4 x M12	4 x M12
- PE connection		6 x M12	6 x M12
Max. conductor cross-sections			
- Line connection (U1, V1, W1)	mm²	6 x 240	6 x 240
- DC link connection (DCP, DCN)	mm²	Busbar	Busbar
- PE connection	mm²	6 x 240	6 x 240
Max. cable length ^{4) 5)}			
(total of all motor cables and DC link)			
- Shielded	m	3900	3900
- Unshielded	m	5850	5850
Degree of protection		IP00	IPOO
Dimensions			
- Width	mm	280	280
- Width - Height	mm mm	1491	1491
- Width			
- Width - Height	mm	1491	1491

Article number	6SL3331-	7TE41-3AA0	7TE41-4AA0	
Recommended AC fuse acc. to IEC 6) - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE1448-2 2 ⁹⁾ 850 3	3NE1448-2 2 ⁹⁾ 850 3	
Recommended DC fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE3338-8 2 ⁹⁾ 800 2	3NC3341-1U 2 ⁹⁾ 1000 3	
Recommended AC fuse according to UL ^{6) 7)} - Rated current	А	3NB3358- 1KK26 1700	3NB3358- 1KK26 1700	
Recommended DC fuses according to UL ⁶⁾ Type 3NB1/3NB2 - Rated current	А	3NB2357- 4KK16 1600	3NB2364- 4KK17 2100	
Minimum short-circuit current 8)	kA	30	30	

- 1) Derating for higher pulse frequencies on request.
- The maximum DC link capacitances of the drive line-up are specified as a function of the number of precharging resistors (2.2 Ω) connected in parallel per phase: 1 precharging resistor/2 precharging resistors/3 precharging resistors.
- ³⁾ The specified power loss is the maximum value at 100 % utilization. The value in normal operation is lower.
- The cable lengths are valid for use in IT supply systems. When used in TN systems, the cable lengths are shortened to 30 % of the specified value.
- ⁵⁾ When used in TN systems and during operation of the Active Line Module Chassis-2 or the connected Motor Module with increased pulse frequency, you can obtain the permitted cable lengths on request.
- 6) Only 3NE1 or 3NB3 fuses should be used to protect the devices. These must be located as close as possible to the converter.
 - The specified 3NA3 fuses can be used for the additional cable protection, see Catalog D21.3.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.
- 8) Minimum current required for reliable triggering of the protective devices.
- 9) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.

5.5.7.2 Overload capability

The Active Line Modules Chassis-2 provide an overload reserve.

The criterion for overload is that the Active Line Module is operated as a maximum with its base load current before and after the overload occurs.

For the specified load cycles, it is possible that the applicable derating factors must be taken into consideration (for example, pulse frequency, ambient temperature).

5.5 Active Line Modules Chassis-2

Low overload

Based on the base-load current for slight overload IL_DC, the duty cycle is 115% for 60 seconds with a duty cycle duration of 300 seconds.




Figure 5-54 Low overload

Duty cycle with maximum current

The duty cycle with maximum current I_{max_Dc} is based on a duty cycle 150% for 5 seconds with a duty cycle duration of 300 seconds.

The duty cycle for Imax_DC is valid for a pulse frequency of 4 kHz.




Figure 5-55 Duty cycle with maximum current


Motor Modules 6

6.1 Motor Modules Chassis

6.1.1 Description

A Motor Module is a power unit (DC-AC inverter) that provides the power supply for the motor connected to it. Power is supplied by means of the DC link of the drive unit. A Motor Module must be connected to a Control Unit via DRIVE-CLiQ. The open-loop and closed-loop control functions are stored in the Control Unit.

Table 6-1 Overview of Motor Modules



Operating principle

Motor Modules are designed for multi-axis drive systems and are controlled by either a CU320-2 or a SIMOTION D Control Unit. Motor Modules are interconnected by means of a shared DC busbar.

One or more Motor Modules are supplied with energy for the motors via the DC link. Both synchronous and induction motors can be operated.

Since the Motor Modules share the same DC link, they can exchange energy with one another, i.e. if one Motor Module operating in generator mode produces energy, the energy can be used by another Motor Module operating in motor mode. The DC link is supplied with line voltage by a Line Module.

Characteristics of the Motor Modules

- Version for 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V) from 210 to 1405 A
 Version for 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V) from 85 to 1270 A
- Internal air cooling
- Short-circuit/ground-fault-proof
- · Electronic rating plate
- Operating status and error status via LEDs
- DRIVE-CLiQ interface for communication with the Control Unit and/or other components in the drive line-up
- Integration in system diagnostics

6.1.2 Safety information

MWARNING

Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



/ WARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.

! WARNING

Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in increased downtime and reduced service lives for Motor Modules.

• Observe the ventilation clearances above, below, and in front of the Motor Modules, which are specified in the dimension drawings.

!CAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.

NOTICE

Material damage caused by the failure to remove linkage levers for devices of frame sizes HX and JX

The failure to remove linkage levers from devices of frame sizes HX and JX can cause damage to the device as a result of undershooting the necessary voltage clearances.

For devices of frame sizes HX and JX, remove the linkage levers marked in red once the
devices have been installed.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

• Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

6.1.3 Interface description

6.1.3.1 Overview




Figure 6-1 Motor Module, frame size FX




Figure 6-2 Motor Module, frame size GX




Figure 6-3 Motor Module, frame size HX




Figure 6-4 Motor Module, frame size JX

6.1.3.2 Connection example




Figure 6-5 Connection example Motor Modules

6.1.3.3 DC link/motor connection

Table 6- 2 DC link/motor connection of the Motor Module

Terminals	Technical specifications				
DCP, DCN	Voltage:				
DC power input	• 510 720 VDC				
	• 675 1035 VDC				
	Connections:				
	Frame sizes FX / GX: Thread M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: d = 12 mm (M10 / 25 Nm) flat connector for busbar connection				
DCPA, DCNA	Voltage:				
Connection for Braking Module	• 510 720 VDC				
	• 675 1035 VDC				
	Connections:				
	Frame sizes FX / GX: Threaded bolts M6 / 6 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	Frame sizes HX / JX: Connection for connection clip				
DCPS, DCNS	Voltage:				
Connection for a dV/dt filter plus VPL	• 510 720 VDC				
	• 675 1035 VDC				
	Connections:				
	Frame sizes FX / GX: Thread M8 / 13 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	Frame sizes HX / JX: Thread M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
U2, V2, W2	Voltage:				
3 AC power output	3 AC 0 V to 0.75 x DC link voltage ²⁾				
	Connecting thread:				
	• Frame sizes FX / GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
PE connection	Connecting thread:				
PE1, PE2	• Frame sizes FX / GX: M10 / 25 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				
	• Frame sizes HX / JX: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 1)				

^{1)} Dimensions for connecting alternative cable lugs, see "cable lugs" in the appendix.

For pure space vector modulation, a factor of approximately 0.70 ... 0.72 applies. For edge modulation, a factor of approximately 0.74 ... 0.75.

6.1.3.4 X9 terminal strip

Table 6-3 Terminal strip X9

	Terminal	Signal name	Technical specifications
	1	P24V	External 24 V DC supply
5	2	М	Voltage: 24 VDC (20.4 28.8 V) Current consumption: max. 1.4 A
	3	VL1	240 V AC: 8 A max.
22.2	4	VL2	24 VDC: max. 1 A isolated
1	5	HS1	240 V AC: 8 A max.
	6	HS2	24 VDC: max. 1 A isolated
	L1	Connection for fan	380 480 VAC / 500 690 VAC
	L2	supply	Current consumption: See Technical data
		(frame sizes HX and JX only)	

Max. connectable cross-section:

- terminal 1 ... 6: 2.5 mm²
- terminals L1, L2: 35 mm²

Note

Connecting the fan supply with frame sizes FX and GX

The fan supply for frame sizes FX and GX is connected directly to fuse holders -F10 and -F11.

6.1.3.5 DCPS, DCNS connection for a dv/dt filter

Table 6-4 DCPS, DCNS

Frame size	Connectable cross-section	Connecting screw
FX ¹⁾	1 x 35 mm²	M8
GX ¹⁾	1 x 70 mm ²	M8
HX	1 x 185 mm²	M10
JX	2 x 185 mm²	M10

¹⁾ For frame sizes FX and GX, the connecting cables are routed down through the Motor Module.

6.1.3.6 X41 EP terminal / temperature sensor connection

Table 6-5 Terminal strip X41

Connector	Terminal	Function	Technical specifications
1 2 3 4	1	EP M1 (Enable Pulses)	Supply voltage: 24 VDC (20.4 28.8 V)
	2	EP +24 V (Enable Pulses)	Current consumption: 10 mA
0000			The pulse inhibit function is only available when the "Safety Integrated Basic Functions via onboard terminals" is enabled in the software.
	3	-Temp	Temperature sensor connection: KTY84-1C130
	4	+Temp	/ PT100 / PT1000 / PTC
Max. connecta	ble cross-se	ection: 1.5 mm ²	





Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to motor in the event of incorrectly connected KTY temperature sensor

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

• Connect a KTY temperature sensor with the correct polarity.

Note

The temperature sensor connection can be used for motors that are equipped with a KTY84-1C130, PT100, PT1000 or PTC measuring sensor in the stator windings.

Note

Function of the EP terminals

The function of the EP terminals for pulse inhibit is only available if the "Safety Integrated Basic Functions via onboard terminals" is enabled in the software.

6.1.3.7 X42 terminal strip

Table 6- 6 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications	
© □1 Þ	1	P24L	Power supply for Control Unit, Sensor Module and	
	2		Terminal Module (18 28.8 V) maximum load current: 3 A	
	3	М	Thaximum load current. 3 A	
94.	4			
Max. connectable cross-section: 2.5 mm ²				

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

6.1.3.8 X46 Brake control and monitoring

Table 6-7 Terminal strip X46 brake control and monitoring

Connector	Terminal	Function	Technical specifications		
© □1♭	1	BR output +	Brake connection		
O □2 b O □3 b	2	BR output -	Supply voltage: 24 V DC Max. load current: 200 mA		
ОЦ4Р	3	FB input +	Internal feedback signal from the Safe Brake		
	4	FB input -	Adapter		
Max. connecta	Max. connectable cross-section: 1.5 mm ²				

Note

The interface is intended for connection of the Safe Brake Adapter.



Fire due to overheating when the total length of the connecting cables is exceeded

Excessively long connection cables on terminal strip X46 can cause components to overheat with the associated risk of fire and smoke.

- Limit the length of the connecting cables to a maximum of 10 m.
- Do not route the connection cable outside the control cabinet or control cabinet group.

6.1.3.9 DRIVE-CLiQ interfaces X400, X401, X402

Table 6-8 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications
. 🗔 B	1	TXP	Transmit data +
	2	TXN	Transmit data -
1 5 5	3	RXP	Receive data +
	4	Reserved, do not use	
	5	Reserved, do not use	
	6	RXN	Receive data -
	7	Reserved, do not use	
	8	Reserved, do not use	
	Α	+ (24 V)	24 V power supply
	В	M (0 V)	Electronics ground
Blanking plate	for DRIVE-CLi	Q interfaces (50 pcs.) Article number:	6SL3066-4CA00-0AA0

6.1.3.10 Meaning of the LEDs on the Control Interface Module in the Motor Module

Table 6-9 Meaning of the LEDs "READY" and "DC LINK" on the Control Interface Module in the Motor Module

LED	state	Description
READY	DC LINK	
Off	Off	The electronics power supply is missing or out of tolerance.
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.
	Red	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.
Orange	Orange	DRIVE-CLiQ communication is being established.
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.
Flashing light 2 Hz: green/orange or red/orange	1)	Detection of the components via LED is activated (p0124). Note: Both options depend on the LED status when module recognition is activated via p0124 = 1.

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 6-10 Meaning of the LED "POWER OK" on the Control Interface Module in the Motor Module

LED	Color	Status	Description
POWER OK	Green	Off	DC link voltage or control voltage at -X9 too low.
		On	The component is ready for operation.
		Flashing light	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



/ WARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

6.1.4 Dimension drawing

Dimension drawing, frame size FX




Figure 6-6 Dimension drawing Motor Module, frame size FX Front view, side view

Dimension drawing, frame size GX




Figure 6-7 Dimension drawing Motor Module, frame size GX Front view, side view

Dimension drawing, frame size HX




Figure 6-8 Dimension drawing Motor Module, frame size HX Side view, rear view

Dimension drawing, frame size JX




Figure 6-9 Dimension drawing Motor Module, frame size JX Side view, rear view

6.1.5 Electrical connection

Adjusting the fan voltage (-T10)


The power supply for the device fans (1 AC 230 V) in the Motor Module (-T10) is taken from the line supply using transformers. The installation position of the transformers is indicated in the interface descriptions.

The transformers are fitted with primary taps so that they can be fine-tuned to the line supply voltage.

If necessary, the connection fitted in the factory, shown with a dashed line, must be reconnected to the actual line voltage.

Note

Two transformers (T10 and -T20) are installed in Motor Modules frame size JX. The two primary-side terminals on each of these devices must be adjusted together.






Figure 6-10 Setting terminals for the fan transformers (3 AC 380 ... 480 V / 3 AC 500 ... 690 V)

The supply voltage assignments for making the appropriate setting on the fan transformer are indicated in the following tables (factory presetting: 480 V / 0 V or 690 V / 0 V).

Note

With the 3 AC 500 V to 690 V fan transformer, a jumper is inserted between the "600 V" terminal and "CON" terminal. The jumper between terminal "600 V" and "CON" is for internal use.



Fire due to overheating resulting from insufficient equipment fan voltage

If the terminals are not reconnected to the actual line voltage, overheating and human danger due to smoke and fire may result.

This can also cause the fan fuses to blow due to overload.

• Set the terminals in accordance with the actual line voltage.

Table 6-11 Line voltage assignment for the setting at the fan transformer (3 AC 380 ... 480 V)

Line voltage	Tap at the fan transformer (-T10)
380 V ± 10%	380 V
400 V ± 10%	400 V
440 V ± 10%	440 V
480 V ± 10%	480 V

Table 6- 12 Line voltage assignment for the setting at the fan transformer (3 AC 500 ... 690 V)

Line voltage	Tap at the fan transformer (-T10)
500 V ± 10%	500 V
525 V ± 10%	525 V
575 V ± 10%	575 V
600 V ± 10%	600 V
660 V ± 10%	660 V
690 V ± 10%	690 V

6.1.6 Technical specifications

6.1.6.1 Motor Modules, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V)

Table 6-13 Technical data for Motor Modules, 510 ... 720 V DC (line voltage 380 ... 480 V3 AC), Part 1

Article number	6SL3320-	1TE32-1AA3	1TE32-6AA3	1TE33-1AA3	1TE33-8AA3
Output current					
- Rated current IN A	Α	210	260	310	380
- Base load current I∟	Α	205	250	302	370
- Base load current Iн	Α	178	233	277	340
- For S6 operation (40%) Is6	Α	230	285	340	430
- Max. output current I _{max}	Α	307	375	453	555
Type rating					
- Based on I _L (50 Hz 400 V) 1)	kW	110	132	160	200
- Based on Iн (50 Hz 400 V) 1)	kW	90	110	132	160
- Based on I _L (60 Hz 460 V) ²⁾	HP	150	200	250	300
- Based on Iн (60 Hz 460 V) ²⁾	HP	150	200	200	250
DC-link current					
-Rated current IN DC when fed via					
- Basic/Smart Line Module	Α	252	312	372	456
- Active Line Module	Α	227	281	335	411
Base load current ILDC when fed via					
- Basic/Smart Line Module	Α	245	304	362	444
- Active Line Module	Α	221	273	326	400
Base load current In DC when fed via					
- Basic/Smart Line Module	Α	224	277	331	405
- Active Line Module	Α	202	250	298	365
Supply voltages			·		_
- DC-link voltage	V DC		510.	720	
- Electronic power supply	V DC		24 (20.4	· 28.8)	
- Output voltage	VACrms		0 0.75 x D	C link voltage	

Article number	6SL3320-	1TE32-1AA3	1TE32-6AA3	1TE33-1AA3	1TE33-8AA3
Rated pulse frequency - Max. pulse frequency without derating - Max. pulse frequency with derating	kHz kHz kHz	2 2 8	2 2 8	2 2 8	2 2 8
Max. ambient temperature - Without derating - With derating	° C ° C	40 55	40 55	40 55	40 55
DC-link capacitance	μF	4200	5200	6300	7800
Current consumption - Electronics current consumption (24 VDC) - Fan supply, at 2 AC 400 V, 50/60 Hz	A A	0.8 0.63 / 0.95	0.8 1.13 / 1.7	0.9 1.8 / 2.7	0.9 1.8 / 2.7
Power loss, max. ³⁾ - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	1.86 1.94	2.5 2.6	2.96 3.1	3.67 3.8
Cooling air requirement	m³/s	0.17	0.23	0.36	0.36
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	64 / 67	71 / 71	69 / 73	69 / 73
Connections - DC-link connection - Motor connection - PE connection PE1 - PE connection PE2		M10 M10 M10 M10	M10 M10 M10 M10	M10 M10 M10 M10	M10 M10 M10 M10
Max. conductor cross-sections - DC-link connection (DCP, DCN) - Motor connection (U2, V2, W2) - PE connection PE1 - PE connection PE2	mm² mm² mm² mm²	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 240 2 x 240 2 x 240 2 x 240 2 x 240	2 x 240 2 x 240 2 x 240 2 x 240 2 x 240
Motor cable length, max. 4) - shielded - unshielded	m m	300 450	300 450	300 450	300 450
Degree of protection		IP20	IP20	IP20	IP20
Dimensions - Width - Height - Depth	mm mm mm	326 1400 356	326 1400 356	326 1533 545	326 1533 545
Frame size		FX	FX	GX	GX
Weight	kg	95	95	136	136

¹⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 400 V 50 Hz.

²⁾ Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 460 V 60 Hz.

³⁾ The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.

When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

Table 6-14 Technical data for Motor Modules, 510 ... 720 V DC (line voltage 380 ... 480 V 3 AC), Part 2

Article number	6SL3320-	1TE35-0AA3	1TE36-1AA3	1TE37-5AA3	1TE38-4AA3
Output current					
- Rated current In A	Α	490	605	745	840
- Base load current I∟	Α	477	590	725	820
- Base load current Iн	Α	438	460	570	700
- For S6 operation (40%) Is6	Α	540			
- Max. output current I _{max}	Α	715	885	1087	1230
Type rating					
- Based on I _L (50 Hz 400 V) ¹⁾	kW	250	315	400	450
- Based on I _H (50 Hz 400 V) ¹⁾	kW	200	250	315	400
- Based on L (60 Hz 460 V) ²⁾	HP	400	500	600	700
- Based on Iн (60 Hz 460 V) ²⁾	HP	350	350	450	600
DC-link current					
-Rated current IN DC when fed via - Basic/Smart Line Module	_	588	726	894	1008
- Active Line Module	A	529	653	89 4 805	907
Base load current lldc when fed via	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	329	033	803	907
- Basic/Smart Line Module	Α	573	707	871	982
- Active Line Module	A	515	636	784	884
Base load current IHDC when fed via	/ /	313	050	704	004
- Basic/Smart Line Module	Α	523	646	795	897
- Active Line Module	A	470	581	716	807
Supply voltages				·	•
- DC-link voltage	VDC		510.	720	
- Electronic power supply	VDC			28.8)	
- Output voltage	VACrms		0 0.75 x D	C link voltage	
Rated pulse frequency	kHz	2	1.25	1.25	1.25
- Max. pulse frequency without derating	kHz	2	1.25	1.25	1.25
- Max. pulse frequency with derating	kHz	8	8	8	8
Max. ambient temperature					
- Without derating	° C	40	40	40	40
- With derating	° C	55	55	55	55
DC-link capacitance	μF	9600	12600	15600	16800
Current consumption					
- Electronics current consumption (24 VDC)	Α	0.9	1.0	1.0	1.0
- Fan supply, at 2 AC 400 V, 50/60 Hz	Α	1.8 / 2.7	3.6 / 5.4	3.6 / 5.4	3.6 / 5.4
Power loss, max. 3)					
- at 50 Hz 400 V	kW	4.28	5.84	6.68	7.15
- at 60 Hz 460 V	kW	4.5	6.3	7.3	7.8
Cooling air requirement	m³/s	0.36	0.78	0.78	0.78
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	69 / 73	70 / 73	70 / 73	70 / 73
Connections					
- DC-link connection		M10	4 x M10	4 x M10	4 x M10
- Motor connection		M10	2 x M12	2 x M12	2 x M12
- PE connection PE1		M10	M12	M12	M12
- PE connection PE2	-	M10	2 x M12	2 x M12	2 x M12
Max. conductor cross-sections	2	2 246			
- DC-link connection (DCP, DCN)	mm²	2 x 240	Busbar	Busbar	Busbar
- Motor connection (U2, V2, W2)	mm²	2 x 240	4 x 240	4 x 240	4 x 240
- PE connection PE1	mm²	2 x 240	1 x 240	1 x 240	1 x 240
- PE connection PE2	mm²	2 x 240	2 x 240	2 x 240	2 x 240
Motor cable length, max. 4)			200		200
- shielded	m	300	300	300	300
- unshielded	m	450	450	450	450
Degree of protection	1	IP20	IPO0	IPOO	IP00

Article number	6SL3320-	1TE35-0AA3	1TE36-1AA3	1TE37-5AA3	1TE38-4AA3
Dimensions - Width - Height - Depth	mm mm mm	326 1533 545	503 1475 540	503 1475 540	503 1475 540
Frame size		GX	HX	HX	HX
Weight	kg	136	290	290	290

- $^{1)}$ Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 400 V 50 Hz.
- ²⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 460 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

Table 6- 15 Technical data for Motor Modules, 510 ... 720 V DC (line voltage 380 ... 480 V3 AC), Part 3

Article number	6SL3320-	1TE41-0AA3	1TE41-2AA3	1TE41-4AA3	1TE41-4AS3
Output current					
- Rated current In A	Α	985	1260	1405	1330
- Base load current I∟	Α	960	1230	1370	1310
- Base load current Iн	Α	860	1127	1257	1150
- For S6 operation (40%) Is6	Α				
- Max. output current I _{max}	Α	1440	1845	2055	2055
Type rating					
- Based on I _L (50 Hz 400 V) 1)	kW	560	710	800	800
- Based on I _H (50 Hz 400 V) ¹⁾	kW	450	560	710	630
- Based on I _L (60 Hz 460 V) ²⁾	HP	800	1000	1150	1000
- Based on I _H (60 Hz 460 V) ²⁾	HP	700	900	1000	900
DC-link current					
-Rated current IN DC when fed via					
- Basic/Smart Line Module	A	1182	1512	1686	1550
- Active Line Module	Α	1064	1361	1517	1403
Base load current ledc when fed via		1150	1 4 7 4	1642	4505
- Basic/Smart Line Module	A	1152	1474	1643	1525
- Active Line Module	Α	1037	1326	1479	1405
Base load current IH DC when fed via - Basic/Smart Line Module	Α	1051	1345	1500	1676
- Active Line Module	A	946	1211	1350	1403
	Α	940	1211	1330	1403
Supply voltages	N/		F10	720	
- DC-link voltage	V _{DC}				
- Electronic power supply- Output voltage	VDC VACrms			28.8) C link voltage	
		4.05			I a
Rated pulse frequency	kHz	1.25	1.25	1.25	2
- Max. pulse frequency without derating	kHz	1.25	1.25	1.25	2
- Max. pulse frequency with derating	kHz	8	8	8	4
Max. ambient temperature					
- Without derating	° C	40	40	40	40
- With derating	° C	55	55	55	55
DC-link capacitance	μF	18900	26100	28800	19200
Current consumption					
- Electronics current consumption (24 VDC)	A	1.25	1.4	1.4	1.4
- Fan supply, at 2 AC 400 V, 50/60 Hz	Α	5.4 / 8.1	5.4 / 8.1	5.4 / 8.1	5.4 / 8.1
Power loss, max. 3)					
- at 50 Hz 400 V	kW	9.5	11.1	12.0	10.8
- at 60 Hz 460 V	kW	10.2	12.0	13.0	12.30
Cooling air requirement	m³/s	1.08	1.08	1.08	1.08
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	71 / 73	71 / 73	71 / 73	71 / 73
Connections	_				
- DC-link connection		4 x M10	4 x M10	4 x M10	4 x M10
- Motor connection		3 x M12	3 x M12	3 x M12	3 x M12
- PE connection PE1		M12	M12	M12	M12
- PE connection PE2		3 x M12	3 x M12	3 x M12	3 x M12
Max. conductor cross-sections					
- DC-link connection (DCP, DCN)	mm²	Busbar	Busbar	Busbar	Busbar
	mm²	6 x 240	6 x 240	6 x 240	6 x 240
- Motor connection (U2, V2, W2)					4 242
- PE connection PE1	mm²	1 x 240	1 x 240	1 x 240	1 x 240
			1 x 240 3 x 240	1 x 240 3 x 240	1 x 240 3 x 240
- PE connection PE1 - PE connection PE2	mm²	1 x 240			
- PE connection PE1	mm²	1 x 240			
- PE connection PE1 - PE connection PE2 Motor cable length, max. 4)	mm² mm²	1 x 240 3 x 240	3 x 240	3 x 240	3 x 240

Article number	6SL3320-	1TE41-0AA3	1TE41-2AA3	1TE41-4AA3	1TE41-4AS3
Dimensions - Width - Height - Depth	mm mm mm	704 1475 540	704 1475 540	704 1475 540	704 1475 540
Frame size		JX	JX	JX	JX
Weight	kg	450	450	450	450

- $^{1)}$ Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 400 V 50 Hz.
- ²⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 460 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

6.1.6.2 Motor Modules, 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V)

Table 6-16 Technical data for Motor Modules, 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V), Part 1

Article number	6SL3320-	1TG28-5AA3	1TG31-0AA3	1TG31-2AA3	1TG31-5AA3
Output current - Rated current IN A - Base load current IL	A A	85 80	100 95	120 115	150 142
- Base load current IH - Max. output current I _{max}	A A	76 120	89 142	107 172	134 213
Type rating - Based on IL (50 Hz 690 V) 1) - Based on IH (50 Hz 690 V) 1) - Based on IL (50 Hz 500 V) 1) - Based on IH (50 Hz 500 V) 1) - Based on IL (60 Hz 575 V) 2) - Based on IH (60 Hz 575 V) 2)	kW kW kW kW HP	75 55 55 45 75 75	90 75 55 55 75 75	110 90 75 75 100 100	132 110 90 90 150 125
DC-link current -Rated current INDC when fed via - Basic/Smart Line Module - Active Line Module Base load current ILDC when fed via - Basic/Smart Line Module	A A	102 92 99	120 108	144 130	180 162 175
- Active Line Module Base load current IHDC when fed via - Basic/Smart Line Module - Active Line Module	A A A	90 81	105 106 96	126 128 115	157 160 144
Supply voltages - DC-link voltage - Electronic power supply - Output voltage	VDC VDC VACrms	675 1035 24 (20.4 28.8) 0 0.75 x DC link voltage			
Rated pulse frequency - Max. pulse frequency without derating - Max. pulse frequency with derating	kHz kHz kHz	1.25 1.25 7.5	1.25 1.25 7.5	1.25 1.25 7.5	1.25 1.25 7.5
Max. ambient temperature - Without derating - With derating	° C ° C	40 55	40 55	40 55	40 55
DC-link capacitance	μF	1200	1200	1600	2800
Current consumption - Electronics current consumption (24 VDC) - Fan supply, at 2 AC 690 V, 50/60 Hz	A A	0.8 0.4 / 0.6	0.8 0.4 / 0.6	0.8 0.4 / 0.6	0.8 0.4 / 0.6
Power loss, max. 3) - at 50 Hz 690 V - at 60 Hz 575 V	kW kW	1.17 1.1	1.43 1.3	1.89 1.77	1.80 1.62
Cooling air requirement	m³/s	0.17	0.17	0.17	0.17
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	64 / 67	64 / 67	64 / 67	64 / 67
Connections - DC-link connection - Motor connection - PE connection PE1 - PE connection PE2		M10 M10 M10 M10	M10 M10 M10 M10	M10 M10 M10 M10	M10 M10 M10 M10
Max. conductor cross-sections - DC-link connection (DCP, DCN) - Motor connection (U2, V2, W2) - PE connection PE1 - PE connection PE2	mm² mm² mm² mm²	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185	2 x 185 2 x 185 2 x 185 2 x 185 2 x 185

Article number	6SL3320-	1TG28-5AA3	1TG31-0AA3	1TG31-2AA3	1TG31-5AA3
Motor cable length, max. 4) - shielded - unshielded	m m	300 450	300 450	300 450	300 450
Degree of protection		IP20	IP20	IP20	IP20
Dimensions - Width - Height - Depth	mm mm mm	326 1400 356	326 1400 356	326 1400 356	326 1400 356
Frame size		FX	FX	FX	FX
Weight	kg	95	95	95	95

- 1) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 500 V or 690 V 50 Hz.
- $^{2)}$ Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 575 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

Table 6-17 Technical data for Motor Modules, 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V), Part 2

Article number	6SL3320-	1TG31-8AA3	1TG32-2AA3	1TG32-6AA3	1TG33-3AA3
Output current					
- Rated current IN A	Α	175	215	260	330
- Base load current I∟	Α	171	208	250	320
- Base load current Iн	Α	157	192	233	280
- Max. output current I _{max}	Α	255	312	375	480
Type rating					
- Based on IL (50 Hz 690 V) 1)	kW	160	200	250	315
- Based on I _H (50 Hz 690 V) ¹⁾	kW	132	160	200	250
- Based on I∟ (50 Hz 500 V) 1)	kW	110	132	160	200
- Based on I _H (50 Hz 500 V) 1)	kW	90	110	132	160
- Based on IL (60 Hz 575 V) ²⁾ - Based on IH (60 Hz 575 V) ²⁾	HP	150	200	250	300
	HP	150	200	200	250
DC-link current					
-Rated current INDC when fed via		210	250	242	206
- Basic/Smart Line Module	A	210	258	312	396
- Active Line Module Base load current ILDC when fed via	Α	189	232	281	356
- Basic/Smart Line Module	Α	204	251	304	386
- Active Line Module	A	184	226	273	347
Base load current IHDC when fed via	[*			[-/ 5] ,
- Basic/Smart Line Module	Α	186	229	277	352
- Active Line Module	Α	168	206	250	316
Supply voltages			•	•	•
- DC-link voltage	VDC		675	. 1035	
- Electronic power supply	VDC			28.8)	
- Output voltage	VACrms			C link voltage	
Rated pulse frequency	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency without derating	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency with derating	kHz	7.5	7.5	7.5	7.5
Max. ambient temperature					
- Without derating	° C	40	40	40	40
- With derating	° C	55	55	55	55
DC-link capacitance	μF	2800	2800	3900	4200
Current consumption					
- Electronics current consumption (24 VDC)	Α	0.9	0.9	0.9	0.9
- Fan supply, at 2 AC 690 V, 50/60 Hz	Α	1.0 / 1.5	1.0 / 1.5	1.0 / 1.5	1.0 / 1.5
Power loss, max. 3)					
- at 50 Hz 690 V	kW	2.67	3.09	3.62	4.34
- at 60 Hz 575 V	kW	2.5	2.91	3.38	3.98
Cooling air requirement	m³/s	0.36	0.36	0.36	0.36
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	69 / 73	69 / 73	69 / 73	69 / 73
Connections					
- DC-link connection		M10	M10	M10	M10
- Motor connection		M10	M10	M10	M10
- PE connection PE1		M10	M10	M10	M10
- PE connection PE2	1	M10	M10	M10	M10
Max. conductor cross-sections	_				
- DC-link connection (DCP, DCN)	mm²	2 x 240	2 x 240	2 x 240	2 x 240
- Motor connection (U2, V2, W2)	mm²	2 x 240	2 x 240	2 x 240	2 x 240
- PE connection PE1	mm²	2 x 240	2 x 240	2 x 240	2 x 240
- PE connection PE2	mm²	2 x 240	2 x 240	2 x 240	2 x 240
Motor cable length, max. 4)			200		
- shielded	m	300	300	300	300
- unshielded	m	450	450	450	450

Article number	6SL3320-	1TG31-8AA3	1TG32-2AA3	1TG32-6AA3	1TG33-3AA3
Degree of protection		IP20	IP20	IP20	IP20
Dimensions - Width - Height - Depth	mm mm mm	326 1533 545	326 1533 545	326 1533 545	326 1533 545
Frame size		GX	GX	GX	GX
Weight	kg	136	136	136	136

- 1) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 500 V or 690 V 50 Hz.
- ²⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 575 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

Table 6-18 Technical data for Motor Modules, 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V), Part 3

Article number	6SL3320-	1TG34-1AA3	1TG34-7AA3	1TG35-8AA3	1TG37-4AA3
Output current					
- Rated current IN A	Α	410	465	575	735
- Base load current I∟	Α	400	452	560	710
- Base load current Iн	Α	367	416	514	657
- Max. output current I _{max}	A	600	678	840	1065
Type rating					
- Based on I∟ (50 Hz 690 V) 1)	kW	400	450	560	710
- Based on I _H (50 Hz 690 V) ¹⁾	kW	315	400	450	630
- Based on I _L (50 Hz 500 V) 1)	kW	250	315	400	500
- Based on I _H (50 Hz 500 V) 1)	kW	200	250	315	450
- Based on L (60 Hz 575 V) ²⁾	HP	400	450	600	700
- Based on Iн (60 Hz 575 V) ²⁾	HP	350	450	500	700
DC-link current					
-Rated current INDC when fed via		400	550	600	000
- Basic/Smart Line Module	A	492	558	690	882
- Active Line Module Base load current ILDC when fed via	Α	443	502	621	794
- Basic/Smart Line Module	Α	479	544	672	859
- Active Line Module	Â	431	489	605	774
Base load current In DC when fed via		151	103	003	' ' '
- Basic/Smart Line Module	Α	437	496	614	784
- Active Line Module	A	394	446	552	706
Supply voltages			•	•	•
- DC-link voltage	VDC		675	. 1035	
- Electronic power supply	VDC			28.8)	
- Output voltage	VACrms			C link voltage	
Rated pulse frequency	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency without derating	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency with derating	kHz	7.5	7.5	7.5	7.5
Max. ambient temperature					
- Without derating	° C	40	40	40	40
- With derating	° C	55	55	55	55
DC-link capacitance	μF	7400	7400	7400	11100
Current consumption					
- Electronics current consumption (24 VDC)	Α	1.0	1.0	1.0	1.25
- Fan supply, at 2 AC 690 V, 50/60 Hz	Α	2.1 / 3.1	2.1 / 3.1	2.1 / 3.1	3.1 / 4.6
Power loss, max. 3)					
- at 50 Hz 690 V	kW	6.13	6.80	10.3	10.9
- at 60 Hz 575 V	kW	5.71	6.32	9.7	10.0
Cooling air requirement	m³/s	0.78	0.78	0.78	1.08
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	70 / 73	70 / 73	70 / 73	71 / 73
Connections					
- DC-link connection		4 x M10	4 x M10	4 x M10	4 x M10
- Motor connection		2 x M12	2 x M12	2 x M12	3 x M12
- PE connection PE1		M12	M12	M12	M12
- PE connection PE2		2 x M12	2 x M12	2 x M12	3 x M12
Max. conductor cross-sections					
- DC-link connection (DCP, DCN)	mm²	Busbar	Busbar	Busbar	Busbar
- Motor connection (U2, V2, W2)	mm²	4 x 240	4 x 240	4 x 240	6 x 240
- PE connection PE1	mm ²	1 x 240	1 x 240	1 x 240	1 x 240
- PE connection PE2	mm²	2 x 240	2 x 240	2 x 240	3 x 240
Motor cable length, max. 4)					
- shielded	m	300	300	300	300
- unshielded	m	450	450	450	450

Article number	6SL3320-	1TG34-1AA3	1TG34-7AA3	1TG35-8AA3	1TG37-4AA3
Degree of protection		IP00	IP00	IP00	IP00
Dimensions - Width - Height - Depth	mm mm mm	503 1475 547	503 1475 547	503 1475 547	704 1475 550
Frame size		HX	HX	HX	JX
Weight	kg	290	290	290	450

- 1) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 500 V or 690 V 50 Hz.
- ²⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 575 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

Table 6-19 Technical data for Motor Modules, 675 ... 1035 V DC (line voltage 3 AC 500 ... 690 V), Part 4

Article number	6SL3320-	1TG38-1AA3	1TG38-8AA3	1TG41-0AA3	1TG41-3AA3
Output current					
- Rated current IN A	Α	810	910	1025	1270
- Base load current I∟	Α	790	880	1000	1230
- Base load current Iн	Α	724	814	917	1136
- Max. output current I _{max}	Α	1185	1320	1500	1845
Type rating					
- Based on IL (50 Hz 690 V) 1)	kW	800	900	1000	1200
- Based on I _H (50 Hz 690 V) ¹⁾	kW	710	800	900	1000
- Based on I∟ (50 Hz 500 V) 1)	kW	560	630	710	900
- Based on I _H (50 Hz 500 V) ¹⁾	kW	500	560	630	800
- Based on lւ (60 Hz 575 V) ²⁾ - Based on lн (60 Hz 575 V) ²⁾	HP HP	800 700	900 800	1000 900	1250 1000
	ПР	700	800	900	1000
DC-link current					
-Rated current IN DC when fed via - Basic/Smart Line Module	_	972	1092	1230	1524
- Basic/smart Line Module - Active Line Module	A	875	983	1107	1372
Base load current ILDC when fed via	^	3/3	703	1107	13/2
- Basic/Smart Line Module	Α	947	1064	1199	1485
- Active Line Module	A	853	958	1079	1337
Base load current IH DC when fed via					
- Basic/Smart Line Module	Α	865	971	1094	1356
- Active Line Module	Α	778	874	985	1221
Supply voltages					
- DC-link voltage	VDC		675	. 1035	
- Electronic power supply	V _{DC}			· 28.8)	
- Output voltage	VACrms		0 0.75 x D	C link voltage	
Rated pulse frequency	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency without derating	kHz	1.25	1.25	1.25	1.25
- Max. pulse frequency with derating	kHz	7.5	7.5	7.5	7.5
Max. ambient temperature					
- Without derating	° C	40	40	40	40
- With derating	° C	55	55	55	55
DC-link capacitance	μF	11100	14400	14400	19200
Current consumption					
- Electronics current consumption (24 VDC)	Α	1.25	1.4	1.4	1.4
- Fan supply, at 2 AC 690 V, 50/60 Hz	Α	3.1 / 4.6	3.1 / 4.6	3.1 / 4.6	3.1 / 4.6
Power loss, max. 3)					
- at 50 Hz 690 V	kW	11.5	11.7	13.2	16.0
- at 60 Hz 575 V	kW	10.5	10.6	12.0	14.2
Cooling air requirement	m³/s	1.08	1.08	1.08	1.08
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	71 / 73	71 / 73	71 / 73	71 / 73
Connections					
- DC-link connection		4 x M10	4 x M10	4 x M10	4 x M10
- Motor connection		3 x M12	3 x M12	3 x M12	3 x M12
- PE connection PE1		M12	M12	M12	M12
- PE connection PE2		3 x M12	3 x M12	3 x M12	3 x M12
Max. conductor cross-sections					
- DC-link connection (DCP, DCN)	mm ²	Busbar	Busbar	Busbar	Busbar
- Motor connection (U2, V2, W2)	mm²	6 x 240	6 x 240	6 x 240	6 x 240
- PE connection PE1	mm²	1 x 240	1 x 240	1 x 240	1 x 240
- PE connection PE2	mm²	3 x 240	3 x 240	3 x 240	3 x 240
Motor cable length, max. 4)					
- shielded	m	300	300	300	300
- unshielded	m	450	450	450	450

Article number	6SL3320-	1TG38-1AA3	1TG38-8AA3	1TG41-0AA3	1TG41-3AA3
Degree of protection		IP00	IP00	IP00	IP00
Dimensions - Width - Height - Depth	mm mm mm	704 1475 550	704 1475 550	704 1475 550	704 1475 550
Frame size		JX	JX	JX	JX
Weight	kg	450	450	450	450

- 1) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 500 V or 690 V 50 Hz.
- ²⁾ Rated power of a typical 6-pole standard induction motor based on I_L or I_H at 3 AC 575 V 60 Hz.
- 3) The specified power loss is the maximum value at 100% capacity utilization. The value in normal operation is lower.
- When used in the TN system and infeed via Active Line Module and when operating the Motor Modules with increased pulse frequency, you will receive the permitted motor cable lengths upon request.

6.1.6.3 Overload capability

The Motor Modules have an overload reserve (e.g. to handle breakaway torques).

In the case of drives with overload requirements, the appropriate base-load current must, therefore, be used as a basis for the required load.

The criterion for overload is that the Motor Module is operated as a maximum with its base load current before and after the overload occurs (a load duration of 300 s is used as a basis here).

Another precondition is that the Motor Module is operated at its factory-set pulse frequency at output frequencies > 10 Hz.

Additional information on the overload capability is provided in the Low Voltage Configuration Manual and in the SINAMICS S120 Function Manual Drive Functions.

Low overload

The base load current for low overload (I_L) is based on a load duty cycle of 110% for 60 s or 150% for 10 s.




Figure 6-11 Low overload

High overload

The base load current for a high overload I_H is based on a duty cycle of 150% for 60 s or 160% for 10 s.




Figure 6-12 High overload

6.1.6.4 Current de-rating depending on the pulse frequency

When the pulse frequency is increased, the derating factor of the output current must be taken into account. This derating factor must be applied to the currents specified in the technical data for Motor Modules.

Table 6- 20 Derating factor of the output current as a function of the pulse frequency for devices with a rated pulse frequency of 2 kHz

Article No.	Type rating	Output current at 2 kHz	Derating factor at the pulse frequency				
6SL3320	[kW]	[A]	2.5 kHz	4 kHz	5 kHz	7.5 kHz	8 kHz
	Conn	ection voltage 510 7	'20 V DC (line	voltage 3 AC	380 480 V)	
1TE32-1AA3	110	210	95 %	82 %	74%	54%	50 %
1TE32-6AA3	132	260	95 %	83 %	74%	54%	50 %
1TE33-1AA3	160	310	97 %	88 %	78%	54%	50 %
1TE33-8AA3	200	380	96%	87 %	77%	54%	50 %
1TE35-0AA3	250	490	94%	78%	71 %	53 %	50 %
1TE41-4AS3	800	1330	88 %	55 %			

Table 6- 21 Derating factor of the output current as a function of the pulse frequency for devices with a rated pulse frequency of 1.25 kHz

Article No.	Type rating	Output current at 1.25 kHz	Derating factor at the pulse frequency					
6SL3320	[kW]	[A]	2 kHz	2.5 kHz	4 kHz	5 kHz	7.5 kHz	8 kHz
	Conn	ection voltage 510	720 V DC (li	ne voltage	3 AC 380	. 480 V)		
1TE36-1AA3	315	605	83 %	72 %	64 %	60 %	40 %	36 %
1TE37-5AA3	400	745	83 %	72 %	64 %	60 %	40 %	36 %
1TE38-4AA3	450	840	87 %	79 %	64 %	55 %	40 %	37 %
1TE41-0AA3	560	985	92 %	87 %	70 %	60 %	50 %	47 %
1TE41-2AA3	710	1260	92 %	87 %	70 %	60 %	50 %	47 %
1TE41-4AA3	800	1405	97 %	95 %	74%	60 %	50 %	47 %
	Connection voltage 675 1035 V DC (line voltage 3 AC 500 690 V)							
1TG28-5AA3	75	85	93%	89 %	71 %	60 %	40 %	
1TG31-0AA3	90	100	92 %	88 %	71 %	60 %	40 %	
1TG31-2AA3	110	120	92 %	88 %	71 %	60 %	40 %	
1TG31-5AA3	132	150	90%	84%	66%	55 %	35 %	
1TG31-8AA3	160	175	92 %	87 %	70 %	60 %	40 %	
1TG32-2AA3	200	215	92 %	87 %	70 %	60 %	40 %	
1TG32-6AA3	250	260	92 %	88 %	71 %	60 %	40 %	
1TG33-3AA3	315	330	89 %	82 %	65 %	55 %	40 %	
1TG34-1AA3	400	410	89 %	82 %	65 %	55 %	35 %	
1TG34-7AA3	450	465	92 %	87 %	67 %	55 %	35 %	
1TG35-8AA3	560	575	91 %	85 %	64 %	50 %	35 %	1
1TG37-4AA3	710	735	87 %	79 %	64 %	55 %	35%	
1TG38-1AA3	800	810	97 %	95 %	71 %	55 %	35 %	1
1TG38-8AA3	900	910	92 %	87 %	67 %	55 %	33 %	
1TG41-0AA3	1000	1025	91 %	86 %	64 %	50 %	30 %	
1TG41-3AA3	1200	1270	87 %	79 %	55 %	40 %	25 %	

Note

Derating factors for pulse frequencies in the range between two fixed values

For pulse frequencies in the range between the specified fixed values, the relevant derating factors can be determined by linear interpolation.

Maximum output frequencies achieved by increasing the pulse frequency

The adjustable pulse frequencies - and therefore the output frequencies that can be achieved with the factory-set current controller clock cycles - are listed below.

Table 6- 22 Maximum output frequencies achieved by increasing the pulse frequency

Current controller	Adjustable pulse	Maximum achievable output frequency fa				
clock cycle Tı	frequencies f _P	V/f operating mode	Vector operating mode	Servo mode		
250 μs ¹⁾	2 kHz	166 Hz	166 Hz	333 Hz		
	4 kHz	333 Hz	333 Hz	550 Hz ³⁾		
	8 kHz	550 Hz ³⁾	480 Hz	550 Hz ³⁾		
400 μs ²⁾	1.25 kHz	104 Hz	104 Hz	-		
	2.50 kHz	208 Hz	208 Hz	-		
	5.00 kHz	416 Hz	300 Hz	-		
	7.50 kHz	550 Hz ³⁾	300 Hz	-		

¹⁾ As factory setting, the following devices have a current controller clock cycle of 250 μs - and a pulse frequency of 2 kHz: - 510 ... 720 V DC: ≤250 kW / 490 A, 6SL3320-1TE41-4AS3

Refer to the Low Voltage Configuration Manual for current controller clock cycles deviating from the factory setting.

As factory setting, the following devices have a current controller clock cycle of 400 μ s - and a pulse frequency of 1.25 kHz:

^{- 510 ... 720} V DC: ≥315 kW / 605 A, with the exception of 6SL3320-1TE41-4AS3

^{- 675 ... 1035} V DC: All power ratings

With the "High output frequencies" license, which can be ordered as option J01 on the CompactFlash card for SINAMICS S120, the maximum output frequency is increased up to 650 Hz.

6.1.6.5 Parallel connection of Motor Modules

The following rules must be observed when connecting Motor Modules in parallel:

- Up to four identical Motor Modules can be connected in parallel.
- A common Control Unit is required whenever the modules are connected in parallel.
- The motor supply cables must have the same length (symmetrical design).
- Power must be supplied to the Motor Modules from a common DC link.
- For motors with a single winding system, supply cables with a minimum length or motor reactors must be used. The cable lengths are listed in the following tables.
- For motors with multi-winding systems, carefully observe the notes provided in the Low Voltage Engineering Manual.
- A derating factor of 5 % must be taken into consideration, regardless of the number of Motor Modules connected in parallel.

Note

Different power units cannot be connected in parallel.

It is only possible to connect Motor Module in parallel if all power units have the same hardware version.

It is not possible to connect Motor Modules with Article No. 6SL3320-1Txxx-xAA0 and Article No. 6SL3320-1Txxx-xAA3 in parallel.

Minimum cable lengths for parallel connection and connection to a motor with a single-winding system

Note

Minimum cable lengths

The minimum cable lengths specified in the tables below must be observed when two or more Motor Modules are connected in parallel and there is a connection to a motor with a single-winding system. If the cable length required for the application cannot be achieved, a motor reactor must be provided.

Table 6- 23 Motor Modules, DC 510 ... 720 V (line voltage 3 AC 380 ... 480 V)

Article number	Type rating [kW]	Output current [A]	Minimum cable length [m]
6SL3320-1TE32-1AA3	110	210	30
6SL3320-1TE32-6AA3	132	260	27
6SL3320-1TE33-1AA3	160	310	20
6SL3320-1TE33-8AA3	200	380	17
6SL3320-1TE35-0AA3	250	490	15
6SL3320-1TE36-1AA3	315	605	13
6SL3320-1TE37-5AA3	400	745	10
6SL3320-1TE38-4AA3	450	840	9
6SL3320-1TE41-0AA3	560	985	8
6SL3320-1TE41-2AA3	710	1260	6
6SL3320-1TE41-4AA3	800	1405	5
6SL3320-1TE41-4AS3	800	1330	5

Table 6- 24 Motor Modules, DC 675 ... 1035 V (line voltage 3 AC 500 ... 690 V)

Article number	Type rating [kW]	Output current [A]	Minimum cable length [m]
6SL3320-1TG28-5AA3	75	85	100
6SL3320-1TG31-0AA3	90	100	90
6SL3320-1TG31-2AA3	110	120	80
6SL3320-1TG31-5AA3	132	150	70
6SL3320-1TG31-8AA3	160	175	60
6SL3320-1TG32-2AA3	200	215	50
6SL3320-1TG32-6AA3	250	260	40
6SL3320-1TG33-3AA3	315	330	30
6SL3320-1TG34-1AA3	400	410	25
6SL3320-1TG34-7AA3	450	465	25
6SL3320-1TG35-8AA3	560	575	20
6SL3320-1TG37-4AA3	710	735	18
6SL3320-1TG38-1AA3	800	810	15
6SL3320-1TG38-8AA3	900	910	12
6SL3320-1TG41-0AA3	1000	1025	10
6SL3320-1TG41-3AA3	1200	1270	8

6.2.1 Description

A Motor Module is a power unit (DC-AC inverter) that provides the power supply for the motor connected to it. The power supply is realized through the DC link of the drive unit. A Motor Module must be connected to a Control Unit via DRIVE-CLiQ. The open-loop and closed-loop control functions are implemented in the Control Unit.



Figure 6-13 Motor Module Chassis-2, frame size FS4

Operating principle

Motor Modules are designed for multi-axis drive systems and are controlled by either a CU320-2 or a SIMOTION D Control Unit. The Motor Modules are connected through a common DC busbar.

One or more Motor Modules are supplied with energy for the motors via the DC link. Both synchronous and induction motors can be operated.

Since the Motor Modules share the same DC link, they can exchange energy with one another, i.e. if one Motor Module operating in generator mode produces energy, the energy can be used by another Motor Module operating in motor mode. The DC link is supplied with line voltage by a Line Module.

Characteristics of Motor Modules Chassis-2

- Version for 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V) from 655 to 1495 A
- Internal air cooling with variable-speed fan; the fan speed is controlled as a function of the load and temperature
- Short-circuit/ground-fault-proof
- Electronic nameplate
- Operating status and error status via LEDs
- DRIVE-CLiQ interface for communication with the Control Unit and/or other components in the drive line-up
- Integration in system diagnostics
- The DC link fuses are not included; they are provided on the plant/system side to make diagnostics simpler and they can be simply replaced in the control cabinet, see Chapter "Technical data (Page 323)".

6.2.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.



/ WARNING

High leakage currents when the protective conductor in the line feeder cable is interrupted

The drive components conduct a high leakage current via the protective conductor. Touching conductive parts when the protective conductor is interrupted can result in death or serious injury.

- Ensure that the external protective conductor satisfies at least one of the following conditions:
 - It has been installed so that it is protected against mechanical damage. 1)
 - For an individual core, it has a cross-section of at least 10 mm² Cu.
 - If it is a conductor of a multi-conductor cable, it has a cross-section of at least 2.5 mm² Cu.
 - It has a second protective conductor in parallel with the same cross-section.
 - ¹⁾ Cables laid within control cabinets or closed machine housings are considered to be adequately protected against mechanical damage.
- Observe the local regulations for protective conductors subject to a high leakage current at the operating location.



Fire due to inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in increased downtime and reduced service lives for Motor Modules.

• Observe the ventilation clearances above, below and in front of the Motor Modules, which are specified in the dimension drawings.

ACAUTION

Fire due to overheating when the total length of the power cables is exceeded

Overheating and a fire can result when the total length of the power cables is exceeded.

• Ensure that the total length of the power cables (motor feeder cables and DC link cables) does not exceed the values specified in the technical data.



CAUTION

Burns resulting from high surface temperatures

Depending on the ambient temperature, the temperature on the enclosure of the device can exceed >60 °C. Contact with the surface can result in severe burns.

• Before starting to work on the device, check the temperature of the enclosure.

NOTICE

Material damage caused by loose power connections

Insufficient tightening torques or vibration can result in faulty electrical connections. This can cause fire damage or malfunctions.

- Tighten all power connections with the specified tightening torques, e.g. line connection, motor connection, DC link connections.
- Check the tightening torques of all power connections at regular intervals and tighten them when required. This applies in particular after transport.

NOTICE

Damage to the devices when performing a voltage test as a result of connections that have not been disconnected

As part of routine tests, SINAMICS S components undergo a voltage test according to IEC 61800-5-1.

• Disconnect or unplug all SINAMICS devices before the voltage test of the machine equipment according to IEC 60204-1, Section 18.4.

NOTICE

Damage through use of incorrect DRIVE-CLiQ cables

Damage or malfunctions can occur on the devices or system when DRIVE-CLiQ cables are used that are either incorrect or have not been released for this purpose.

• Only use suitable DRIVE-CLiQ cables that have been released by Siemens for the particular application.

Note

Fan can start automatically

When the power supply is available, the fan can start automatically as a function of the ambient temperature.

NOTICE

Operation only with firmware V5.2 HF4 or higher.

The Motor Module Chassis-2 can be damaged if operated with unsuitable firmware.

Only operate the Motor Module Chassis-2 with a firmware V5.2 HF4 or higher.

6.2.3 Interface description

6.2.3.1 Overview





Figure 6-14 Motor Module Chassis-2

6.2.3.2 Connection example



① The DC link fuses must be provided on the plant/system side, see Chapter "Technical data (Page 323)".

Figure 6-15 Connection example, Motor Modules Chassis-2

6.2.3.3 DC link/motor connection

Table 6- 25 DC link / motor connection of Motor Modules Chassis-2

Terminals	Technical specifications
DCP, DCN DC power input	 Voltage: 510 720 VDC Connections: Frame size FS2, FS2+, FS4, FS4+: d = 14 mm (M12 / 50 Nm) flat connector for busbar connection
	When connecting using copper busbars, the same cross-sections should be used as the connecting busbars of the device itself:
	Frame size FS2: 70 mm x 4 mm
	Frame size FS2+: 70 mm x 6 mm
	• Frame size FS4, FS4+: 80 mm x 8 mm The DC link must be protected (fused) on the plant/system side.
U2, V2, W2 3 AC power output	Voltage: • 3 AC 0 V to 0.75 x DC link voltage ¹⁾ Connecting thread: • Frame size FS2, FS2+, FS4+: M12 / 50 Nm for cable lugs in accordance with DIN 46234 /
PE connection	DIN 46235 ²⁾ Connecting thread:
T E CONTINUE COOT	 Frame size FS2, FS2+, FS4, FS4+: M12 / 50 Nm for cable lugs in accordance with DIN 46234 / DIN 46235 ²⁾

For pure space vector modulation, a factor of approximately 0.70 ... 0.72 applies. For edge modulation, a factor of approximately 0.74 ... 0.75.

! WARNING

Electric shock if unsuitable screws are used to connect the motor

The plastic enclosure behind the motor connections can be damaged if screws longer than 40 mm are used. This represents danger to life, and equipment can be damaged.

- Only use the original M12x40 screws, including the spring washer, when connecting the motor cables.
- If you have to replace screws, then only use screws with the same length. Always use a spring washer.

²⁾ Dimensions for connecting alternative cable lugs, see "Cable lugs for devices with Chassis-2 design" in the Appendix.

6.2.3.4 X51 connection, fan power supply

Table 6- 26 Terminal strip X51, fan power supply connection

Connector	Terminal	Function	Technical specifications
L1 L2 L3 PE	L1	L1	Supply voltage: 3 AC 380 V 480 V
	L2	L2	Frequency: 47 63 Hz
	L3	L3	Max. load current: 1.8 A
	PE	PE	Connection is connected to the fan housing.
Max. connectable cross-section: 6.0 mm ²			

A 3-pole 16 A miniature circuit breaker, with a tripping characteristic Class C is recommended to protect the fan power supply.

Note

After installation, screw on the connector.

Note

Connect the PE connection with the PE connection of the electrical cabinet.

Note

For installation altitudes exceeding 2000 m, an isolating transformer must be connected upstream of the fan power supply.

NOTICE

Damage to the fan when pulling the connector under load

The fan can become damaged if the connector is pulled under load (while the fan is rotating).

• Do not pull the connector under load.

6.2.3.5 X9 terminal strip

Table 6-27 Terminal strip X9

Connector	Terminal	Signal name	Technical specifications	
	VL1 VL2	Pre-charge contac- tor control	240 V AC: 8 A max. 24 VDC: max. 1 A isolated relay contact	
	NC	NC	Reserved, do not use	
	HS1 HS2	Main contactor control	240 V AC: 8 A max. 24 VDC: max. 1 A isolated relay contact	
	P24V M	P24V M	External 24 V DC supply Voltage: 24 V DC (20.4 28.8 V)	
	IVI	IVI	Current consumption: max. 1.6 Å	
Max. connectable cross-section: 2.5 mm ²				

6.2.3.6 X41 EP terminal / temperature sensor connection

Table 6-28 Terminal strip X41

Connector	Terminal	Function	Technical specifications
	1	EP +24 V (enable pulses)	Supply voltage: 24 VDC (20.4 28.8 V) Current consumption: 10 mA
	2	EP M1 (enable pulses)	The pulse inhibit function is only available when the "Safety Integrated Basic Functions via onboard terminals" is enabled in the software.
	3 +Temp (motor) Temperature sensor connection: KT	Temperature sensor connection: KTY84-1C130	
	4	-Temp (motor)	/ PT100 / PT1000 / PTC
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

At terminals 1 and 2, the terminal strip has a yellow marking, it is coded at terminal 4; please use the corresponding connector from the accessory pack.



MARNING

Electric shock in the event of voltage flashovers at the temperature sensor

Voltage flashovers in the signal electronics can occur in motors without safe electrical separation of the temperature sensors.

- Only use temperature sensors that fully comply with the specifications of the safety isolation.
- If safe electrical separation cannot be guaranteed (for linear motors or third-party motors, for example), use a Sensor Module External (SME120 or SME125) or Terminal Module TM120.

NOTICE

Device failure as a result of unshielded or incorrectly routed cables to temperature sensors

Unshielded or incorrectly routed cables to temperature sensors can result in interference being coupled into the signal processing electronics from the power side. This can result in significant disturbance of all signals (fault messages) up to failure of individual components (destruction of the devices).

- Only use shielded cables as temperature sensor cables.
- If temperature sensor cables are routed together with the motor cable, use separately shielded cables twisted in pairs.
- Connect the cable shield to ground potential through a large surface area.

NOTICE

Damage to the motor in the event of incorrectly connected KTY temperature sensor at terminals X41:3,4

If a KTY temperature sensor is connected with incorrect polarity, it is not possible to detect when the motor overheats. Overheating can cause damage to the motor.

• Connect a KTY temperature sensor with the correct polarity.

Note

The temperature sensor connection at terminals X41:3,4 can be used for motors that are equipped with a KTY84-1C130, PT100, PT1000 or PTC measuring sensor in the stator windings.

Note

Function of the EP terminals

The function of the EP terminals for pulse inhibit is only available if the "Safety Integrated Basic Functions via onboard terminals" is enabled in the software.

6.2.3.7 X42 terminal strip

Table 6-29 Terminal strip X42 voltage supply for Control Unit, Sensor Module and Terminal Module

Connector	Terminal	Function	Technical specifications
	1	P24L	Power supply for Control Unit, Sensor Module
	2		and Terminal Module (18 28.8 V) maximum load current: 3 A
	3	M	maximum ioad current: 3 A
	4		
Max. connectable cross-section: 2.5 mm ²			

Note

Connection options for terminal strip X42

The terminal strip is not intended to be freely used for other 24 V DC loads (for example for supplying additional line-side components), as the voltage supply of the Control Interface Module could also be overloaded and operating capability could thus be compromised.

6.2.3.8 X46 Brake control and monitoring

Table 6-30 Terminal strip X46 brake control and monitoring

Connector	Terminal	Function	Technical specifications
	1	BR output +	Brake connection
	2	BR output -	Supply voltage: 24 V DC Max. load current: 200 mA
	3	FB input +	Internal feedback signal from the Safe Brake
	4	FB input -	Adapter
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 1; please use the corresponding connector from the accessory pack.

Note

The interface is intended for connection of the Safe Brake Adapter.



Fire due to overheating when the total length of the connecting cables is exceeded

Excessively long connection cables on terminal strip X46 can cause components to overheat with the associated risk of fire and smoke.

- Limit the length of the connecting cables to a maximum of 10 m.
- Do not route the connection cable outside the control cabinet or control cabinet group.

6.2.3.9 X47 contactor feedback signal

Table 6- 31 Terminal strip X47, contactor feedback signal

Connector	Terminal	Signal name	Technical specifications
	1	VL_R	Precharging contactor feedback signal
	2	М	Supply voltage: 24 V DC Max. Load current: 10 mA
	3	HS_R	Main contactor feedback signal
	4	М	Supply voltage: 24 V DC Max. Load current: 10 mA
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 3; please use the corresponding connector from the accessory pack.

6.2.3.10 X49 terminal block

Table 6- 32 Terminal strip X49

Connector	Terminal	Function	Technical specifications
	1	LAMPPWR	Supply voltage: 24 V DC
	2	М	Max. Load current: 100 mA
			If the power unit has a fault condition, then voltage is available at the terminals.
	3	NC	Reserved, do not use
	4	NC	Reserved, do not use
	5	NC	Reserved, do not use
	6	NC	Reserved, do not use

Max. connectable cross-section: 1.5 mm²

The terminal strip is coded at terminal 6; please use the corresponding connector from the accessory pack.

Note

Function of the "LAMPPWR" signal

By connecting a signal lamp, the "LAMPPWR" terminal can be used in large cabinet groups for signaling the power unit in which a problem exists. Once there is a fault in the respective power supply unit, a voltage of 24 V DC is output at the output.

Note: During a firmware update, the output alternates between 0 V and 24 V.

6.2.3.11 DRIVE-CLiQ interfaces X400, X401, X402

Table 6- 33 DRIVE-CLiQ interfaces X400, X401, X402

Connector	PIN	Signal name	Technical specifications	
. □ B	1	TXP	Transmit data +	
▮▮▮	2	TXN	Transmit data -	
1 =	3	RXP	Receive data +	
	4	Reserved, do not use		
	5	Reserved, do not use		
	6	RXN	Receive data -	
	7	Reserved, do not use		
	8	Reserved, do not use		
	Α	+ (24 V) 24 V power supply		
	В	M (0 V)	Electronics ground	
Blanking plate	Blanking plate for DRIVE-CLiQ interfaces (50 pcs.) Article number: 6SL3066-4CA00-0AA0			

6.2.3.12 Test points for 1 mm test probes

On the connectors X41, X46, X47 and X49 you will find test points for 1 mm test probes on the sides, see ① in the following figure.




Figure 6-16 Test points for 1 mm test probes

6.2.3.13 Meaning of the LEDs on the Motor Module

Table 6-34 Meaning of the "READY" and "DC LINK" LEDs on the Motor Module Chassis-2

LED state		Description		
READY	DC LINK			
Off	Off	The electronics power supply is missing or out of tolerance.		
Green	1)	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place.		
	Orange	The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC-link voltage is present.		
Red		The component is ready for operation and cyclic DRIVE-CLiQ communication is taking place. The DC link voltage lies outside the permitted tolerance range.		
Orange	Orange	DRIVE-CLiQ communication is being established.		
Red	1)	This component has at least one fault. Remark: The LED is activated irrespective of whether the corresponding messages have been reconfigured.		
Flashing light 0.5 Hz: green/red	1)	Firmware is being downloaded.		
Flashing light 2 Hz: green/red	1)	Firmware download is complete. Waiting for POWER ON.		
Flashing light 2 Hz: green/orange or red/orange	1)	Detection of the components via LED is activated (p0124). Note: Both options depend on the LED status when module recognition is activated via $p0124 = 1$.		

¹⁾ Irrespective of the status of the LED "DC LINK"

Table 6- 35 Meaning of the "PWR ON" LED on the Motor Module Chassis-2

LED	Color	Status	Description
PWR ON	Green	Off	DC link voltage or supply voltage at -X9 too low.
		On	The component is ready for operation.
	Red	Flashing light	There is a fault. If the LED continues to flash after you have performed a POWER ON, please contact your Siemens service center.



MARNING

Electric shock when live parts of the DC link are touched

Hazardous DC link voltages may be present at any time regardless of the status of the "DC LINK" LED. This means that when live parts are touched, this can result in death or serious injury.

• Observe the warning information on the component.

6.2.4 Dimension drawing

Dimension drawing, frame size FS2

The mandatory cooling clearances are indicated by the dotted line.




Figure 6-17 Dimension drawing, Motor Module Chassis-2 format, frame size FS2. Side view, front view

Dimension drawing, frame size FS2+

The mandatory cooling clearances are indicated by the dotted line.




Figure 6-18 Dimension drawing, Motor Module Chassis-2+, frame size FS2+. Side view, front view

Dimension drawing, frame size FS4, FS4+

The mandatory cooling clearances are indicated by the dotted line.




Figure 6-19 Dimension drawing, Motor Module Chassis-2 format, frame size FS4, FS4+ Side view, front view

6.2.5 Installation

The Motor Module Chassis-2 is secured using two M10 bolts on the top of the device, which are screwed onto the rear mounting panel of the control cabinet.

Then the Motor Module Chassis-2 is fastened to the mounting surface of the control cabinet using a mounting bracket.



When installing the device without using a suitable mounting aid, the device may be damaged or cause injury.

When installing the Motor Module in a control cabinet without using a suitable mounting aid, the Motor Module may be damaged or cause injury.

• When installing the Motor Module in a control cabinet, use a suitable mounting aid so that the device can be horizontally rolled into the control cabinet.

ACAUTION

Injury or damage to the device if it topples or rolls away.

During installation, the Motor Module can topple over or roll away. This can result in injuries or damage to the device.

• Secure the Motor Module so that it cannot topple over or roll away.

Mounting dimensions in the control cabinet

Refer to the following diagrams for the mounting dimensions when installing a Motor Module Chassis-2 in a control cabinet.

Front view of the control cabinet

210 ±0.1 ≥45

Frame size FS2, FS2+

M10 12.5 ±0.2

Frame size FS4, FS4+ 210 ±0.1 M10 12.5 ±0.2 1391 ±0.2


- 1) Side panel of the control cabinet
- 2 Mounting surface for the Motor Module

Note

Tolerances for holes tapped in the rear mounting panel

If the specified tolerances for the threaded holes of the rear mounting panel of the control cabinet cannot be adhered to, then compensating fastening elements should be used to facilitate screwing in the Motor Module.

Top view of the control cabinet mounting surface



- ① Side panel of the control cabinet
- ② Rear mounting panel

Figure 6-20 Installation top view

Attaching the mounting bracket

First, fasten the mounting bracket to the mounting surface of the control cabinet (1), then to the fastening points on the Motor Module (2).

When mounting, ensure that no additional pressure is applied to the rollers of the Motor Module by observing the positions of the elongated holes (11 mm x 15 mm).

Tighten the M10 screws to a torque of 50 Nm.




Figure 6-21 Attaching the mounting bracket (diagram showing an example)

6.2.6 Electrical connection

Attaching the PE connections

The 3 PE connections must be attached before installing the Motor Module. The connecting busbars are included in the accessory pack.

Attach each PE connection at the Motor Module using 2 screws, torque 25 Nm.




Figure 6-22 Attaching the PE connections

Attaching the PE connections

The shield connections are used to connect the shields of the shielded signal cables to the Motor Module.

Attach the support plate for the shield connections at the intended position. You can break off individual parts from the 6-part support plate corresponding to your specific requirements, torque 3 Nm.






Figure 6-23 Attaching the PE connections

The accessory pack of the Motor Module includes 3 shield clamps for cable diameters 3 ...6 mm and 6 ...8 mm.

Use the respective shielding clamps corresponding to the cables to be shielded.



Attach shield clip



Snap in shield clip




Figure 6-24 Installed signal cable with strain relief and shielding

6.2.7 Technical data

6.2.7.1 Motor Modules, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V)

Table 6- 36 Technical data, Motor Modules Chassis-2, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V), Part 1

Article number	6SL3321-	1TE36-6AA0	1TE37-4AA0	1TE38-1AA0	1TE38-8AA0
Output current - Rated current In A - Base load current IL - Base load current IH 1) - Max. output current Imax	A A A	655 620 555 917	740 700 620 1036	810 770 675 1134	910 865 760 1274
Type rating - Based on IL (50 Hz 400 V) ²⁾ - Based on IH (50 Hz 400 V) ²⁾ - Based on IL (60 Hz 460 V) ³⁾ - Based on IH (60 Hz 460 V) ³⁾	kW kW HP HP	315 280 500 450	355 315 600 500	400 355 650 550	450 400 700 650
DC link current Rated current INDC	A	785	890	975	1090
Supply voltages - DC link voltage - Electronics power supply - Output voltage Rated pulse frequency	VDC VDC VACrms	510 720 24 (20.4 28.8) 0 0.75 x DC link voltage			2.5
- Max. pulse frequency without derating - Max. pulse frequency with derating	kHz kHz	2.5	2.5	2.5	2.5
Max. ambient temperature - Without derating - With derating	° C	45 60	45 60	45 60	45 60
DC-link capacitance	μF	16450	16450	18800	18800
Current consumption - Electronics current consumption (24 V DC) - Fan supply, at 3 AC 400 V, 50/60 Hz	A A	1.3 1.8 / 1.8	1.3 1.8 / 1.8	1.3 1.8 / 1.8	1.3 1.8 / 1.8
Power loss, max. 4) - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	6.4 6.6	6.7 7.0	7.4 7.7	8.4 8.7
Cooling air requirement	m³/s	0.64	0.64	0.64	0.64
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5	72.5	72.5	72.5
Connections - DC link connection - Motor connection - PE connection		2 x M12 4 x M12 4 x M12	2 x M12 4 x M12 4 x M12	2 x M12 4 x M12 4 x M12	2 x M12 4 x M12 4 x M12
Max. conductor cross-sections - DC link connection (DCP, DCN) - Motor connection (U2, V2, W2) - PE connection	mm² mm²	Busbar 4 x 240 4 x 240	Busbar 4 x 240 4 x 240	Busbar 4 x 240 4 x 240	Busbar 4 x 240 4 x 240
Motor cable length, max. 5) - shielded - unshielded	m m	300 450	300 450	300 450	300 450
Degree of protection		IP00	IP00	IPOO	IP00

Article number	6SL3321-	1TE36-6AA0	1TE37-4AA0	1TE38-1AA0	1TE38-8AA0
Dimensions - Width - Height - Depth	mm mm mm	280 1248 542	280 1248 542	280 1248 542	280 1248 542
Frame size		FS2	FS2	FS2+	FS2+
Weight	kg	119	119	122	122
Recommended fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE3334-0B 2 ⁶⁾ 500 2	3NE3335 2 ⁶⁾ 560 2	3NE3335 2 ⁶⁾ 560 2	3NE3336 2 ⁶⁾ 630 2
Recommended fuses according to UL ⁷⁾ Type 3NB1/3NB2 - Rated current	А	3NB2350- 4KK16 1000	3NB2350- 4KK16 1000	3NB2355- 4KK16 1400	3NB2355- 4KK16 1400

- 1) The value for IH is valid for a pulse frequency of 2 kHz. It is also valid for a pulse frequency of 2.5 kHz, if p0290 is set = 12 (automatic pulse frequency and output current reduction for a thermal power unit overload).
- 2) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 400 V 50 Hz.
- 3) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 460 V 60 Hz.
- 4) The specified power loss is the maximum value for a 100 % utilization level. The value in normal operation is lower.
- When used in the TN system and with infeed via Active Line Module and when operating the Motor Modules Chassis-2 with an increased pulse frequency, you will receive the permitted motor cable lengths upon request.
- 6) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.

Table 6- 37 Technical data, Motor Modules Chassis-2, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V), Part 2

Article number	6SL3321-	1TE41-0AA0	1TE41-1AA0	1TE41-2AA0	1TE41-3AA0
Output current - Rated current IN A - Base load current IL - Base load current IH 1) - Max. output current Imax	A A A	975 910 800 1365	1075 1000 890 1505	1200 1145 1000 1680	1325 1260 1100 1855
Type rating - Based on IL (50 Hz 400 V) ²⁾ - Based on IH (50 Hz 400 V) ²⁾ - Based on IH (50 Hz 400 V) ³⁾ - Based on IH (60 Hz 460 V) ³⁾	kW kW HP	500 450 750 650	560 500 850 750	630 560 950 850	710 630 1050 900
DC link current Rated current IN DC	A	1170	1290	1440	1590
Supply voltages - DC link voltage - Electronics power supply - Output voltage	VDC VDC VACrms		24 (20.4	720 l 28.8) C link voltage	
Rated pulse frequency - Max. pulse frequency without derating - Max. pulse frequency with derating	kHz kHz kHz	2.5 2.5 8	2.5 2.5 8	2.5 2.5 8	2.5 2.5 8
Max. ambient temperature - Without derating - With derating	° C	45 60	45 60	45 60	45 60
DC-link capacitance	μF	25900	25900	25900	40800
Current consumption - Electronics current consumption (24 V DC) - Fan supply, at 3 AC 400 V, 50/60 Hz	A A	1.3 1.8 / 1.8	1.3 1.8 / 1.8	1.3 1.8 / 1.8	1.3 1.8 / 1.8
Power loss, max. 4) - at 50 Hz 400 V - at 60 Hz 460 V	kW kW	8.7 9.0	9.5 9.8	10.4 10.8	12.1 13.2
Cooling air requirement	m³/s	0.64	0.64	0.64	0.64
Sound pressure level L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5	72.5	72.5	72.5
Connections - DC link connection - Motor connection - PE connection		4 x M12 6 x M12 6 x M12	4 x M12 6 x M12 6 x M12	4 x M12 6 x M12 6 x M12	4 x M12 6 x M12 6 x M12
Max. conductor cross-sections - DC link connection (DCP, DCN) - Motor connection (U2, V2, W2) - PE connection	mm² mm²	Busbar 6 x 240 6 x 240	Busbar 6 x 240 6 x 240	Busbar 6 x 240 6 x 240	Busbar 6 x 240 6 x 240
Motor cable length, max. 5) - shielded - unshielded	m m	300 450	300 450	300 450	300 450
Degree of protection		IP00	IP00	IP00	IPOO
Dimensions - Width - Height - Depth	mm mm mm	280 1491 542	280 1491 542	280 1491 542	280 1491 542
Frame size		FS4	FS4	FS4	FS4+
Weight	kg	162	162	162	173

Article number	6SL3321-	1TE41-0AA0	1TE41-1AA0	1TE41-2AA0	1TE41-3AA0
Recommended fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	А	3NE3336 2 ⁶⁾ 630 2	3NE3337-8 2 ⁶⁾ 710 2	3NE3338-8 2 ⁶⁾ 800 2	3NC3341-1U 2 ⁶⁾ 1000 3
Recommended fuses according to UL 7) Type 3NB1/3NB2 - Rated current	A	3NB2355- 4KK16 1400	3NB2357- 4KK16 1600	3NB2357- 4KK16 1600	3NB2364- 4KK17 2100

- The value for IH is valid for a pulse frequency of 2 kHz. It is also valid for a pulse frequency of 2.5 kHz, if p0290 is set = 12 (automatic pulse frequency and output current reduction for a thermal power unit overload).
- 2) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 400 V 50 Hz.
- 3) Rated power of a typical 6-pole standard induction motor based on I∟or Iн at 3 AC 460 V 60 Hz.
- 4) The specified power loss is the maximum value for a 100 % utilization level. The value in normal operation is lower.
- When used in the TN system and with infeed via Active Line Module and when operating the Motor Modules Chassis-2 with an increased pulse frequency, you will receive the permitted motor cable lengths upon request.
- 6) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.

Table 6-38 Technical data, Motor Modules Chassis-2, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V), Part 3

Article number	6SL3321-	1TE41-5AA0			
Output current					
- Rated current In A	Α	1495			
- Base load current I∟	Α	1420			
- Base load current IH 1)	Α	1240			
- Max. output current I _{max}	Α	2093			
Type rating					
- Based on I _L (50 Hz 400 V) ²⁾	kW	800			
- Based on In (50 Hz 400 V) 2)	kW	710			
- Based on I _L (60 Hz 460 V) ³⁾	HP	1200			
- Based on Iн (60 Hz 460 V) ³⁾	HP	1050			
DC link current					
Rated current In DC	Α	1795			
Supply voltages				I.	
- DC link voltage	VDC		510.	720	
- Electronics power supply	VDC			28.8)	
- Output voltage	VACrms			C link voltage	
Rated pulse frequency	kHz	2.5		g-	
- Max. pulse frequency without derating	kHz	2.5			
- Max. pulse frequency with derating	kHz	8			
Max. ambient temperature	1				
- Without derating	° C	45			
- With derating	∘ C	60			
3	_				
DC-link capacitance	μF	40800			
Current consumption					
- Electronics current consumption (24 V DC)	A	1.3			
- Fan supply, at 3 AC 400 V, 50/60 Hz	Α	1.8 / 1.8			
Power loss, max. 4)					
- at 50 Hz 400 V	kW	13.7			
- at 60 Hz 460 V	kW	14.8			
Cooling air requirement	m³/s	0.64			
Sound pressure level					
L _{pA} (1 m) at 50/60 Hz	dB(A)	72.5			
Connections					
- DC link connection		4 x M12			
- Motor connection		6 x M12			
- PE connection		6 x M12			
Max. conductor cross-sections					
- DC link connection (DCP, DCN)		Busbar			
- Motor connection (U2, V2, W2)	mm²	6 x 240			
- PE connection	mm²	6 x 240			
Motor cable length, max. 5)					
- shielded	m	300			
- unshielded	m	450			
Degree of protection		IP00			
Dimensions					
- Width	mm	280			
- Height	mm	1491			
- Depth	mm	542			
Frame size		FS4+			
	ka				
Weight	kg	173			

Article number	6SL3321-	1TE41-5AA0		
Recommended fuse acc. to IEC - Number per phase (connected in parallel) - Rated current - Frame size acc. to IEC 60269	A	3NC3342-1U 2 ⁶⁾ 1100 3		
Recommended fuses according to UL 7) Type 3NB1/3NB2 - Rated current	A	3NB2364- 4KK17 2100		

- 1) The value for IH is valid for a pulse frequency of 2 kHz. It is also valid for a pulse frequency of 2.5 kHz, if p0290 is set = 12 (automatic pulse frequency and output current reduction for a thermal power unit overload).
- 2) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 400 V 50 Hz.
- 3) Rated power of a typical 6-pole standard induction motor based on IL or IH at 3 AC 460 V 60 Hz.
- 4) The specified power loss is the maximum value for a 100 % utilization level. The value in normal operation is lower.
- When used in the TN system and with infeed via Active Line Module and when operating the Motor Modules Chassis-2 with an increased pulse frequency, you will receive the permitted motor cable lengths upon request.
- 6) When using fuses connected in parallel in each phase, all of the fuses must be replaced if one fuse ruptures.
- 7) To achieve a UL-approved system, it is absolutely essential to use the fuse types specified in the table.

6.2.7.2 Overload capability

The Motor Modules Chassis-2 have an overload reserve (e.g. to handle breakaway torques).

In the case of drives with overload requirements, the appropriate base-load current must, therefore, be used as a basis for the required load.

The overloads apply under the precondition that the Motor Module is operated as a maximum with its base load current before and after the overload; this is based on a duty cycle of 300 s (low overload, high overload) - or 60 s (S6 duty cycle).

Another precondition is that the Motor Module is operated at its factory-set pulse frequency at output frequencies > 10 Hz.

Additional information on the overload capability is provided in the Low Voltage Configuration Manual and in the SINAMICS S120 Function Manual Drive Functions.

Low overload

The base load current for low overload (I_L) is based on a load duty cycle of 110 % for 60 s.




Figure 6-25 Low overload

High overload

The base load current for a high overload IH is based on a duty cycle of 150 % for 60 s.

The duty cycle for I_H is valid for a pulse frequency of 2 kHz. It is also valid for a pulse frequency of 2.5 kHz, if p0290 is set = 12 (automatic pulse frequency and output current reduction for a thermal power unit overload).




Figure 6-26 High overload

S6 duty cycle

The base load current for duty cycle ls6 is based on a duty cycle of 200 % for 6 s.

The duty cycle for I_{56} is valid for a pulse frequency of 2 kHz. It is also valid for a pulse frequency of 2.5 kHz, if p0290 is set = 12 (automatic pulse frequency and output current reduction for a thermal power unit overload).




Figure 6-27 S6 duty cycle with initial load with a duty cycle duration of 60 s

6.2.7.3 Current de-rating depending on the pulse frequency

When the pulse frequency is increased, the derating factor of the output current must be taken into account. This derating factor must be applied to the currents specified in the technical data for Motor Modules Chassis-2.

Table 6- 39 Derating factor of the output current as a function of the pulse frequency for devices with a rated pulse frequency of 2.5 kHz

Article No.	Type rating	Output current at 2.5 kHz	Dera	iting factor at t	he pulse frequ	ency
6SL3321	[kW]	[A]	4 kHz	5 kHz	7.5 kHz	8 kHz
Connection voltage 510 720 V DC (line voltage 3 AC 380 480 V)						
1TE36-6AA0	315	655	78 %	67 %	48 %	45 %
1TE37-4AA0	355	740	78 %	67 %	48 %	45 %
1TE38-1AA0	400	810	78 %	67 %	48 %	45 %
1TE38-8AA0	450	910	78 %	67 %	48 %	45 %
1TE41-0AA0	500	975	78 %	67 %	48 %	45 %
1TE41-1AA0	560	1075	78 %	67 %	48 %	45 %
1TE41-2AA0	630	1200	78 %	67 %	48 %	45 %
1TE41-3AA0	710	1325	78 %	67 %	48 %	45 %
1TE41-5AA0	800	1495	75 %	62 %	39%	36 %

Note

Derating factors for pulse frequencies in the range between two fixed values

For pulse frequencies in the range between the specified fixed values, the relevant derating factors can be determined by linear interpolation.

Maximum output frequencies achieved by increasing the pulse frequency

The adjustable pulse frequencies - and therefore the output frequencies that can be achieved with the factory-set current controller clock cycles - are listed below.

Table 6- 40 Maximum output frequencies achieved by increasing the pulse frequency

Current controller	Adjustable pulse	Maximum achievable output frequency fa				
clock cycle Tı	frequencies f _p	V/f operating mode	Vector operating mode	Servo mode		
400 μs	2.50 kHz 5.00 kHz 7.50 kHz	208 Hz 416 Hz 550 Hz ¹⁾	208 Hz 300 Hz 300 Hz	- - -		

With the "High output frequencies" license, which can be ordered as option J01 on the CompactFlash card for SINAMICS S120, the maximum output frequency is increased up to 650 Hz.

Refer to the Low Voltage Configuration Manual for current controller clock cycles deviating from the factory setting.

6.2.7.4 Parallel connection of Motor Modules Chassis-2

The following rules must be observed when connecting Motor Modules Chassis-2 in parallel:

- Up to 6 identical Motor Modules Chassis-2 can be connected in parallel.
- Parallel connection can only be implemented using one common Control Unit. For more than 4 power units, these must be distributed as symmetrically as possible between at least two DRIVE-CLiQ ports (e.g. 3x 2 Motor Modules Chassis-2 in series, or a minimum of 2x 3 Motor Modules Chassis-2 in series).
- The motor supply cables must have the same length (symmetrical design).
- The Motor Modules Chassis-2 must be supplied from a shared DC link.
- For motors with a single winding system, supply cables with a minimum length or motor reactors must be used. The cable lengths are listed in the following tables.
- For motors with multi-winding systems, carefully observe the notes provided in the Low Voltage Engineering Manual.
- A derating factor of 5% must be taken into consideration, regardless of the number of Motor Modules Chassis-2 connected in parallel.

Note

Different power units cannot be connected in parallel.

It is only possible to connect power units in parallel if all power units have the same hardware version.

It is not possible to connect Motor Modules (Article No. 6SL3320-1Txxx-xAAx) and Motor Modules Chassis-2 (Article No. 6SL3321-1Txxx-xAA0) in parallel.

Minimum cable lengths for parallel connection and connection to a motor with a single-winding system

Note

Minimum cable lengths

The minimum cable lengths specified in the tables below must be observed when two or more Motor Modules Chassis-2 are connected in parallel and there is a connection to a motor with a single-winding system. If the cable length required for the application cannot be achieved, a motor reactor must be provided.

Table 6- 41 Motor Modules Chassis-2, 510 ... 720 V DC (line voltage 3 AC 380 ... 480 V)

Article number	Type rating [kW]	Output current [A]	Minimum cable length [m]
6SL3321-1TE36-6AA0	315	655	13
6SL3321-1TE37-4AA0	355	740	12
6SL3321-1TE38-1AA0	400	810	10
6SL3321-1TE38-8AA0	450	910	9
6SL3321-1TE41-0AA0	500	975	8
6SL3321-1TE41-1AA0	560	1075	8
6SL3321-1TE41-2AA0	630	1200	8
6SL3321-1TE41-3AA0	710	1325	8
6SL3321-1TE41-5AA0	800	1495	8

DC link components

7.1 Braking Module

7.1.1 Description

A Braking Module and an external braking resistor are required to bring drives to a controlled standstill in the event of a power failure (e.g. emergency retraction or EMERGENCY STOP category 1) or limit the DC-link voltage if the generator is operated for a short period of time, for example because there is no regenerative feedback capability into the supply network when a Basic Line Module is used. The Braking Module contains the power electronics and the associated control.

During operation the DC-link energy is converted into heat loss in an external braking resistor outside of the control cabinet. Braking Modules function autonomously. Parallel operation of several braking modules is possible. In this case, each Braking Module must have its own braking resistor.

Up to 3 slots are available depending on the size of the Line Module or Motor Module:

Frame sizes FB, GB, GD, FX, GX:

1 mounting location
2 mounting locations
Frame size JX:

3 mounting locations
Frame size FS2, FS4:

Installation not possible

Note

No installation in Motor Modules Chassis-2

It is not permissible to install the Braking Modules in a Motor Module Chassis-2.



Figure 7-1 Braking Module

Layout

The Braking Module in the chassis format is inserted in a mounting location inside the Line Module or Motor Module, whose fan force cools it. The supply voltage for the electronics is drawn from the DC link. The Braking Module is connected to the DC link by means of the busbar sets and flexible cables, which are supplied as standard.

The activation threshold of the Braking Module can be adjusted by means of a DIP switch. The braking power values specified in the technical specifications apply to the upper activation threshold.

The Braking Module has as standard, the following interfaces:

- The DC link is connected through busbars and flexible cables
- Connecting terminal for external braking resistor
- 1 digital input (inhibit Braking Module with high signal / acknowledge error with negative edge high-low)
- 1 digital output (Braking Module inhibited)
- 1 DIP switch for adjusting the activation threshold

Note

Installing a Braking Module of frame size GX in a Basic Line Module of frame size GB or GD

To install a frame size GX Braking Module in a frame size GB or GD Basic Line Module a cable harness set is required, which is available under Article number 6SL3366-2NG00-0AA0.

7.1.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

MARNING

Fire and device damage as a result of ground fault/short-circuit

Inadequate installation of the cables to the braking resistor can result in a ground fault/short-circuit and place persons at risk as a result of the associated smoke and fire.

- Comply with local installation regulations that enable this fault to be ruled out.
- · Protect the cables from mechanical damage.
- In addition, apply one of the following measures:
 - Use cables with double insulation.
 - Maintain adequate clearance, e.g. by using spacers.
 - Route the cables in separate cable ducts or pipes.

/ WARNING

Fire due to overheating when the total length of the connecting cables is exceeded

Excessively long Braking Module connection cables can cause components to overheat with the associated risk of fire and smoke.

• The Braking Module connecting cables may not be longer than 100 m.

NOTICE

Damage through the use of non-released braking resistors

Braking resistors can be damaged when using braking resistors other than those specified in this Manual.

• Only use braking resistors released by Siemens.

7.1.3 Interface description

7.1.3.1 Braking Module for frame sizes FX, FB




Figure 7-2 Braking Module for Active Line Module / Motor Module, frame size FX and for Basic Line Module, frame size FB

Note

Common connection for the R1 and DCPA

With this Braking Module, the R1 and DCPA interfaces use the same connection.






Figure 7-3 Braking Module for Smart Line Module / Active Line Module / Motor Module, frame size GX and for Basic Line Module, frame size GB, GD

Note

Common connection for the R1 and DCPA

With this Braking Module, the R1 and DCPA interfaces use the same connection.

7.1.3.3 Braking Module for frame sizes HX, JX




Figure 7-4 Braking Module for Smart Line Module / Active Line Module / Motor Module, frame sizes HX / JX

7.1.3.4 Connection example




Figure 7-5 Connection example for Braking Module

7.1.3.5 Braking resistor connection

Table 7- 1 Braking resistor connection

Terminal	Designation			
R1	Braking resistor connection R+			
R2	Braking resistor connection R-			
Recommen	Recommended conductor cross-sections: for 25/125 kW: 35 mm², for 50/250 kW: 50 mm²			

7.1.3.6 X21 digital inputs/outputs

Table 7-2 X21 terminal strip

	Terminal	Designation 1)	Technical specifications
Ħ	1	Shield	Shield connection for terminals 2 6
⊠ 2	2	0 V	High level: +15 30 V
Щ۵	3	DI inhibit input	Current drawn: 2 15 mA
			Low level: -3 5 V
₩°	4	0 V	High signal: No fault
	5	DO fault output	Low signal: Fault present
		·	Voltage: 24 VDC Load current: 0.5 0.6 A
	_		
	6 +24 V		Voltage: +18 30 V Typical current consumption (intrinsic current consumption): 10 mA at 24 V DC
Max. conne	ectable cross	-section 1.5 mm ²	

¹⁾ DI: Digital input; DO: Digital output

Note

Position of the terminals

The position of the individual terminals of terminal strip X21 on the Braking Module are as follows when the module is installed: Terminal "1" is at the back, terminal "6" is at the front.

Note

Signal characteristics of terminal X21.3

Applying a high signal to terminal X21.3 inhibits the Braking Module. On a falling edge, pending error signals are acknowledged.

Note

The Braking Module requires a DC link voltage so that the "No fault" message can be issued correctly.

Note

Notes on setting

You will find setting instructions for wiring the signals in the SINAMICS S120 Function Manual.

7.1.3.7 S1 Threshold switch

The response threshold at which the Braking Module is activated and the DC-link voltage generated during braking are specified in the following table.



/ WARNING

Electric shock when the threshold switch switches

Operating the threshold switch when a voltage is present can cause death or serious injury.

• Only use the threshold switch when the Basic Line, Smart Line, Active Line, or Motor Module are switched off and the DC link capacitors are discharged.

Table 7-3 Response thresholds of the Braking Modules

Voltage	Response threshold	Switch position	Remark
3 AC 380	673 V	1	774 V is the default factory setting. For line voltages of
480 V	774 V	2	between 3 AC 380 V and 400 V, the response threshold can be set to 673 V to reduce the voltage stress on the motor and converter. This does, however, reduce the possible braking power with the square of the voltage $(673/774)^2 = 0.75$.
			The maximum possible braking power is therefore 75%.
3 AC 500	841 V	1	967 V is the default factory setting. With a supply voltage
600 V	967 V	2	of 3 AC 500 V, the response threshold can be set to 841 V to reduce the voltage stress on the motor and converter. This does, however, reduce the possible braking power with the square of the voltage $(841/967)^2 = 0.75$.
			The maximum possible braking power is therefore 75%.
3 AC 660	1070 V	1	1158 V is the default factory setting. With a supply volt-
690 V	1158 V	2	age of 3 AC 660 V, the response threshold can be set to 1070 V to reduce the voltage stress on the motor and converter. This does, however, reduce the possible braking power with the square of the voltage $(1070/1158)^2 = 0.85$.
			The maximum possible braking power is therefore 85%.

Note

Positions of the threshold switches

The switch positions of the threshold switches of the Braking Modules are positioned on the panel as follows:

- Braking Modules for frame sizes FX, FB, GX, GB, GD: Position "1" is at the top; position "2" is at the bottom
- Braking Modules for frame sizes HX and JX: Position "1" is at the back; position "2" is at the front

Note

"Overvoltage" fault

Even when the response threshold is set to a low value, the DC-link voltage can still reach the maximum voltage value (hardware shutdown threshold), thus triggering the "Overvoltage" fault. This can occur, for example, in cases where there is too much regenerative energy for the available braking power.

To prevent the DC-link voltage from exceeding the threshold, the Vdc-max controller must be enabled (p1240) and the device supply voltage set accordingly (p0210).

7.1.4 Installation

7.1.4.1 Installing the Braking Module in an Active Line Module / Motor Module, frame size FX




Figure 7-6 Installing the Braking Module in an Active Line Module / Motor Module, frame size FX – steps 1 - 3




Figure 7-7 Installing the Braking Module in an Active Line Module / Motor Module, frame size FX – steps 4 - 7

Installing the Braking Module

The steps for the installation procedure are numbered in accordance with the diagrams in front of them.

- 1. Unscrew the two M6 screws from the front cover and lift off the cover.
- 2. Unscrew the two screws from the upper cover plate.

Loosen the M6 nut on the left

Remove the left cover

3. Unscrew the four screws from the upper cover plate.

Unscrew the three screws from the rear cut-out sections

Remove the top covers.

4. Unscrew the three screws of the blanking plate.

Remove the plate.

- 5. Insert the Braking Module where the cover used to be and secure it using the three screws (from step 4).
- 6. Attach the adapter bar to the DCNA using a nut, so that the busbar cannot be twisted. For this purpose, a small bolt is attached to the adapter bar, which must be located on the lower side of the DCNA connection.
- 7. Secure the connecting cable to the DC link with two screws (Braking Module connection) and two nuts (DC-link connection).

Carry out the subsequent steps in reverse order from steps 1 - 3.

An opening above the connections for the braking resistor (R1, R2) is provided in the cover for connecting the cable to the braking resistor.

Note

Pay attention to the tightening torques

7.1.4.2 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size GX




Figure 7-8 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size GX – steps 1 - 3




Figure 7-9 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size GX – steps 4 - 6

Installing the Braking Module

The steps for the installation procedure are numbered in accordance with the diagrams in front of them.

- 1. Unscrew the two M6 screws from the front cover and lift off the cover.
- 2. Unscrew the two screws from the upper cover plate.

Loosen the M6 nut on the left.

Remove the left cover

3. Unscrew the four screws from the upper cover plate.

Unscrew the three screws from the rear cut-out sections.

Remove the top covers.

4. Unscrew the three screws of the blanking plate.

Remove the plate.

- 5. Insert the Braking Module where the cover used to be and secure it using the three screws (from step 4).
- 6. Secure the connecting cable to the DC link with two screws (Braking Module connection) and two nuts (DC-link connection).

Carry out the subsequent steps in reverse order from steps 1 - 3.

An opening above the connections for the braking resistor (R1, R2) is provided in the cover for connecting the cable to the braking resistor.

Note

Pay attention to the tightening torques

7.1.4.3 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size HX




Figure 7-10 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size HX

Installing the Braking Module

The steps for the installation procedure are numbered in accordance with the diagram.

- 1. Insert the Braking Module.
- 2. Tighten the 4 retaining screws for the Braking Module.
- 3. Secure the connection clip to the DC link (DCPA/DCNA) with two screws (Braking Module connection) and two nuts (DC-link connection).

Note

Pay attention to the tightening torques

7.1.4.4 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size JX




Figure 7-11 Installing the Braking Module in a Smart Line Module / Active Line Module / Motor Module, frame size JX


Installing the Braking Module

The steps for the installation procedure are numbered in accordance with the diagram.

- 1. Insert the Braking Module.
- 2. Tighten the four retaining screws for the Braking Module.
- 3. Secure the connection clip to the DC link (DCPA/DCNA) with two screws (Braking Module connection) and two nuts (DC-link connection).

Note

Pay attention to the tightening torques



7.1.4.5 Installing the Braking Module in a Basic Line Module, frame size FB

Figure 7-12 Installing the Braking Module in a Basic Line Module, frame size FB

Installing the Braking Module

The steps for the installation procedure are numbered in accordance with the diagram.

- Unscrew the three screws of the blanking plate.
 Remove the plate.
- 2. Insert the Braking Module where the cover used to be and secure it using the three screws (from step 1).
- 3. Attach the adapter bar to the DCNA using a nut, so that the busbar cannot be twisted. For this purpose, a small bolt is attached to the adapter bar, which must be located on the lower side of the DCNA connection.
- 4. Secure the connecting cable to the DC link with two screws (Braking Module connection) and two nuts (DC-link connection).

Note

Pay attention to the tightening torques

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

7.1.4.6 Installing the Braking Module in a Basic Line Module, frame size GB, GD




Figure 7-13 Installing the Braking Module in a Basic Line Module, frame size GB, GD

Installing the Braking Module

Note

To install a frame size GX Braking Module in a frame size GB or GD Basic Line Module a cable harness set is required, which is available under Article number 6SL3366-2NG00-0AA0.

The steps for the installation procedure are numbered in accordance with the diagram.

- Unscrew the three screws of the blanking plate.
 Remove the plate.
- 2. Insert the Braking Module where the cover used to be and secure it using the three screws (from step 1).
- 3. Use the connecting cable in the cable harness set (Article number 6SL3366-2NG00-0AA0).
- 4. Secure the connecting cable to the DC link with two screws (Braking Module connection) and two nuts (DC-link connection).

Note

Pay attention to the tightening torques

7.1.5 Technical specifications

Table 7-4 Technical data, Braking Modules, 3 AC 380 V ... 480 V

Braking Module 6SL3300-	1AE31-3AA0	1AE32-5AA0	1AE32-5BA0
Suitable for installation in:			
Smart Line Module / Active Line Module / Motor Module, frame size	FX	GX	HX / JX
Basic Line Module, frame size	FB	GB, GD	
PDB power (rated power)	25 kW	50 kW	50 kW
P ₁₅ power (peak power)	125 kW	250 kW	250 kW
P ₂₀ power	100 kW	200 kW	200 kW
P ₄₀ power	50 kW	100 kW	100 kW
Variable response thresholds	774 V (673 V)		
Digital input			
Voltage	-3 30 V		
Low level (an open digital input is interpreted as "low")	-3 5 V		
High level	15 30 V		
Current consumption (typical at 24 VDC)	10 mA		
Max. connectable cross-section	1.5 mm²		
Digital output (continuously short-circuit p	proof)		
Voltage	24 VDC		
Max. load current of the digital output	500 mA		
Max. connectable cross-section	1.5 mm²		
R1/R2 connection	M8 screw	M8 screw	M8 screw
Max. conductor cross-section R1/R2	35 mm²	50 mm ²	50 mm²
Weight, approx.	3.6 kg	7.3 kg	7.5 kg

Table 7-5 Technical data, Braking Modules, 3 AC 500 V ... 600 V

Braking Module 6SL3300-	1AF31-3AA0	1AF32-5AA0	1AF32-5BA0
Suitable for installation in:			
Smart Line Module / Active Line Module / Motor Module, frame size	FX	GX	HX / JX
Basic Line Module, frame size	FB	GB, GD	
PDB power (rated power)	25 kW	50 kW	50 kW
P ₁₅ power (peak power)	125 kW	250 kW	250 kW
P ₂₀ power	100 kW	200 kW	200 kW
P ₄₀ power	50 kW	100 kW	100 kW
Variable response thresholds	967 V (841 V)		
Digital input			
Voltage	-3 30 V		
Low level (an open digital input is interpreted as "low")	-3 5 V		
High level	15 30 V		
Current consumption (typical at 24 VDC)	10 mA		
Max. connectable cross-section	1.5 mm²		
Digital output (continuously short-circuit p	roof)		
Voltage	24 VDC		
Max. load current of the digital output	500 mA		
Max. connectable cross-section	1.5 mm²		
R1/R2 connection	M8 screw	M8 screw	M8 screw
Max. conductor cross-section R1/R2	35 mm²	50 mm ²	50 mm²
Weight, approx.	3.6 kg	7.3 kg	7.5 kg

Table 7- 6 Technical data, Braking Modules, 3 AC 660 V ... 690 V

Braking Module 6SL3300-	1AH31-3AA0	1AH32-5AA0	1AH32-5BA0
Suitable for installation in:			
Smart Line Module / Active Line Module / Motor Module, frame size	FX	GX	HX / JX
Basic Line Module, frame size	FB	GB, GD	
PDB power (rated power)	25 kW	50 kW	50 kW
P ₁₅ power (peak power)	125 kW	250 kW	250 kW
P ₂₀ power	100 kW	200 kW	200 kW
P ₄₀ power	50 kW	100 kW	100 kW
Variable response thresholds	1158 V (1070 V)		
Digital input			
Voltage	-3 30 V		
Low level (an open digital input is interpreted as "low")		-3 5 V	
High level	15 30 V		
Current consumption (typical at 24 VDC)	10 mA		
Max. connectable cross-section	1.5 mm ²		
Digital output (continuously short-circuit p	proof)		
Voltage	24 VDC		
Max. load current of the digital output	500 mA		
Max. connectable cross-section	1.5 mm²		
R1/R2 connection	M8 screw	M8 screw	M8 screw
Max. conductor cross-section R1/R2	35 mm²	50 mm ²	50 mm²
Weight, approx.	3.6 kg	7.3 kg	7.5 kg

7.2 Braking resistors

7.2.1 Description

The excess energy of the DC link is dissipated via the braking resistor.

The braking resistor is connected to a Braking Module. The braking resistor is positioned outside the cabinet or switchgear room. This enables the heat loss from the Line Modules or Motor Modules to be dissipated. This reduces the level of air conditioning required.

Resistors with rated powers of 25 kW and 50 kW are available.

Greater outputs can be implemented by connecting Braking Modules and braking resistors in parallel. In this case, the Braking Modules are installed in the air duct of the Line Modules and Motor Modules. Depending on the size of the respective module, up to three mounting locations are available.

Since the braking resistors can be used in converters with a wide voltage range, the voltage can be adjusted (for example, to reduce the voltage stress on the motor and converter) by setting the response thresholds on the Braking Module.

A thermostatic switch monitors the braking resistor for overtemperature and issues a signal on a floating contact if the limit value is exceeded.

7.2.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

! WARNING

Fire due to overheating when the total length of the connecting cables is exceeded

Excessively long Braking Module connection cables can cause components to overheat with the associated risk of fire and smoke.

• The Braking Module connecting cables may not be longer than 100 m.

MARNING

Fire due to overheating because of inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. This can also result in increased failures and reduced service lives of braking resistors.

• It is essential that you maintain a ventilation clearance of 200 mm on all sides of the component with ventilation grilles.

! WARNING

Fire and device damage as a result of ground fault/short-circuit

Inadequate installation of the cables to the braking resistor can result in a ground fault/short-circuit and place persons at risk as a result of the associated smoke and fire.

- Comply with local installation regulations that enable this fault to be ruled out.
- Protect the cables from mechanical damage.
- In addition, apply one of the following measures:
 - Use cables with double insulation.
 - Maintain adequate clearance, e.g. by using spacers.
 - Lay the cables in separate cable ducts or conduits.

MARNING

Risk of fire as a result of braking resistor thermal power loss

A braking resistor which is not mounted properly can cause components to overheat with the associated risk of fire and development of smoke.

- Only mount braking resistors on a baseplate/floor.
- Mount the braking resistors so that they are in the vertical position and freestanding.
 Sufficient space must be available for dissipating the energy converted by the braking resistor.
- Maintain sufficient clearance to objects that can burn.
- Do not place any objects on or above the braking resistor.

CAUTION

Burns resulting from high surface temperature of the braking resistor

The braking resistor can become very hot. You can get seriously burnt when touching the surface.

Mount the braking resistors so that contact is not possible. If this is not possible, attach a
clearly visible and understandable warning notice at hazardous positions.

NOTICE

Damage to braking resistor due to ingress of water

Water penetration may damage the braking resistor.

• For outdoor installations, a hood must be provided to protect it from precipitation in accordance with degree of protection IP20.

Note

Braking resistor/fire alarm sensor interaction

If a braking resistor is placed underneath a fire alarm sensor, then the heat produced may trigger the fire alarm sensor.

7.2.3 Dimension drawing




Figure 7-14 Dimension drawing braking resistor 25 kW / 125 kW




Figure 7-15 Dimension drawing for 50 kW / 250 kW braking resistor




Figure 7-16 Fixing dimensions of the braking resistors

7.2.4 Electrical connection

Recommended cable cross-sections:

For 25/125 kW: 35 mm²
 For 50/250 kW: 50 mm²

Thermostatic switch

A thermostatic switch is installed to protect the braking resistor against overload. Its floating contacts must be integrated in the fault chain on the line side.

Table 7-7 Thermostatic switch connection

Terminal	Function	Technical specifications
T1	Thermostatic switch connection	Voltage: 240 VAC
T2	Thermostatic switch connection	Load current: Max. 10 A

Max. connectable cross-section: 2.5 mm²

7.2.5 Technical data

Table 7-8 Technical data, braking resistors, 380 V ... 480 V 3 AC

Article number	Unit	6SL3000-1BE31-3AA0	6SL3000-1BE32-5AA0
Pdb (rated power)	kW	25	50
P ₁₅ (peak power)	kW	125	250
Max. current	Α	189	378
Resistance	Ω	4.4 (± 7.5 %)	2.2 (± 7.5 %)
Cable entry		via M50 cable gland	via M50 cable gland
Power connection		via M8 bolt-type terminal	via M10 bolt-type terminal
Max. connectable cable cross-section	mm²	50	70
Degree of protection		IP20	IP20
Width x height x depth	mm	740 x 605 x 485	810 x 1325 x 485
Weight, approx.	kg	50	120

Table 7-9 Technical data, braking resistors, 500 V ... 600 V 3 AC

Article number	Unit	6SL3000-1BF31-3AA0	6SL3000-1BF32-5AA0
Pdb (rated power)	kW	25	50
P ₁₅ (peak power)	kW	125	250
Max. current	Α	153	306
Resistance	Ω	6.8 (± 7.5 %)	3.4 (± 7.5 %)
Cable entry		via M50 cable gland	via M50 cable gland
Power connection		via M8 bolt-type terminal	via M10 bolt-type terminal
Max. connectable cable cross-section	mm²	50	70
Degree of protection		IP20	IP20
Width x height x depth	mm	740 x 605 x 485	810 x 1325 x 485
Weight, approx.	kg	50	120

Table 7- 10 Technical data, braking resistors, 660 V ... 690 V 3 AC

Article number	Unit	6SL3000-1BH31-3AA0	6SL3000-1BH32-5AA0
PDB (rated power)	kW	25	50
P ₁₅ (peak power)	kW	125	250
Max. current	Α	125	255
Resistance	Ω	9.8 (± 7.5 %)	4.9 (± 7.5 %)
Cable entry		via M50 cable gland	via M50 cable gland
Power connection		via M8 bolt-type terminal	via M10 bolt-type terminal
Max. connectable cable cross-section	mm²	50	70
Degree of protection		IP20	IP20
Width x height x depth	mm	740 x 605 x 485	810 x 1325 x 485
Weight, approx.	kg	50	120

Duty cycle




Figure 7-17 Duty cycle for braking resistors

7.2 Braking resistors

Motor-side power components

8

8.1 Sine-wave filter

8.1.1 Description

If a sine-wave filter is connected at the Motor Module output, the voltage between the motor terminals is virtually sinusoidal. This reduces the voltage load on the motor windings and prevents motor noise induced by the pulse frequency.

Sine-wave filters are available up to a converter type power rating of 250 kW (without consideration for derating).

The pulse frequency of the Motor Modules must be set to 4 kHz for the sine-wave filter. As a consequence, the output current of the Motor Module is reduced.

When commissioning the drive, sine-wave filters must be activated using parameter p0230 = 3 so that the required parameter changes in conjunction with the sine-wave filter are automatically set (e.g. a pulse frequency of 4 kHz).

When a sine-wave filter is used, the available output voltage decreases by 15%.




Figure 8-1 Sine-wave filters

8.1.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- · When assessing the risk, take into account remaining risks.

! WARNING

Fire due to overheating because of inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. Furthermore, an increased number of failures and shorter service life of the components can occur.

Maintain 100 mm ventilation clearances above and to the side of the component.

ACAUTION

Burns resulting from high surface temperature of the sine-wave filter

The surface temperature of the sine-wave filters can exceed 80 °C. You can get seriously burnt when touching the surface.

Mount the sine-wave filter so that it cannot be touched. If this is not possible, attach a
clearly visible and understandable warning notice at hazardous positions.

NOTICE

Sine-wave filter damage due to interchanged connections

Interchanging the input and output connections will damage the sine-wave filter.

- Connect the incoming cable from the Motor Module to 1U1, 1V1, 1W1.
- Connect the outgoing cable to the load at 1U2, 1V2, 1W2.

NOTICE

Damage to the Motor Module by using components that have not been released

When using components that have not been released, damage or malfunctions can occur at the devices or the system itself.

Only use sine-wave filters that SIEMENS has released for SINAMICS.

NOTICE

Risk of damaging sine-wave filter by exceeding the maximum output frequency

The maximum permissible output frequency when sine-wave filters are used is 150 Hz. The sine-wave filter can be damaged if the output frequency is exceeded.

• Operate the sine-wave filter with a maximum output frequency of 150 Hz.

NOTICE

Damage to the sine-wave filter if it is not activated during commissioning

The sine-wave filter may be damaged if it is not activated during commissioning.

• Activate the sine-wave filter during commissioning via parameter p0230 = 3.

NOTICE

Damage to the sine-wave filter if a motor is not connected

Sine-wave filters, which are operated without a motor being connected, can be damaged or destroyed.

 Never operate a sine-wave filter connected to the Motor Module without a connected motor.

Note

Cable lengths

Keep the connecting cables to the Motor Module as short as possible (max. 5 m).

8.1.3 Dimension drawing




Figure 8-2 Dimension drawing, sine-wave filter

6SL3000-2CE34-1AA0 2CE32-3AA0 2CE32-8AA0 2CE33-3AA0 В Н Т h1 h2 n1 ¹⁾ n2 1) n3 ¹⁾ n4 d1 d2 d3

Table 8-1 Dimensions of the sine-wave filter (all values in mm)

8.1.4 Technical data

Table 8- 2 Technical data of sine-wave filters 380 V ... 480 V 3 AC

Article number	6SL3000-	2CE32-3AA0	2CE32-3AA0	2CE32-8AA0	2CE33-3AA0	2CE34-1AA0
Suitable for Motor Module	6SL3320-	1TE32-1AA3	1TE32-6AA3	1TE33-1AA3	1TE33-8AA3	1TE35-0AA3
Rated current (type rating) of the Motor Module with sine- wave filter at a pulse frequen- cy of 4 kHz		170 A (90 kW)	215 A (110 kW)	270 A (132 kW)	330 A (160 kW)	380 A (200 kW)
Rated current	Α	225	225	276	333	408
Maximum output frequency	Hz	150	150	150	150	150
Power loss - at 50 Hz - at 150 Hz	kW kW	0.35 0.6	0.35 0.6	0.4 0.69	0.245 0.53	0.38 0.7
Connections - to the Motor Module - load		M10 connecting lugs M10 connecting lugs				
Max. permissible cable length between sine-wave filter and motor	m	300 (shielded) 450 (unshielded)				
Degree of protection		IP00	IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	620 300 320	620 300 320	620 300 320	620 370 360	620 370 360
Weight	kg	124	124	127	136	198

¹⁾ The lengths n1, n2 and n3 correspond to the drill hole spacing

8.2 Motor reactors

8.2.1 Description

Motor reactors reduce the voltage stress on the motor windings by reducing the voltage gradients at the motor terminals that occur when motors are fed from drive converters. At the same time, the capacitive charge/discharge currents that also occur on the output of the Motor Module when long motor cables are used are reduced.

Table 8-3 Maximum pulse frequency when using a motor reactor with devices with a rated pulse frequency of 2 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 2 kHz [A]	Maximum pulse frequency when using a motor reactor
	L	ine voltage 3 AC 380 480	V
1TE32-1AA3	110	210	4 kHz
1TE32-6AA3	132	260	4 kHz
1TE33-1AA3	160	310	4 kHz
1TE33-8AA3	200	380	4 kHz
1TE35-0AA3	250	490	4 kHz
1TE41-4AS3	800	1330	2.5 kHz

Table 8- 4 Maximum pulse frequency when using a motor reactor with devices with a rated pulse frequency of 1.25 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 1.25 kHz [A]	Maximum pulse frequency when using a motor reactor
	L	ine voltage 3 AC 380 480	V
1TE36-1AA3	315	605	2.5 kHz
1TE37-5AA3	400	745	2.5 kHz
1TE38-4AA3	450	840	2.5 kHz
1TE41-0AA3	560	985	2.5 kHz
1TE41-2AA3	710	1260	2.5 kHz
1TE41-4AA3	800	1405	2.5 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 1.25 kHz [A]	Maximum pulse frequency when using a motor reactor
	L	ine voltage 3 AC 500 690	V
1TG28-5AA3	75	85	2.5 kHz
1TG31-0AA3	90	100	2.5 kHz
1TG31-2AA3	110	120	2.5 kHz
1TG31-5AA3	132	150	2.5 kHz
1TG31-8AA3	160	175	2.5 kHz
1TG32-2AA3	200	215	2.5 kHz
1TG32-6AA3	250	260	2.5 kHz
1TG33-3AA3	315	330	2.5 kHz
1TG34-1AA3	400	410	2.5 kHz
1TG34-7AA3	450	465	2.5 kHz
1TG35-8AA3	560	575	2.5 kHz
1TG37-4AA3	710	735	2.5 kHz
1TG38-1AA3	800	810	2.5 kHz
1TG38-8AA3	900	910	2.5 kHz
1TG41-0AA3	1000	1025	2.5 kHz
1TG41-3AA3	1200	1270	2.5 kHz

Table 8-5 Maximum pulse frequency when using a motor reactor with devices with a rated pulse frequency of 2.5 kHz

Article No. of the Motor Module Chassis-2 6SL3321	Type rating [kW]	Output current for a pulse frequency of 2.5 kHz [A]	Maximum pulse frequency when using a motor reactor
	L	ine voltage 3 AC 380 480	V
1TE36-6AA0	315	655	2.5 kHz
1TE37-4AA0	355	740	2.5 kHz
1TE38-1AA0	400	810	2.5 kHz
1TE38-8AA0	450	910	2.5 kHz
1TE41-0AA0	500	975	2.5 kHz
1TE41-1AA0	560	1075	2.5 kHz
1TE41-2AA0	630	1200	2.5 kHz
1TE41-3AA0	710	1325	2.5 kHz
1TE41-5AA0	800	1495	2.5 kHz

8.2.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

MWARNING

Fire due to overheating because of inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. Furthermore, an increased number of failures and shorter service life of the components can occur.

Maintain 100 mm ventilation clearances above and to the side of the component.

ACAUTION

Burns resulting from high surface temperature of the motor reactor

The surface temperature of the motor reactors can exceed 80 °C. You can get seriously burnt when touching the surface.

 Mount the motor reactor so that it cannot be touched. If this is not possible, attach a clearly visible and understandable warning notice at hazardous positions.

NOTICE

Damage to the Motor Module by using components that have not been released

When using components that have not been released, damage or malfunctions can occur at the devices or the system itself.

Only use motor reactors that SIEMENS has released for SINAMICS.

NOTICE

Risk of damaging the motor reactor by exceeding the maximum output frequency

The maximum permissible output frequency when a motor reactor is used is 150 Hz. The motor reactor can be damaged if the output frequency is exceeded.

• Operate the motor reactor with a maximum output frequency of 150 Hz.

NOTICE

Damage to the motor reactor if the maximum pulse frequency is exceeded

The maximum permissible pulse frequency when a motor reactor is used is 2.5 kHz or 4 kHz. The motor reactor can be damaged if the pulse frequency is exceeded.

• When using the motor reactor, operate the Motor Module with a maximum pulse frequency of 2.5 kHz or 4 kHz.

NOTICE

Damage to the motor reactor if it is not activated during commissioning

The motor reactor may be damaged if it is not activated during commissioning.

• Activate the motor reactor during commissioning via parameter p0230 = 1.

Note

Cable lengths

Keep the connecting cables to the Motor Module as short as possible (max. 5 m).

8.2.3 Dimension drawing




Figure 8-3 Dimension drawing, motor reactor

Table 8- 6 Dimensions of motor reactors, 3 AC 380 V ... 480 V, Part 1 (all specifications in mm)

6SL3000-	2BE32-1AA0	2BE32-6AA0	2BE33-2AA0	2BE33-8AA0	2BE35-0AA0
Connection type	Type 1	Type 1	Type 1	Type 1	Type 2
a2	25	25	25	25	30
a3	5	5	5	5	6
a4	12.5	12.5	12.5	12.5	15
a5	11	11	11	11	14
14	300	300	300	300	300
15	100	100	100	100	100
h1	-	-	-	-	-
h2	194	227	194	194	245
h3	60	60	60	60	60
h4	285	315	285	285	365
n1 ¹⁾	163	183	163	183	183
n2 ¹⁾	224	224	224	224	224
n3	257	277	257	277	277
n4	79	79	79	79	79
d3	M8	M8	M8	M8	M8

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 8-7 Dimensions of motor reactors, 3 AC 380 V ... 480 V, Part 2 (all specifications in mm)

6SL3000-	2AE36-1AA0	2AE38-4AA0	2AE41-0AA0	2AE41-4AA0	2DE41-4DA0
Connection type	Type 1				
a2	40	40	40	60	60
a3	8	8	8	12	10
a4	20	20	20	17	19
a5	14	14	14	14	14 x 18
a6	=	-	-	22	26
a7	-	-	-	19	17
14	410	410	410	460	445
15	140	140	140	160	145
h1	392	392	392	392	-
h2	252	252	252	255	250
h3	120	120	120	120	121
h4	385	385	385	385	385
n1 ¹⁾	191	191	206	212	212
n2 ¹⁾	316	316	316	356	341
n3	292	292	302	326	312
n4	84.5	84.5	79.5	94.5	78
n5	30	30	-	-	-
d3	M10	M10	M10	M10	M12 (15 x 22)

¹⁾ Lengths n1 and n2 correspond to the distance between holes

8.2 Motor reactors

Table 8-8 Dimensions of motor reactors, 3 AC 500 V ... 690 V, Part 1 (all specifications in mm)

6SL3000-	2AH31-0AA0	2AH31-5AA0	2AH31-8AA0	2AH32-4AA0	2AH32-6AA0
Connection type	Type 1				
a2	25	25	25	25	25
a3	5	5	5	5	5
a4	12.5	12.5	12.5	12.5	12.5
a5	11	11	11	11	11
14	270	270	300	300	300
15	88	88	100	100	100
h1	-	-	-	-	-
h2	150	150	194	194	194
h3	60	60	60	60	60
h4	248	248	285	285	285
n1 ¹⁾	103	103	118	118	118
n2 ¹⁾	200	200	224	224	224
n3	200	200	212	212	212
n4	82	82	79	79	79
d3	M8	M8	M8	M8	M8

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 8-9 Dimensions of motor reactors, 3 AC 500 V ... 690 V, Part 2 (all specifications in mm)

6SL3000-	2AH33-6AA0	2AH34-5AA0	2AH34-7AA0	2AH35-8AA0	2AH38-1AA0
Connection type	Type 1				
a2	25	30	40	40	40
a3	5	6	8	8	8
a4	12.5	15	20	20	20
a5	11	14	14	14	14
14	300	350	410	410	410
15	100	120	140	140	140
h1	-	-	392	392	392
h2	194	235	252	252	252
h3	60	60	120	120	120
h4	285	330	385	385	385
n1 ¹⁾	118	138	141	141	183
n2 ¹⁾	224	264	316	316	316
n3	212	215	292	292	279
n4	79	63	134.5	134.5	79.5
n5	-	-	30	30	-
d3	M8	M8	M10	M10	M10

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 8- 10 Dimensions of motor reactors, 3 AC 500 V ... 690 V, Part 3 (all specifications in mm)

6SL3000-	2AH41-0AA0	2AH41-1AA0	2AH41-3AA0	
Connection type	Type 1	Type 1	Type 1	
a2	40	50	60	
a3	8	8	12	
a4	20	14	17	
a5	14	14	14	
a6	=	22	22	
a7	-	-	19	
14	410	410	460	
15	140	140	160	
h1	392	392	392	
h2	252	258	255	
h3	120	120	120	
h4	385	385	385	
n1 ¹⁾	183	206	182	
n2 ¹⁾	316	316	356	
n3	279	317	296	
n4	79.5	94.5	94.5	
d3	M10	M10	M10	

¹⁾ Lengths n1 and n2 correspond to the distance between holes

8.2.4 Technical data

Table 8-11 Technical data of motor reactors, 3 AC 380 V ... 480 V, Part 1

Article number	6SL3000-	2BE32-1AA0	2BE32-6AA0	2BE33-2AA0	2BE33-8AA0
Suitable for Motor Module	6SL3320-	1TE32-1AA3	1TE32-6AA3	1TE33-1AA3	1TE33-8AA3
Type rating of the Motor Module	kW	110	132	160	200
Rated current	Α	210	260	310	380
Power loss - at 50 Hz - at 150 Hz	kW kW	0.436 0.486	0.454 0.5	0.422 0.47	0.447 0.5
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M10 M10 M8	M10 M10 M8	M10 M10 M8	M10 M10 M8
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	300 285 257	300 315 277	300 285 257	300 285 277
Weight, approx.	kg	66	66	66	73

Table 8- 12 Technical data of motor reactors, 3 AC 380 ... 480 V, Part 2

Article number	6SL3000-	2BE35-0AA0	2AE36-1AA0	2AE38-4AA0	2AE38-4AA0
Suitable for Motor Module	6SL3320-	1TE35-0AA3	1TE36-1AA3	1TE37-5AA3	1TE38-4AA3
Type rating of the Motor Module	kW	250	315	400	450
Rated current	Α	490	605	840	840
Power loss - at 50 Hz - at 150 Hz	kW kW	0.448 0.5	0.798 0.9	0.75 0.84	0.834 0.943
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M12 M12 M8	M12 M12 M10	M12 M12 M10	M12 M12 M10
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	300 365 277	410 392 292	410 392 292	410 392 292
Weight, approx.	kg	100	130	140	140

Table 8- 13 Technical data of motor reactors, 3 AC 380 ... 480 V, Part 3

Article number	6SL3000-	2AE41-0AA0	2AE41-4AA0	2AE41-4AA0	2AE41-4AA0
Suitable for Motor Module	6SL3320-	1TE41-0AA3	1TE41-2AA3	1TE41-4AA3	1TE41-4AS3
Type rating of the Motor Module	kW	560	710	800	800
Rated current	Α	985	1405	1405	1405
Power loss - at 50 Hz - at 150 Hz	kW kW	0.939 1.062	0.81 0.9	0.946 1.054	0.946 1.054
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M12 M12 M10	2 x M12 2 x M12 M10	2 x M12 2 x M12 M10	2 x M12 2 x M12 M10
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	410 392 302	460 392 326	460 392 326	460 392 326
Weight, approx.	kg	146	179	179	179

Table 8- 14 Technical data of motor reactors 380 V ... 480 V 3 AC, Part 4

Article number	6SL3000-	2AE38-4AA0	2AE41-4AA0	2DE41-4DA0	
Matching Motor Module Chassis-2	6SL3321-	1TE36-6AA0 1TE37-4AA0 1TE38-1AA0	1TE38-8AA0	1TE41-0AA0 1TE41-1AA0 1TE41-2AA0 1TE41-3AA0 1TE41-5AA0	
Type rating of the Motor Module	kW	315 / 355 / 400	450	500 / 560 / 630 / 710 / 800	
Rated current	Α	840	1405	1405	
Power loss - at 50 Hz - at 150 Hz	kW kW	0.75 0.84	0.946 1.054	1.111 1.23	
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M12 M12 M10	2 x M12 2 x M12 M10	2 x M12 2 x M12 M6	
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m			450 (unshielded) 675 (unshielded)	
Degree of protection		IP00	IP00	IP00	
Dimensions Width Height Depth	mm mm mm	410 392 292	460 392 326	445 385 312	
Weight, approx.	kg	140	179	158	

8.2 Motor reactors

Table 8-15 Technical data of motor reactors, 3 AC 500 ... 690 V, Part 1

Article number	6SL3000-	2AH31-0AA0	2AH31-0AA0	2AH31-5AA0	2AH31-5AA0
Suitable for Motor Module	6SL3320-	1TG28-5AA3	1TG31-0AA3	1TG31-2AA3	1TG31-5AA3
Type rating of the Motor Module	kW	75	90	110	132
Rated current	Α	100	100	150	150
Power loss - at 50 Hz - at 150 Hz	kW kW	0.215 0.26	0.269 0.3	0.237 0.26	0.296 0.332
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M10 M10 M6	M10 M10 M6	M10 M10 M6	M10 M10 M6
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	270 248 200	270 248 200	270 248 200	270 248 200
Weight, approx.	kg	25	25	25.8	25.8

Table 8- 16 Technical data of motor reactors, 3 AC 500 ... 690 V, Part 2

Article number	6SL3000-	2AH31-8AA0	2AH32-4AA0	2AH32-6AA0	2AH33-6AA0
Suitable for Motor Module	6SL3320-	1TG31-8AA3	1TG32-2AA3	1TG32-6AA3	1TG33-3AA3
Type rating of the Motor Module	kW	160	200	250	315
Rated current	Α	175	215	260	330
Power loss - at 50 Hz - at 150 Hz	kW kW	0.357 0.403	0.376 0.425	0.389 0.441	0.4 0.454
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M10 M10 M6	M10 M10 M6	M10 M10 M6	M10 M10 M6
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	300 285 212	300 285 212	300 285 212	300 285 212
Weight, approx.	kg	34	34	40	46

Table 8- 17 Technical data of motor reactors, 3 AC 500 ... 690 V, Part 3

Article number	6SL3000-	2AH34-5AA0	2AH34-7AA0	2AH35-8AA0	2AH38-1AA0
Suitable for Motor Module	6SL3320-	1TG34-1AA3	1TG34-7AA3	1TG35-8AA3	1TG37-4AA3
Type rating of the Motor Module	kW	400	450	560	710
Rated current	Α	410	465	575	810
Power loss - at 50 Hz - at 150 Hz	kW kW	0.481 0.545	0.631 0.723	0.705 0.801	0.78 0.91
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M12 M12 M8	M12 M12 M8	M12 M12 M8	M12 M12 M8
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	350 330 215	410 392 292	410 392 292	410 392 279
Weight, approx.	kg	68	80	80	146

Table 8- 18 Technical data of motor reactors, 3 AC 500 ... 690 V, Part 4

Article number	6SL3000-	2AH38-1AA0	2AH41-0AA0	2AH41-1AA0	2AH41-3AA0
Suitable for Motor Module	6SL3320-	1TG38-1AA3	1TG38-8AA3	1TG41-0AA3	1TG41-3AA3
Type rating of the Motor Module	kW	800	900	1000	1200
Rated current	Α	810	910	1025	1270
Power loss - at 50 Hz - at 150 Hz	kW kW	0.877 1.003	0.851 0.965	0.927 1.052	0.862 0.952
Connections - To the Motor Module (1U1, 1V1, 1W1) - Load (1U2, 1V2, 1W2) - PE		M12 M12 M8	M12 M12 M8	M12 M12 M8	M12 M12 M8
Max. permissible cable length between motor reactor and motor - With one motor reactor - With two motor reactors in series	m m	300 (shielded) / 450 (unshielded) 525 (shielded) / 787 (unshielded)			
Degree of protection		IP00	IP00	IP00	IP00
Dimensions Width Height Depth	mm mm mm	410 392 279	410 392 279	410 392 317	460 392 296
Weight, approx.	kg	146	150	163	153

8.3 dv/dt filter plus Voltage Peak Limiter

8.3.1 Description

The dv/dt filter plus Voltage Peak Limiter comprises two components: the dv/dt reactor and the voltage-limiting network (Voltage Peak Limiter), which cuts of the voltage peaks and returns energy to the DC link. The dv/dt filters plus Voltage Peak Limiter must be used for motors for which the proof voltage of the insulation system is unknown or insufficient.

The dv/dt filter plus Voltage Peak Limiter limits the rate of voltage rise dv/dt to values $< 500 \text{ V/}\mu\text{s}$ and typical voltage peaks \hat{U}_{LL} for rated line voltages to the following values (for motor cable lengths of $\leq 150 \text{ m}$):

- < 1000 V at Uline < 575 V
- < 1250 V at $660 \text{ V} < U_{\text{line}} < 690 \text{ V}$.

Components

The article numbers of the individual components (dv/dt reactor and Voltage Peak Limiter) are listed in the following table:

Table 8- 19 dv/dt filter plus Voltage Peak Limiter, article numbers of the individual components

dv/dt filter plus Voltage Peak Lim- iter	dv/dt reactor	Voltage Peak Limiter
Li	ne voltage 3 AC 380 480 V	,
6SL3000-2DE32-6AA0	6SL3000-2DE32-6CA0	6SL3000-2DE32-6BA0
6SL3000-2DE35-0AA0	6SL3000-2DE35-0CA0	6SL3000-2DE35-0BA0
6SL3000-2DE38-4AA0	6SL3000-2DE38-4CA0	6SL3000-2DE38-4BA0
6SL3000-2DE41-4AA0	2 x 6SL3000-2DE41-4DA0	6SL3000-2DE41-4BA0
Lin	ne voltage 3 AC 500 690 V	,
6SL3000-2DH31-0AA0	6SL3000-2DH31-0CA0	6SL3000-2DH31-0BA0
6SL3000-2DH31-5AA0	6SL3000-2DH31-5CA0	6SL3000-2DH31-5BA0
6SL3000-2DH32-2AA0	6SL3000-2DH32-2CA0	6SL3000-2DH32-2BA0
6SL3000-2DH33-3AA0	6SL3000-2DH33-3CA0	6SL3000-2DH33-3BA0
6SL3000-2DH34-1AA0	6SL3000-2DH34-1CA0	6SL3000-2DH34-1BA0
6SL3000-2DH35-8AA0	6SL3000-2DH35-8CA0	6SL3000-2DH35-8BA0
6SL3000-2DH38-1AA0	2 x 6SL3000-2DH38-1DA0	6SL3000-2DH38-1BA0
6SL3000-2DH41-3AA0	2 x 6SL3000-2DH41-3DA0	6SL3000-2DH41-3BA0

Table 8- 20 Max. pulse frequency when a dv/dt filter is used in devices with a rated pulse frequency of 2 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 2 kHz [A]	Max. pulse frequency when a dv/dt filter is used						
	Line voltage 3 AC 380 480 V								
1TE32-1AA3	110	210	4 kHz						
1TE32-6AA3	132	260	4 kHz						
1TE33-1AA3	160	310	4 kHz						
1TE33-8AA3	200	380	4 kHz						
1TE35-0AA3	250	490	4 kHz						
1TE41-4AS3	800	1330	2.5 kHz						

Table 8- 21 Max. pulse frequency when a dv/dt filter is used in devices with a rated pulse frequency of 1.25 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 1.25 kHz [A]	Max. pulse frequency when a dv/dt filter is used				
Line voltage 3 AC 380 480 V							
1TE36-1AA3	315	605	2.5 kHz				
1TE37-5AA3	400	745	2.5 kHz				
1TE38-4AA3	450	840	2.5 kHz				
1TE41-0AA3	560	985	2.5 kHz				
1TE41-2AA3	710	1260	2.5 kHz				
1TE41-4AA3	800	1405	2.5 kHz				
	L	ine voltage 3 AC 500 690 \	V				
1TG28-5AA3	75	85	2.5 kHz				
1TG31-0AA3	90	100	2.5 kHz				
1TG31-2AA3	110	120	2.5 kHz				
1TG31-5AA3	132	150	2.5 kHz				
1TG31-8AA3	160	175	2.5 kHz				
1TG32-2AA3	200	215	2.5 kHz				
1TG32-6AA3	250	260	2.5 kHz				
1TG33-3AA3	315	330	2.5 kHz				
1TG34-1AA3	400	410	2.5 kHz				
1TG34-7AA3	450	465	2.5 kHz				
1TG35-8AA3	560	575	2.5 kHz				
1TG37-4AA3	710	735	2.5 kHz				
1TG38-1AA3	800	810 2.5 kHz					
1TG38-8AA3	900	910	2.5 kHz				
1TG41-0AA3	1000	1025	2.5 kHz				
1TG41-3AA3	1200	1270	2.5 kHz				

Table 8- 22 Max. pulse frequency when a dv/dt filter is used in units with a rated pulse frequency of 2.5 kHz

Article No. of the Motor Module Chassis-2 6SL3321	Type rating [kW]	Output current for a pulse frequency of 2.5 kHz [A]	Max. pulse frequency when a dv/dt filter is used			
	Line voltage 3 AC 380 480 V					
1TE36-6AA0	315	655	2.5 kHz			
1TE37-4AA0	355	740	2.5 kHz			
1TE38-1AA0	400	810	2.5 kHz			
1TE38-8AA0	450	910	2.5 kHz			
1TE41-0AA0	500	975	2.5 kHz			
1TE41-1AA0	560	1075	2.5 kHz			
1TE41-2AA0	630	1200	2.5 kHz			
1TE41-3AA0	710	1325	2.5 kHz			
1TE41-5AA0	800	1495	2.5 kHz			

8.3.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.



Fire due to overheating because of inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. Furthermore, an increased number of failures and shorter service life of the components can occur.

• Maintain 100 mm clearances above and below the components.



Burns resulting from high surface temperature of the dv/dt reactor

The surface temperature of the dv/dt reactors may exceed 80 °C. You can get seriously burnt when touching the surface.

• Mount the dV/dt reactor so that it cannot be touched. If this is not possible, attach a clearly visible and understandable warning notice at hazardous positions.

NOTICE

Damage to the Voltage Peak Limiter due to interchanged connections

The Voltage Peak Limiter will be damaged if the input and output connections are interchanged.

- Connect the incoming cable from the DC link of the Motor Module to DCPS, DCNS.
- Connect the incoming cable from the DC link of the Motor Module Chassis-2 to DCP, DCN.
- Connect the outgoing cable for the dV/dt reactor to 1U2, 1V2, 1W2.

NOTICE

Damage to the dV/dt filter by using components that have not been released

When using components that have not been released, damage or malfunctions can occur at the devices or the system itself.

• Only use dV/dt filters that SIEMENS has released for operation with SINAMICS.

NOTICE

Damage to the dV/dt filter by exceeding the maximum output frequency

The maximum permissible output frequency when using a dv/dt filter is 150 Hz. The dV/dt filter can be damaged if the output frequency is exceeded.

Operate the dv/dt filter with a maximum output frequency of 150 Hz.

NOTICE

Damage to the dV/dt filter by exceeding the maximum pulse frequency

The maximum permissible pulse frequency when using a dv/dt filter is 2.5 kHz or 4 kHz. The dV/dt filter can be damaged if the pulse frequency is exceeded.

• When using the dv/dt filter, operate the Motor Module with a maximum pulse frequency of 2.5 kHz or 4 kHz.

NOTICE

Damage to the dV/dt filter if it is not activated during commissioning

The dV/dt filter may be damaged if it is not activated during commissioning.

Activate the dv/dt filter during commissioning via parameter p0230 = 2.

NOTICE

Damage to the dV/dt filter if a motor is not connected

dV/dt filters which are operated without a motor being connected can be damaged or destroyed.

• Never operate a dV/dt filter connected to the Motor Module without a connected motor.

8.3 dv/dt filter plus Voltage Peak Limiter

Note

Cable lengths

Keep the connecting cables to the Motor Module as short as possible (max. 5 m).

8.3.3 Interface description




Figure 8-4 Interface overview, voltage peak limiter, type 1




Figure 8-5 Interface overview, voltage peak limiter, type 2




Figure 8-6 Interface overview, voltage peak limiter, type 3

8.3.4 Connecting the dv/dt filter plus Voltage Peak Limiter




Figure 8-7 Connecting a dV/dt filter plus voltage peak limiter for versions with one dV/dt reactor




Figure 8-8 Connecting a dV/dt filter plus voltage peak limiter for versions with two dV/dt reactors




Figure 8-9 Connecting a dv/dt filter with Voltage Peak Limiter for versions with two dv/dt reactors to a Motor Module Chassis-2

Cable cross-sections

Table 8- 23 Cable cross-sections for connections between the dV/dt filter plus voltage peak limiter and Motor Module

dv/dt filter plus Voltage Peak Limiter	Connection to the DC link (DCPS/DCNS) [mm²]	Connection between dv/dt reactor and Voltage Peak Limiter (1U2, 1V2, 1W2) [mm²]				
	Line voltage 3 AC 380 4	80 V				
6SL3000-2DE32-6AA0	35	10				
6SL3000-2DE35-0AA0	70	16				
6SL3000-2DE38-4AA0	2 x 50	50				
6SL3000-2DE41-4AA0	2 x 120	120				
	Line voltage 3 AC 500 690 V					
6SL3000-2DH31-0AA0	16	6				
6SL3000-2DH31-5AA0	16	6				
6SL3000-2DH32-2AA0	70	16				
6SL3000-2DH33-3AA0	70	16				
6SL3000-2DH34-1AA0	120	35				
6SL3000-2DH35-8AA0	120	35				
6SL3000-2DH38-1AA0	2 x 70	70				
6SL3000-2DH41-3AA0	2 x 120	120				

8.3 dv/dt filter plus Voltage Peak Limiter

Table 8- 24 Cable cross-sections for connections between the dv/dt filter plus Voltage Peak Limiter and Motor Module Chassis-2

dv/dt filter plus Voltage Peak Limiter	Connection to the DC link (DCP / DCN) [mm²]	Connection between dv/dt reactor and Voltage Peak Limiter (1U2, 1V2, 1W2) [mm²]		
Line voltage 3 AC 380 480 V				
6SL3000-2DE38-4AA0	2 x 50	50		
6SL3000-2DE41-4AA0	2 x 120	120		

MARNING

Fire and device damage as a result of ground fault/short-circuit

Inadequate installation of the cables to the Motor Module DC link can result in a ground fault/short-circuit and place persons at risk as a result of the associated smoke and fire.

- Comply with local installation regulations that enable this fault to be ruled out.
- Protect the cables from mechanical damage.
- In addition, apply one of the following measures:
 - Use cables with double insulation.
 - Maintain adequate clearance, e.g. by using spacers.
 - Lay the cables in separate cable ducts or conduits.

Note

Maximum cable lengths

The connections should be kept as short as possible.

The maximum cable length for the specified connections is 5 m in each case.

8.3.5 Dimension drawing, dv/dt reactor




Figure 8-10 Dimension drawing, dV/dt reactor

Table 8- 25 Dimensions of dV/dt reactor, 380 V ... 480 V 3 AC (all dimensions in mm)

6SL3000-	2DE32-6CA0	2DE35-0CA0	2DE38-4CA0	2DE41-4DA0	
a2	25	30	40	60	
a3	5	6	8	10	
a4	14	17	22	19	
a5	10.5 x 14	14 x 18	14 x 18	14 x 18	
a6	7	9	11	11	
a7	-	-	-	17	
a8	-	-	=	26	
14	410	460	460	445	
15	135	152.5	152.5	145	
hmax	370	370	385	385	
h2	258	240	280	250	
h3	76	83	78	121	
n1 ¹⁾	141	182	212	212	
n2 ¹⁾	316	356	356	341	
n3	229	275	312	312	
n4	72	71	78	78	
d3	M10 (12 x 18)	M12 (15 x 22)	M12 (15 x 22)	M12 (15 x 22)	

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 8- 26 Dimensions of dV/dt reactor, 500 V ... 690 V 3 AC, part 1 (all dimensions in mm)

6SL3000-	2DH31-0CA0	2DH31-5CA0	2DH32-2CA0	2DH33-3CA0	2DH34-1CA0
a2	25	25	25	25	30
a3	6	6	5	5	6
a4	14	14	14	14	17
a5	10.5 x 14	10.5 x 14	10.5 x 14	10.5 x 14	14 x 18
a6	7	7	7	9	11
a7	-	-	-	-	-
a8	=	=	=	=	=
14	350	350	460	460	460
15	120	120	152.5	152.5	152.5
hmax	320	320	360	360	385
h2	215	215	240	240	280
h3	70	70	86	86	83
n1 ¹⁾	138	138	155	212	212
n2 ¹⁾	264	264	356	356	356
n3	227	227	275	275	312
n4	74	74	101	42	78
d3	M8	M8	M12 (15 x 22)	M12 (15 x 22)	M12 (15 x 22)

¹⁾ Lengths n1 and n2 correspond to the distance between holes

Table 8- 27 Dimensions of dV/dt reactor, 500 V ... 690 V 3 AC, part 2 (all dimensions in mm)

6SL3000-	2DH35-8CA0	2DH38-1DA0	2DH41-3DA0	
a2	40	50	60	
a3	8	8	10	
a4	22	16	19	
a5	14 x 18	14 x 18	14 x 18	
a6	11	11	11	
a7	-	14	17	
a8	-	22	26	
14	460	445	445	
15	152.5	145	145	
hmax	385	385	385	
h2	280	255	250	
h3	78	114	121	
n1 ¹⁾	212	212	212	
n2 ¹⁾	356	341	341	
n3	312	312	312	
n4	78	78	78	
d3	M12 (15 x 22)	M12 (15 x 22)	M12 (15 x 22)	

¹⁾ Lengths n1 and n2 correspond to the distance between holes

8.3.6 Dimension drawing of the Voltage Peak Limiter




Figure 8-11 Dimension drawing of the voltage peak limiter, type 1




Figure 8-12 Dimension drawing of the voltage peak limiter, type 2




Figure 8-13 Dimension drawing of the voltage peak limiter, type 3

8.3 dv/dt filter plus Voltage Peak Limiter

Table 8- 28 Assigning voltage peak limiter to dimension drawings

Voltage peak limiter	Dimension drawing type						
Line voltage 3	Line voltage 3 AC 380 480 V						
6SL3000-2DE32-6BA0	Type 1						
6SL3000-2DE35-0BA0	Type 2						
6SL3000-2DE38-4BA0	Type 3						
6SL3000-2DE41-4BA0	Type 3						
Line voltage 3 AC 500 690 V							
6SL3000-2DH31-0BA0	Type 1						
6SL3000-2DH31-5BA0	Type 1						
6SL3000-2DH32-2BA0	Type 2						
6SL3000-2DH33-3BA0	Type 2						
6SL3000-2DH34-1BA0	Type 3						
6SL3000-2DH35-8BA0	Type 3						
6SL3000-2DH38-1BA0	Type 3						
6SL3000-2DH41-3BA0	Type 3						

8.3.7 Technical data

Table 8- 29 Technical data of the dv/dt filter plus Voltage Peak Limiter, 3 AC 380 ... 480 V, Part 1

Article number	6SL3000-	2DE32-6AA0	2DE35-0AA0	2DE38-4AA0	2DE41-4AA0 1)
Suitable for Motor Module	6SL3320-	1TE32-1AA3 1TE32-6AA3	1TE33-1AA3 1TE33-8AA3 1TE35-0AA3	1TE36-1AA3 1TE37-5AA3 1TE38-4AA3	1TE41-0AA3 1TE41-2AA3 1TE41-4AA3 1TE41-4AS3
Type rating of the Motor Module	kW	110 / 132	160 / 200 / 250	315 / 400 / 450	560 / 710 / 800 / 800
Ithmax	Α	260	490	840	1405
Degree of protection		IP00	IP00	IP00	IP00
dv/dt reactor					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.701 0.729 0.78	0.874 0.904 0.963	1.106 1.115 1.226	1.111 1.154 1.23
Connections - To the Motor Module - Load - PE		M10 M10 M6	M12 M12 M6	M12 M12 M6	2 x M12 2 x M12 M6
Max. permissible cable length between dv/dt reactor and motor	m	300 (shielded) 450 (unshielded)			
Dimensions Width Height Depth	mm mm mm	410 370 229	460 370 275	460 385 312	445 385 312
Weight, approx.	kg	66	122	149	158
Voltage Peak Limiter					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.029 0.027 0.025	0.042 0.039 0.036	0.077 0.072 0.066	0.134 0.125 0.114
Connections - To the dv/dt reactor - DC - PE		M8 M8 M8	Terminal 70 mm ² Terminal 70 mm ² Terminal 35 mm ²	M8 M8 M8	M10 M10 M8
Dimensions Width Height Depth	mm mm mm	263 265 188	392 285 210	309 1312.5 400	309 1312.5 400
Weight, approx.	kg	6	16	48	72

¹⁾ Two dv/dt reactors are required for these dv/dt filters. The technical data provided applies to one dv/dt reactor.

Note

Cable lengths for versions with two dv/dt reactors

For versions with 2 dv/dt reactors, the cable lengths specified in the table do not change.

8.3 dv/dt filter plus Voltage Peak Limiter

Table 8-30 Technical data of the dv/dt filter plus Voltage Peak Limiter, 3 AC 380 ... 480 V, Part 2

Article number	6SL3000-	2DE38-4AA0	2DE41-4AA0 ¹⁾
Matching Motor Module Chassis-2	6SL3321-	1TE36-6AA0	1TE37-4AA0 / 1TE38-1AA0 1TE38-8AA0 / 1TE41-0AA0 1TE41-1AA0 / 1TE41-2AA0 1TE41-3AA0 / 1TE41-5AA0
Type rating of the Motor Module	kW	315	355 / 400 / 450 / 500 / 560 / 630 / 710 / 800
Ithmax	А	840	1405
Degree of protection		IP00	IP00
dv/dt reactor			
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	1.106 1.115 1.226	1.111 1.154 1.23
Connections - To the Motor Module - Load - PE		M12 M12 M6	2 x M12 2 x M12 M6
Max. permissible cable length between dv/dt reactor and motor	m		00 (shielded) 0 (unshielded)
Dimensions Width Height Depth	mm mm mm	460 385 312	445 385 312
Weight, approx.	kg	149	158
Voltage Peak Limiter			
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.077 0.072 0.066	0.134 0.125 0.114
Connections - To the dv/dt reactor - DC - PE		M8 M8 M8	M10 M10 M8
Dimensions Width Height Depth	mm mm mm	309 1312.5 400	309 1312.5 400
Weight, approx.	kg	48	72

¹⁾ Two dv/dt reactors are required for these dv/dt filters. The technical data provided applies to one dv/dt reactor.

Note

Cable lengths for versions with two dv/dt reactors

For versions with 2 dv/dt reactors, the cable lengths specified in the table do not change.

Table 8-31 Technical data of the dv/dt filter plus Voltage Peak Limiter, 3 AC 500 ... 690 V, Part 1

Article number	6SL3000-	2DH31-0AA0	2DH31-5AA0	2DH32-2AA0	2DH33-3AA0
Suitable for Motor Module	6SL3320-	1TG28-5AA3 1TG31-0AA3	1TG31-2AA3 1TG31-5AA3	1TG31-8AA3 1TG32-2AA3	1TG32-6AA3 1TG33-3AA3
Type rating of the Motor Module	kW	75 / 90	110 / 150	160 / 200	250 / 315
Ithmax	Α	100	150	215	330
Degree of protection		IP00	IP00	IP00	IP00
dv/dt reactor					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.49 0.508 0.541	0.389 0.408 0.436	0.578 0.604 0.645	0.595 0.62 0.661
Connections - To the Motor Module - Load - PE		M10 M10 M6	M10 M10 M6	M10 M10 M6	M10 M10 M6
Max. permissible cable length between dv/dt reactor and motor	m	300 (shielded) 450 (unshielded)			
Dimensions Width Height Depth	mm mm mm	350 320 227	350 320 227	460 360 275	460 360 275
Weight, approx.	kg	48	50	83	135
Voltage Peak Limiter					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.016 0.015 0.013	0.020 0.019 0.018	0.032 0.03 0.027	0.042 0.039 0.036
Connections - To the dv/dt reactor - DC - PE		M8 M8 M8	M8 M8 M8	Terminal 70 mm² Terminal 70 mm² Terminal 35 mm²	Terminal 70 mm² Terminal 70 mm² Terminal 35 mm²
Dimensions Width Height Depth	mm mm mm	263 265 188	263 265 188	392 285 210	392 285 210
Weight, approx.	kg	6	6	16	16

8.3 dv/dt filter plus Voltage Peak Limiter

Table 8- 32 Technical data of the dv/dt filter plus Voltage Peak Limiter, 3 AC 500 ... 690 V, Part 2

Article number	6SL3000-	2DH34-1AA0	2DH35-8AA0	2DH38-1AA0 ¹⁾	2DH41-3AA0 ¹⁾
Suitable for Motor Module	6SL3320-	1TG34-1AA3	1TG34-7AA3 1TG35-8AA3	1TG37-4AA3 1TG38-1AA3	1TG38-8AA3 1TG41-0AA3 1TG41-3AA3
Type rating of the Motor Module	kW	400	450 / 560	710 / 800	900 / 1000 / 1200 / 1200
Ithmax	Α	410	575	810	1270
Degree of protection		IP00	IP00	IP00	IP00
dv/dt reactor					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.786 0.826 0.884	0.862 0.902 0.964	0.828 0.867 0.927	0.865 0.904 0.966
Connections - To the Motor Module - Load - PE		M12 M12 M6	M12 M12 M6	2 x M12 2 x M12 M6	2 x M12 2 x M12 M6
Max. permissible cable length between dv/dt reactor and motor	m	300 (shielded) 450 (unshielded)			
Dimensions Width Height Depth	mm mm mm	460 385 312	460 385 312	445 385 312	445 385 312
Weight, approx.	kg	147	172	160	164
Voltage Peak Limiter					
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.051 0.048 0.043	0.063 0.059 0.054	0.106 0.1 0.091	0.15 0.14 0.128
Connections - To the dv/dt reactor - DC - PE		M8 M8 M8	M8 M8 M8	M10 M10 M8	M10 M10 M8
Dimensions Width Height Depth	mm mm mm	309 1312.5 400	309 1312.5 400	309 1312.5 400	309 1312.5 400
Weight, approx.	kg	48	48	72	72

¹⁾ Two dv/dt reactors are required for these dv/dt filters. The technical data provided applies to one dv/dt reactor.

Note

Cable lengths for versions with two dv/dt reactors

For versions with 2 dv/dt reactors, the cable lengths specified in the table do not change.

8.4.1 Description

The dv/dt filter compact plus Voltage Peak Limiter comprises two components: The dv/dt reactor and the voltage-limiting network (Voltage Peak Limiter) which cuts off the voltage peaks and returns the energy into the DC link. The dv/dt filter compact plus Voltage Peak Limiter is designed for use with motors for which the proof voltage of the insulation system is unknown or insufficient.

dv/dt filters compact plus Voltage Peak Limiters limit the voltage rate of rise dv/dt to values $< 1600 \text{ V/}\mu\text{s}$ - and the typical voltage peaks to the following values according to limit value curve A according to IEC 60034-25:2007:

- < 1150 V at Uline < 575 V
- < 1400 V at 660 V < Uline < 690 V.

Note

Setting range for pulse frequencies

It is permissible to set pulse frequencies in the range between the rated pulse frequency and the relevant maximum pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used.

Note

Current derating at increased pulse frequency

For current derating with increased pulse frequency, the derating of the associated Motor Module is the decisive factor.

Note

Components of the dv/dt filter

The dv/dt filters compact plus Voltage Peak Limiter of Types 1 to 3 comprise one single component. Type 4 consists of two separate components, the dv/dt reactor and the Voltage Peak Limiter.

Table 8- 33 Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used in units with a rated pulse frequency of 2 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 2 kHz [A]	Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used
	L	ine voltage 3 AC 380 480	V
1TE32-1AA3	110	210	4 kHz
1TE32-6AA3	132	260	4 kHz
1TE33-1AA3	160	310	4 kHz
1TE33-8AA3	200	380	4 kHz
1TE35-0AA3	250	490	4 kHz
1TE41-4AS3	800	1330	2.5 kHz

Table 8- 34 Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used in units with a rated pulse frequency of 1.25 kHz

Article No. of the Motor Module 6SL3320	Type rating [kW]	Output current for a pulse frequency of 1.25 kHz [A]	Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used
	L	ine voltage 3 AC 380 480	V
1TE36-1AA3	315	605	2.5 kHz
1TE37-5AA3	400	745	2.5 kHz
1TE38-4AA3	450	840	2.5 kHz
1TE41-0AA3	560	985	2.5 kHz
1TE41-2AA3	710	1260	2.5 kHz
1TE41-4AA3	800	1405	2.5 kHz
	L	ine voltage 3 AC 500 690	V
1TG28-5AA3	75	85	2.5 kHz
1TG31-0AA3	90	100	2.5 kHz
1TG31-2AA3	110	120	2.5 kHz
1TG31-5AA3	132	150	2.5 kHz
1TG31-8AA3	160	175	2.5 kHz
1TG32-2AA3	200	215	2.5 kHz
1TG32-6AA3	250	260	2.5 kHz
1TG33-3AA3	315	330	2.5 kHz
1TG34-1AA3	400	410	2.5 kHz
1TG34-7AA3	450	465	2.5 kHz
1TG35-8AA3	560	575	2.5 kHz
1TG37-4AA3	710	735	2.5 kHz
1TG38-1AA3	800	810	2.5 kHz
1TG38-8AA3	900	910	2.5 kHz
1TG41-0AA3	1000	1025	2.5 kHz
1TG41-3AA3	1200	1270	2.5 kHz

2.5 kHz

Article No. of the Motor Module Chassis-2 6SL3321	Type rating [kW]	Output current for a pulse frequency of 2.5 kHz [A]	Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used
	L	ine voltage 3 AC 380 480	V
1TE36-6AA0	315	655	2.5 kHz
1TE37-4AA0	355	740	2.5 kHz
1TE38-1AA0	400	810	2.5 kHz
1TE38-8AA0	450	910	2.5 kHz
1TE41-0AA0	500	975	2.5 kHz
1TE41-1AA0	560	1075	2.5 kHz
1TE41-2AA0	630	1200	2.5 kHz
1TE41-3AA0	710	1325	2.5 kHz

1495

Table 8- 35 Max. pulse frequency when a dv/dt filter compact plus Voltage Peak Limiter is used in units with a rated pulse frequency of 2.5 kHz

8.4.2 Safety information



1TE41-5AA0

Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

• Comply with the fundamental safety instructions.

800

When assessing the risk, take into account remaining risks.

WARNING

Fire due to overheating because of inadequate ventilation clearances

Inadequate ventilation clearances can cause overheating with a risk for personnel through smoke development and fire. Furthermore, an increased number of failures and shorter service life of the components can occur.

- Maintain 100 mm clearances above and below the components.
- Always mount the dV/dt filters compact plus Voltage Peak Limiter in a vertical, upright
 position to enable cooling air to flow through the heat sink on the Voltage Peak Limiter
 from the bottom to the top.

ACAUTION

Burns due to high surface temperature of the dv/dt filter compact

The surface temperature of the dv/dt filters compact may exceed 80 °C. You can get seriously burnt when touching the surface.

• Mount the dV/dt filters compact so that they cannot be touched. If this is not possible, attach a clearly visible and understandable warning notice at hazardous positions.

NOTICE

Damage to the Voltage Peak Limiter due to interchanged connections

The Voltage Peak Limiter will be damaged if the input and output connections are interchanged on devices with the article numbers 6SL3000-2DE41-4EA0, 6SL3000-2DG38-1EA0, and 6SL3000-2DG41-3EA0.

- Connect the incoming cable from the DC link of the Motor Module to DCPS, DCNS.
- Connect the outgoing cable for the dV/dt reactor to 1U2, 1V2, 1W2.

NOTICE

Damage to the dV/dt filter compact by using components that have not been released

When using components that have not been released, damage or malfunctions can occur at the devices or the system itself.

• Only use a dV/dt filter compact that SIEMENS has released for operation with SINAMICS.

NOTICE

Damage to the dV/dt filter compact by exceeding the maximum output frequency

The maximum permissible output frequency when a dv/dt filter compact is used is 150 Hz. The dV/dt filter compact can be damaged if the output frequency is exceeded.

• Operate the dv/dt filter compact with a maximum output frequency of 150 Hz.

NOTICE

Damage to the dV/dt filter compact during continuous operation with low output frequencies

Uninterrupted duty at an output frequency less than 10 Hz can result in thermal overload and destroy the dv/dt filter.

- When using a dv/dt filter compact plus voltage peak limiter do not operate the drive continuously with an output frequency less than 10 Hz.
- You may operate the drive for a maximum load duration of 5 minutes at an output frequency less than 10 Hz, provided that you then select an operation with an output frequency higher than 10 Hz for a period of 5 minutes.

NOTICE

Damage to the dV/dt filter compact by exceeding the maximum pulse frequency

The maximum permissible pulse frequency when a dv/dt filter compact is used is 2.5 kHz or 4 kHz. The dV/dt filter compact can be damaged if the pulse frequency is exceeded.

• When using the dv/dt filter compact, only operate the Motor Module with a maximum pulse frequency of 2.5 kHz or 4 kHz.

NOTICE

Damage to the dV/dt filter compact if it is not activated during commissioning

The dV/dt filter compact may be damaged if it is not activated during commissioning.

• Activate the dv/dt filter compact during commissioning using parameter p0230 = 2.

NOTICE

Damage to the dV/dt filter compact if a motor is not connected

dV/dt filters compact which are operated without a motor being connected can be damaged or destroyed.

 Never operate a dV/dt filter compact connected to the Motor Module without a connected motor.

Note

Cable lengths

Keep the connecting cables to the Motor Module as short as possible (max. 5 m). Use an equivalent cable type when replacing the cables supplied.

8.4.3 Interface description




Figure 8-14 Interface overview for dv/dt filter compact plus Voltage Peak Limiter, Type 1




Figure 8-15 Interface overview for dv/dt filter compact plus Voltage Peak Limiter, Type 2




Figure 8-16 Interface overview for dv/dt filter compact plus Voltage Peak Limiter, Type 3




Figure 8-17 Interface overview for dv/dt filter compact plus Voltage Peak Limiter, Type 4 dv/dt reactor




Figure 8-18 Interface overview for dv/dt filter compact plus Voltage Peak Limiter, Type 4 Voltage Peak Limiter

8.4.4 Connecting the dv/dt filter compact plus Voltage Peak Limiter




Figure 8-19 Connecting the dv/dt filter compact plus Voltage Peak Limiter - complete unit




Figure 8-20 Connecting the dv/dt filter compact plus Voltage Peak Limiter - separate components




Figure 8-21 Connecting the dv/dt filter compact plus Voltage Peak Limiter to a Motor Module Chassis-2

Cable cross-sections

For a dv/dt filter with separate Voltage Peak Limiter (Type 4), the connections between dv/dt reactor and Voltage Peak Limiter are already installed at the Voltage Peak Limiter.

Table 8- 36 Cable cross-sections for connections between a dv/dt filter and Motor Module

dv/dt filter compact plus Voltage Peak Limiter	Cross-section [mm²]	Connection on dv/dt filter (DCPS, DCNS)
Type 1	16	Screw M8 / 12 Nm
Type 2	25	Screw M8 / 12 Nm
Type 3	50	Copper bar for M8 bolt / 12 Nm

Table 8-37 Cable cross-sections for connections between a Voltage Peak Limiter and Motor Module

dv/dt filter compact plus Voltage Peak Limiter	Cross-section [mm²]	Connection to Voltage Peak Limiter (DCPS, DCNS)
Type 4	95	Copper bar for M8 bolt / 12 Nm

Table 8-38 Connection cable enclosed for connecting dv/dt reactor and Voltage Peak Limiter

Voltage Peak Limiter	Cross-section [mm²]	Lug for connecting 1U2 / 1V2 / 1W2 on the dv/dt reactor
Type 4	70	M12

Cable type: 600 V, UL style 3271, operating temperature 125° C



Fire and device damage as a result of ground fault/short-circuit

Inadequate installation of the cables to the Motor Module DC link can result in a ground fault/short-circuit and place persons at risk as a result of the associated smoke and fire.

- Comply with local installation regulations that enable this fault to be ruled out.
- Protect the cables from mechanical damage.
- In addition, apply one of the following measures:
 - Use cables with double insulation.
 - Maintain adequate clearance, e.g. by using spacers.
 - Route the cables in separate cable ducts or pipes.

NOTICE

Damage to the dv/dt filter compact due to mechanical load at the connections

The connections at the dv/dt filter compact are not designed for direct mechanical connection to the motor cables.

• Take measures on the plant or system side to ensure that the connections cannot be deformed by the mechanical load exerted by the connected cables.

8.4.5 Dimension drawing for dv/dt filter compact plus Voltage Peak Limiter




Figure 8-22 Dimension drawing for dV/dt filter compact plus voltage peak limiter, type 1




Figure 8-23 Dimension drawing for dV/dt filter compact plus voltage peak limiter, type 2




Figure 8-24 Dimension drawing for dV/dt filter compact plus voltage peak limiter, type 3




Figure 8-25 Dimension drawing for dV/dt filter compact plus voltage peak limiter, type 4 dV/dt reactor




Figure 8-26 Dimension drawing for dV/dt filter compact plus voltage peak limiter, type 4 Voltage peak limiter

Table 8-39 Assignment of dV/dt filters compact plus voltage peak limiter to the dimension drawings

dV/dt filter compact plus voltage peak limiter	Dimension drawing type				
Line voltage 3 AC 380 480 V					
6SL3000-2DE32-6EA0	Type 1				
6SL3000-2DE35-0EA0	Type 2				
6SL3000-2DE38-4EA0	Type 3				
6SL3000-2DE41-4EA0	Type 4				
Line voltage 3 AC 500 690 V					
6SL3000-2DG31-0EA0	Type 1				
6SL3000-2DG31-5EA0	Type 1				
6SL3000-2DG32-2EA0	Type 2				
6SL3000-2DG33-3EA0	Type 2				
6SL3000-2DG35-8EA0	Type 3				
6SL3000-2DG38-1EA0	Type 4				
6SL3000-2DG41-3EA0	Type 4				

8.4.6 Technical data

Table 8-40 Technical data of the dV/dt filter compact plus voltage peak limiter, 380 V ... 480 V 3 AC, Part 1

Article number	6SL3000-	2DE32-6EA0	2DE35-0EA0	2DE38-4EA0
Suitable for Motor Module (unit rating)	6SL3320-	1TE32-1AA3 (110 kW) 1TE32-6AA3 (132 kW)	1TE33-1AA3 (160 kW) 1TE33-8AA3 (200 kW) 1TE35-0AA3 (250 kW)	1TE36-1AA3 (315 kW) 1TE37-5AA3 (400 kW) 1TE38-4AA3 (450 kW)
Ithmax	Α	260	490	840
Degree of protection		IP00	IP00	IP00
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.210 0.215 0.255	0.290 0.296 0.344	0.518 0.529 0.609
Terminals - 1U1/1V1/1W1 - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M10 bolt for M8 screw for M10 bolt M6 screw	for M10 bolt for M8 screw for M10 bolt M6 screw	for M12 bolt for M8 bolt for M12 bolt M6 screw
Max. permissible cable length between dv/dt filter and motor	m	100 (shielded) 150 (unshielded)		
Dimensions Width Height Depth	mm mm mm	310 283 238	350 317 260	440 369 311
Weight, approx.	kg	41	61	103

Table 8-41 Technical data of the dV/dt filter compact plus voltage peak limiter, 380 V ... 480 V 3 AC, Part 2

Article number	6SL3000-	2DE41-4EA0		
Suitable for Motor Module (unit rating)	6SL3320-	1TE41-0AA3 (560 kW) 1TE41-2AA3 (710 kW) 1TE41-4AA3 (800 kW) 1TE41-4AS3 (800 kW)		
Ithmax	Α	1405		
Degree of protection		IP00		
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	1.154 1.197 1.444		
Max. permissible cable length between dv/dt filter and motor	m		100 (shielded) 150 (unshielded)	
dv/dt reactor				
Terminals - 1U1/1V1/1W1 - 1U2/1V2/1W2 - PE		for 2 x M12 bolts for 2 x M12 bolts M6 screw		
Dimensions Width Height Depth	mm mm mm	430 385 323		
Weight, approx.	kg	168.8		
Voltage Peak Limiter				
Terminals - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M8 bolt for M8 bolt for M6 screw		
Dimensions Width Height Depth	mm mm mm	277 360 291		
Weight, approx.	kg	19.2		

Table 8- 42 Technical data of the dv/dt filter compact plus voltage peak limiter, 380 V ... 480 V 3 AC, Part 3

Article number	6SL3000-	2DE38-4EA0	
Matching Motor Module Chassis-2 (type rating)	6SL3321-	1TE36-6AA0 (315 kW)	
Ithmax	Α	840	
Degree of protection		IP00	
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.518 0.529 0.609	
Terminals - 1U1/1V1/1W1 - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M12 bolt for M8 bolt for M12 bolt M6 screw	
Max. permissible cable length between dv/dt filter and motor	m		100 (shielded) 150 (unshielded)
Dimensions Width Height Depth	mm mm mm	440 369 311	
Weight, approx.	kg	103	

Table 8- 43 Technical data of the du/dt filter compact plus voltage peak limiter, 3 AC 380 ... 480 V, Part 4

Article number	6SL3000-	2DE41-4EA0		
Matching Motor Module Chassis-2 (type rating)	6SL3321-	1TE37-4AA0 (355 kW) 1TE38-1AA0 (400 kW) 1TE38-8AA0 (450 kW) 1TE41-0AA0 (500 kW) 1TE41-1AA0 (560 kW) 1TE41-2AA0 (630 kW) 1TE41-3AA0 (710 kW) 1TE41-5AA0 (800 kW)		
Ithmax	Α	1405		
Degree of protection		IP00		
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	1.154 1.197 1.444		
Max. permissible cable length between dv/dt filter and motor	m		100 (shielded) 150 (unshielded)	
dv/dt reactor				
Terminals - 1U1/1V1/1W1 - 1U2/1V2/1W2 - PE		for 2 x M12 bolts for 2 x M12 bolts M6 screw		
Dimensions Width Height Depth	mm mm mm	430 385 323		
Weight, approx.	kg	168.8		
Voltage Peak Limiter				
Terminals - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M8 bolt for M8 bolt for M6 screw		
Dimensions Width Height Depth	mm mm mm	277 360 291		
Weight, approx.	kg	19.2		

Table 8-44 Technical data of the dV/dt filter compact plus voltage peak limiter, 500 V ... 690 V 3 AC, Part 1

Article number	6SL3000-	2DG31-0EA0	2DG31-5EA0	2DG32-2EA0
Suitable for Motor Module (unit rating)	6SL3320-	1TG28-5AA3 (75 kW) 1TG31-0AA3 (90 kW)	1TG31-2AA3 (110 kW) 1TG31-5AA3 (132 kW)	1TG31-8AA3 (160 kW) 1TG32-2AA3 (200 kW)
Ithmax	Α	100	150	215
Degree of protection		IP00	IP00	IP00
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.227 0.236 0.287	0.270 0.279 0.335	0.305 0.316 0.372
Terminals - 1U1/1V1/1W1 - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M10 bolt for M8 screw for M10 bolt M6 screw	for M10 bolt for M8 screw for M10 bolt M6 screw	for M10 bolt for M8 screw for M10 bolt M6 screw
Max. permissible cable length between dv/dt filter and motor	m	100 (shielded) 150 (unshielded)		
Dimensions Width Height Depth	mm mm mm	310 283 238	310 283 238	350 317 260
Weight, approx.	kg	34	36	51

Table 8- 45 Technical data of the dV/dt filter compact plus voltage peak limiter, 500 V ... 690 V 3 AC, Part 2

Article number	6SL3000-	2DG33-3EA0	2DG34-1EA0	2DG35-8EA0
Suitable for Motor Module (unit rating)	6SL3320-	1TG32-6AA3 (250 kW) 1TG33-3AA3 (315 kW)	1TG34-1AA3 (400 kW)	1TG34-7AA3 (450 kW) 1TG35-8AA3 (560 kW)
Ithmax	Α	330	410	575
Degree of protection		IP00	IP00	IP00
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.385 0.399 0.480	0.550 0.568 0.678	0.571 0.586 0.689
Terminals - 1U1/1V1/1W1 - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M10 bolt for M8 screw for M10 bolt M6 screw	for M12 bolt for M8 bolt for M12 bolt M6 screw	for M12 bolt for M8 bolt for M12 bolt M6 screw
Max. permissible cable length between dv/dt filter and motor	m	100 (shielded) 150 (unshielded)		
Dimensions Width Height Depth	mm mm mm	350 317 260	440 369 311	440 369 311
Weight, approx.	kg	60	87	100

Table 8- 46 Technical data of the dV/dt filter compact plus voltage peak limiter, 500 V ... 690 V 3 AC, Part 3

Article number	6SL3000-	2DG38-1EA0	2DG41-3EA0	
Suitable for Motor Module (unit rating)	6SL3320-	1TG37-4AA3 (710 kW) 1TG38-1AA3 (800 kW)	1TG38-8AA3 (900 kW) 1TG41-0AA3 (1000 kW) 1TG41-3AA3 (1200 kW)	
Ithmax	Α	810	1270	
Degree of protection		IP00	IP00	
Power loss - at 50 Hz - at 60 Hz - at 150 Hz	kW kW kW	0.964 0.998 1.196	1.050 1.104 1.319	
Max. permissible cable length between dv/dt filter and motor	m		100 (shielded) 150 (unshielded)	
dv/dt reactor				
Terminals - 1U1/1V1/1W1 - 1U2/1V2/1W2 - PE		for 2 x M12 bolts for 2 x M12 bolts M6 screw	for 2 x M12 bolts for 2 x M12 bolts M6 screw	
Dimensions Width Height Depth	mm mm mm	430 385 323	430 385 323	
Weight, approx.	kg	171.2	175.8	
Voltage Peak Limiter				
Terminals - DCPS/DCNS - 1U2/1V2/1W2 - PE		for M8 bolt for M8 bolt for M6 screw	for M8 bolt for M8 bolt for M6 screw	
Dimensions Width Height Depth	mm mm mm	277 360 291	277 360 291	
Weight, approx.	kg	18.8	19.2	

Cabinet design and EMC

9.1 Information

9.1.1 General

The modular concept of SINAMICS S120 chassis units allows a wide range of potential device combinations. For this reason, it is impossible to describe each individual combination. This section instead aims to provide some basic information and general rules on the basis of which special device combinations can be configured to ensure electromagnetic compatibility and adequate cooling – therefore ensuring reliable operation with the appropriate functionality.

SINAMICS S120 components are designed for installation in the appropriate enclosures, which can take the form of cabinet units or control boxes made of steel that provide protection against shock and other environmental effects. They are also part of the EMC concept.

9.1.2 Safety information



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account residual risks.

MARNING

Injuring caused by foreign objects in the device

Parts and components falling into the device (e.g. drilling chips, end sleeves, etc.) can cause short-circuits and damage to the insulation. This can lead to serious injuries (arcing, bangs, pieces flying out of the equipment).

- Only perform installation and other work when the devices are current-free.
- Cover the ventilation slits during the installation of the cabinet and remove the cover before switching on.

9.1 Information

NOTICE

Limiting of overvoltages

On systems with a grounded line conductor and a line voltage >600 V AC, line-side components should be installed to limit overvoltages to overvoltage category II according to IEC 61800-5-1.

Note

Protection against the spread of fire

The converter may be operated only in closed housings or in higher-level control cabinets with protective covers that are closed, and when all of the protective devices are used.

Converters of the Open Type/IP20 degree of protection must be installed in a metal control cabinet or protected by another equivalent measure such that fire cannot spread and emissions outside of the control cabinet are prevented.

Note

Protection against condensation and electrically conductive contamination

To prevent damage caused by (conductive) pollution and moisture, protect the components by installing them in a control cabinet with ingress protection IP54 according to IEC 60529 or Type 12 according to NEMA 250.

- A higher degree of enclosure protection may be required for especially critical operating conditions. Technical measures such as heating devices may be required to prevent condensation.
- Provided that the occurrence of conductive pollution and/or condensation can be excluded at the installation site, a correspondingly low degree of protection is permissible for the control cabinet and the corresponding technical measures may be dispensed with.

Maximum cable lengths

Table 9- 1 Maximum cable lengths

Туре	Maximum length [m]
24 V DC power cables 1)	10
24 V signal cables 1)	30
Power cable between the Motor Module and motor when using two motor reactors in series	300 (shielded) 450 (unshielded) 525 (shielded) 787 (unshielded)
Power cable between the Motor Module Chassis-2 and motor when using 2 motor reactors in series	300 (shielded) 450 (unshielded) 450 (shielded) 675 (unshielded)
DRIVE-CLiQ cables inside the electrical cabinet, e.g. connection between the CU320-2 and the first Motor Module or between the Motor Modules DRIVE-CLiQ MOTION-CONNECT connecting cables for external	70 100
Components Power cable between Praking Medule and braking resistor	100
Power cable between Braking Module and braking resistor	100

¹⁾ For longer lengths, suitable wiring must be provided by the user for overvoltage protection.

Table 9- 2 Recommendations for overvoltage protection

24 V power supply	24 V signal cables
Manufacturer: Dehn Article: BVT AVD 24 Article number: 918422	For digital inputs and outputs up to 0.1 A Manufacturer: Dehn Article: BXT ML4 BE C 24 and BSP BAS 4 Article numbers: 920364 and 926304
	For digital inputs and outputs up to 0.5 A Manufacturer: Dehn Article: DCO SD2 ME 24 and DCO SD2 MD 24 Article numbers: 917921 and 917941

9.2 EMC-compliant design and control cabinet configuration

9.1.3 Directives

The control cabinet must satisfy the following EC Directives in the European Economic Area (EEA):

Table 9-3 Directives

Directive	Description
2014/35/EU	Directive of the European Parliament and Council from February 26, 2014 on the approximation of the laws relating to the provision of electrical equipment designed for use within certain voltage limits (Low-Voltage Directive)
2014/30/EU	Directive of the European Parliament and Council of February 26, 2014 for the harmonization of the laws of the member states relating to electromagnetic compatibility (EMC directive)
2006/42/EC	Directive of the European Parliament and Council of May 17, 2006 on machinery and for changing Directive 95/16/EC (amendment) (machinery directive)

9.2 EMC-compliant design and control cabinet configuration

Detailed configuration instructions regarding the EMC-compliant design of drives and control cabinet configuration can be found in the "SINAMICS Low Voltage Configuration Manual", see Configuration Manual for SINAMICS G130, G150, S120 Built-in Units, S120 Cabinet Modules, S150 (https://support.industry.siemens.com/cs/ww/de/view/83180185).

9.3 Electromagnetic fields at the workplace

9.3.1 Preliminary remarks

Protection of workers from electromagnetic fields is specified in the European EMF Directive 2013/35/EU. This directive is implemented in national law in the European Economic Area (EEA). Employers are obligated to design workplaces in such a way that workers are protected from impermissibly strong electromagnetic fields. To this end, assessments and/or measurements must be performed for workplaces.

General conditions for correct assessment or measurement

- 1. The laws for protection from electromagnetic fields in force in individual EU member states can go beyond the minimum requirements of the EMF Directive 2013/35/EU and always take precedence.
- 2. The ICNIRP 2010 limits for the workplace are the basis for the assessment.
- 3. The 100 μ T (RMS) mentioned below for assessment of active implants comes from the 26th BlmSchV (German Federal Emission Protection Regulations). According to Directive 2013/35/EU, 500 μ T (RMS) at 50 Hz is applicable here.
- 4. Compliance with the limit values was checked for the following frequencies:
 - Line frequency 47 ... 63 Hz (see system data)
 - Pulse frequency, for example 1.25/2/2.5/4/5/7.5/8 kHz and multiples thereof, evaluated up to a maximum of 100 kHz (see system data or relevant technical specifications)
- 5. The routing of power cables has a significant impact on the electromagnetic fields that occur. More detailed information is provided in the "SINAMICS Low Voltage Configuration Manual".

9.3.2 Measurements/evaluations for SINAMICS S120 chassis air cooled

Note

Validity

The following information regarding electromagnetic fields relates solely to products and components supplied by Siemens. A precondition is the installation and operation of components inside metal control cabinets in compliance with the documentation and the "SINAMICS Low Voltage Engineering Manual" and the use of shielded motor cables. More detailed information is provided in the "SINAMICS Low Voltage Engineering Manual".

The components are normally used in machines. Assessment and testing is based on DIN EN 12198-1.

Table 9-4 Information for frequency range 0 Hz to 300 GHz

Frequency range	0 Hz 100 kHz	100 kHz 300 GHz
Electric field strength	Limits not exceeded	Limits not exceeded
Magnetic flux density	For assessment, see the following table	Limits not exceeded

Table 9-5 Minimum clearances to SINAMICS S120 chassis air cooled for 0 Hz ... 100 kHz

Power of the Line Module	Generally		Individuals with active implants	
	Control cabinet closed	Control cabinet open	Control cabinet closed	Control cabinet open
P ≤ 1500 kW	50 cm ¹⁾	200 cm	Must be separately assessed depending on the active implant.	Must be separately assessed depending on the active implant.

¹⁾ The minimum clearances in the area around the power connections is 100 cm.

Note

The minimum distances indicated above apply to the head and complete torso of the human body. Shorter distances are possible for extremities.

9.4.1 General

The minimum dimensions listed below for ventilation clearances must be observed. No other components or cables may be installed in or laid through these areas.

NOTICE

Device failure caused by overloading of devices and components

If the guidelines for installing SINAMICS S120 Chassis devices are not observed, this can significantly reduce the service life of the components This can result in premature device and component failure.

• Observe the guidelines for installing the devices and components.

You must take into account the following specifications when using a SINAMICS S120 Chassis drive line-up:

- Ventilation clearance
- Cabling
- · Air guidance

Table 9- 6 Ventilation clearances for the components

Component	Frame size	Clearance at the front [mm]	Clearance (above) [mm]	Clearance (below) [mm]	Clearance at the side [mm]
Basic Line Module	FB, GB, GD	40 1)	250	150	0
Active Interface Module	FI	40 1)	250	150	0
Active Interface Module	GI	50 ¹⁾	250	150	0
Active Interface Module	HI, JI	40 1)	250	0	0
Active Interface Module Chassis-2	FS2, FS4, FS4+	20 1)	70	0	20
Smart Line Module	GX, HX, JX	40 1)	250	150	0
Active Line Module	FX, GX, HX, JX	40 1)	250	150	0
Active Line Module Chassis-2	FS2, FS2+, FS4, FS4+	0	200	0	80 (clearance to the right) 2)
Motor Module	FX, GX, HX, JX	40 ¹⁾	250	150	0
Motor Module Chassis-2	FS2, FS2+, FS4, FS4+	0	200	0	80 (clearance to the right) 2)

¹⁾ The clearances refer to the area around the ventilation slots on the front cover.

²⁾ The clearances refer to the area around the air intake of the fan and the upper ventilation slots in the lateral cover.

Note

Notes on the dimensions

The dimensions refer to the outer edges of the devices.

Dimension drawings are available in the relevant chapters.

9.4.2 Ventilation

The SINAMICS S120 Chassis devices are forced-ventilated by means of integrated fans. To ensure an adequate air supply, suitably large openings for the inlet intake (e.g. ventilation slots in the cabinet door) and discharged air (e.g. by means of a roof canopy) must be provided.

The cooling air must flow through the components vertically from bottom (cooler region) to top (region heated by operation).

You must ensure that the air is flowing in the right direction. You must also ensure that the warm air can escape at the top. The specified ventilation clearances must be observed.

Note

Cables must not be routed directly on the components. The ventilation grilles must not be covered.

Cold air must not be allowed to blow directly onto electronic equipment.

NOTICE

Device failure due to condensation as a result of unsuitable air guidance and cooling

Unsuitable air guidance and cooling equipment can cause condensation, which can result in device failure.

- Choose air guidance measures, as well as the arrangement of and settings for the cooling equipment in such a way as to prevent condensation even with the highest relative humidity.
- If required, install cabinet enclosure heating.




Figure 9-1 Air guidance for Active Interface Module, frame sizes FI, GI




Figure 9-2 Air guidance for Active Interface Module, frame sizes HI, JI




Figure 9-3 Air guidance for Active Interface Module Chassis-2, frame sizes FS2, FS4, FS4+




Figure 9-4 Air guidance for Smart Line Module, Active Line Module, Motor Module, frame sizes FX, GX




Figure 9-5 Air guidance for Smart Line Module, Active Line Module, Motor Module, frame sizes HX, JX




Figure 9-6 Air guidance for Basic Line Module, frame sizes FB, GB, GD




Figure 9-7 Air guidance for Active Line Module Chassis-2, Motor Module Chassis-2, frame size FS2, FS2+, FS4+, FS4+

Devices must not be operated in an "air short-circuit", since this can damage equipment or cause it to fail.

The drawn air of the fan causes negative pressure to build up at the ventilation openings in the cabinet doors. The pressure is dependent on the volume flow rate and the hydraulic cross-section of the openings.

The air, which blows out of the top of the device, accumulates under the top cover/hood, resulting in overpressure.

The difference between the overpressure at the top of the cabinet and the negative pressure at the bottom creates a flow of air (air short-circuit). This can vary in strength depending on the cross-section of the door and cover openings and the volumetric flow of the fan.

Due to the flow of air within the cabinet, the device fan draws in pre-heated air. This heats up the components considerably and the fan does not function effectively.

NOTICE

Device failure due to air short-circuit in the control cabinet

Short-circuits in the cooling air circuit as a result of unsuitable air guidance can result in overheating in the electrical cabinet and in turn failure of devices.

• Install suitable barriers in the control cabinet in order to prevent an air short-circuit from occurring.

NOTICE

Failure of devices as a result of the different cooling concepts of the Chassis and Chassis-2 power units

When using Chassis and Chassis-2 power units in one electrical cabinet, if suitable partitions are not used, then the devices can fail as a result of the different cooling concepts.

• Install suitable partitions between the cabinet panels where Chassis and Chassis-2 power units are mounted.

Barriers must be installed in such a way that no air can flow along the outer sides on the top and bottom of the devices. In particular, air must be prevented from flowing from the top (warm discharged air) to the bottom (cold cooling air). Suitable plates can be used as barriers The barriers must reach up to the side panels or cabinet doors. They must be set up in such a way that the outgoing air current is not forced into the cabinet cross-beams, but is instead diverted around them. Barriers must be in place for all degrees of protection higher than IP20.

The cabinets adjacent to the converter cabinets must also be taken into account when barriers are installed.

To ensure adequate ventilation of the equipment, the minimum opening sizes specified in the following table must be observed.

The specified opening cross-sections comprise several small openings. To ensure that pressure loss is kept to a minimum and that the flow resistance does not become too great at these mesh-type openings, the cross sectional area of each opening must be around at least 190 mm² (e.g. 7.5 mm x 25 mm or 9.5 mm x 20 mm). The total opening cross-section to be provided is specified for each device in the table below.

To ensure that the devices operate continuously, suitable measures must be taken to prevent the ingress of dirt and dust. Wire lattices (wire fabric DIN 4189-St-vzk-1x0.28) or filter mats (min. filter class G2) must be used for this purpose. The choice of filter mats depends on the required degree of protection and the ambient conditions. If cabinets are installed in an environment containing fine dust particles or oil vapors, micro-filter mats must be used to prevent the devices from becoming contaminated.

If dirt filters are used, the specified opening cross-sections and the filter areas must be adjusted upwards.

NOTICE

Device failure due to overheating as a result of contaminated dirt filters

Contaminated filter mats cause the device to overheat and fail.

• If dirt filters are used, observe the specified replacement intervals.

If the filter mats are heavily contaminated, the volume of air drawn is reduced due to the increased flow resistance. This can cause the fans integrated in the devices to overload, or it could cause the devices themselves to overheat and become damaged.

The opening cross-sections specified in the table refer in each case to one device. If more than one device is installed in a cabinet, the opening cross-section increases accordingly. If the required openings cannot be made in the cabinet, the devices must be distributed across several cabinets which are separated from each other by means of partitions.

The warm air must be discharged via the top cover/hood or via side openings in the cabinet at the level of the device top. The size of the opening cross-section must also be taken into account here.

With degrees of protection higher than IP20 and if a hood is used, it may be necessary to use an "active" hood. An "active" hood contains fans that blow the air current forwards. The hood is closed, with the exception of the air outlet point.

If you choose an "active" hood, you must ensure that the fans are sufficiently powerful to prevent air from accumulating in the cabinet. If air accumulates, the cooling capacity is reduced. This can overheat and destroy the devices. The air capacity of the fans should at least be equivalent to the device fan data.

Table 9-7 Volume flow rate, opening cross-sections

		Acti	ve Interface Mod	ules	
Article number	6SL3300-	7TE32-6AA0	7TE33-8AA0 7TE35-0AA0	7TE38-4AA0 7TE41-4AA0 7TG35-8AA0 7TG37-4AA0 7TG41-3AA0	
Cooling air requirement	[m³/s]	0.24	0.47	0.4	
Min. opening cross-section in cabinet inlet outlet					
	[m²]	0.1	0.25	0.2	
	[m²]	0.1	0.25 terface Modules	O.2	
Article number	6SL3301-	Active in	terrace Modules	7TE36-4AA0	
Article Humber				7TE41-0AA0 7TE41-4AA0	
Cooling air requirement	[m³/s]			0.61	
Min. opening cross-section in cabinet inlet outlet					
	[m²] [m²]			0.38 0.28	
	[]	E	Basic Line Module		
Article number	6SL3330-	1TE34-2AA3 1TE35-3AA3 1TE38-2AA3 1TG33-0AA3 1TG34-3AA3 1TG36-8AA3	1TE41-2AA3 1TE41-5AA3 1TE41-6AA3 1TG41-1AA3 1TG41-4AA3 1TG41-8AA3		
Cooling air requirement	[m³/s]	0.17	0.36		
Min. opening cross-section in cabinet inlet outlet					
	[m²]	0.1	0.19		
	[m²]	0.1	0.19 mart Line Module	<u> </u>	
Article number	6SL3330-	6TE35-5AA3	6TE41-1AA3	6TE41-3AA3	
		6TE37-3AA3 6TG35-5AA3	6TG38-8AA3	6TE41-7AA3 6TG41-2AA3 6TG41-7AA3	
Cooling air requirement	[m³/s]	0.36	0.78	1.08	
Min. opening cross-section in cabinet inlet outlet					
	[m²] [m²]	0.19 0.19	0.28 0.28	0.38 0.38	

Active Line Modules							
A state of	6613333	ı	ı		77526 4 4 4 2	77544 0440	
Article number	6SL3330-	7TE32-1AA3	7TE32-6AA3	7TE33-8AA3 7TE35-0AA3	7TE36-1AA3 7TE37-5AA3 7TE38-4AA3	7TE41-0AA3 7TE41-2AA3 7TE41-4AA3 7TG37-4AA3 7TG41-0AA3 7TG41-3AA3	
Cooling air requirement	[m³/s]	0.17	0.23	0.36	0.78	1.08	
Min. opening cross-section in cabinet inlet outlet							
	[m²] [m²]	0.1 0.1	0.1 0.1	0.19 0.19	0.28 0.28	0.38 0.38	
	1		Line Modules Ch				
Article number	6SL3331-				7TE35-6AA0 7TE36-4AA0 7TE37-5AA0 7TE38-4AA0 7TE38-8AA0 7TE41-0AA0 7TE41-2AA0 7TE41-3AA0 7TE41-4AA0		
Cooling air requirement	[m³/s]				0.64		
Min. opening cross-section in cabinet inlet outlet	121				0.20		
	[m²] [m²]				0.38 0.28		
			Motor Modules				
Article number	6SL3320-	1TE32-1AA3 1TG28-5AA3 1TG31-0AA3 1TG31-2AA3 1TG31-5AA3	1TE32-6AA3	1TE33-1AA3 1TE33-8AA3 1TE35-0AA3 1TG31-8AA3 1TG32-2AA3 1TG32-6AA3 1TG33-3AA3	1TE36-1AA3 1TE37-5AA3 1TE38-4AA3 1TG34-1AA3 1TG34-7AA3 1TG35-8AA3	1TE41-0AA3 1TE41-2AA3 1TE41-4AA3 1TE41-4AS3 1TG37-4AA3 1TG38-1AA3 1TG38-8AA3 1TG41-0AA3 1TG41-3AA3	
Cooling air requirement	[m³/s]	0.17	0.23	0.36	0.78	1.08	
Min. opening cross-section in cabinet inlet outlet				0.15	0.55		
	[m²] [m²]	0.1 0.1	0.1 0.1	0.19 0.19	0.28 0.28	0.38 0.38	

9.5 Control cabinet installation for devices in the Chassis format

Motor Modules Chassis-2						
Article number	6SL3321-				1TE36-6AA0 1TE37-4AA0 1TE38-1AA0 1TE38-8AA0 1TE41-0AA0 1TE41-1AA0 1TE41-2AA0 1TE41-3AA0 1TE41-5AA0	
Cooling air requirement	[m³/s]				0.64	
Min. opening cross-section in cabinet inlet outlet	[m²] [m²]				0.38 0.28	

9.5 Control cabinet installation for devices in the Chassis format

Description

Carefully observe the following notes regarding the installation of Chassis format power units (Active Interface Modules, Basic Line Modules, Smart Line Modules, Active Line Modules, Motor Modules) and the additional power components in a control cabinet or in an appropriately secured electrical room:

- When screwing to the mounting surface of the control cabinet, use all attachment points of the power units and/or the additional power components.

 The attachment points are shown in the dimension drawings.
- Use screws of property class 8.8 in accordance with DIN EN ISO 898-1.
- Use large washers, e.g. in accordance with ISO 7093 or ISO 7094.
- Use spring washers, e.g. in accordance with DIN 6796.

Mechanical support

For increased requirements relating to the mechanical stability, a mechanical support must be provided below the power units. For instance, a frame or a foot can be used.

The mechanical load of the power unit can be better distributed by using a suitably designed mechanical support.

The mechanical support must be designed and built for the specific system; however, it must not have a negative impact on the ventilation clearance.

9.6 Control cabinet installation for devices in the Chassis-2 format

9.6.1 Installing the devices in a Rittal VX25 control cabinet

9.6.1.1 Installing an Active Line Modules Chassis-2 or Motor Modules Chassis-2

Description

To install an Active Line Module Chassis-2 or Motor Module in a Rittal VX25 control cabinet, you require a baseplate and a mounting plate for the rear panel of the control cabinet.

Models of the individual parts are also available in the "DT Configurator", see "DT Configurator (https://www.siemens.com/dt-configurator)".

The following data applies for creating the base plate:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with 2 x 45°.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 2 insert nuts, type KVT M10-H (number ① in the baseplate drawing).

The following data applies for creating the mounting plate for a 400 mm wide control cabinet:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance
 of ±0.15; other dimensions where the tolerance is not specified must have a tolerance
 according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with 2 x 45°.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 4 insert nuts, type KVT PEM-M10-H (number ① in the mounting plate drawing).

9.6 Control cabinet installation for devices in the Chassis-2 format

The following data applies for creating the mounting plate for a 600 mm wide control cabinet:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with $2 \times 45^{\circ}$.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 4 insert nuts, type KVT PEM-M10-H (number ① in the mounting plate drawing).
- To fasten the Control Unit, you require an additional 2 insert nuts, type KVT PEM-M6-SS-2 (number ② in the mounting plate drawing).

To mount the individual parts, you also require in addition:

• 16 screws, type ISO14585 5.5x13 (number ③ in the installation drawing), e.g. Rittal No. VX 5051.018.

Dimension drawings of the spare parts




Figure 9-8 Base plate for a Rittal VX25 control cabinet

9.6 Control cabinet installation for devices in the Chassis-2 format




Figure 9-9 Mounting plate for a 400 mm wide Rittal VX25 control cabinet




Figure 9-10 Mounting plate for a 600 mm wide Rittal VX25 control cabinet

Installing the individual parts




Figure 9-11 Mounting the individual parts in a 400 mm wide Rittal VX25 control cabinet




Figure 9-12 Mounting the individual parts in a 600 mm wide Rittal VX25 control cabinet

9.6.1.2 Installing an Active Interface Modules Chassis-2

Description

To install Active Interface Modules Chassis-2 in a Rittal VX25 control cabinet, you require a console and two mounting plates for the rear panel of the control cabinet.

Models of the individual parts are also available in the "DT Configurator", see "DT Configurator (https://www.siemens.com/dt-configurator)".

The following data applies for creating the console.

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ±0.3; other dimensions - where the tolerance is not specified - must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawing without dimensions must have radius R4.
- All radii shown in the drawing without dimensions must have radius R4.
- All chamfers shown in the drawing without dimensions must be 5x45°
- Material for the console: EN10025-2 S235JRC+N 4 with galvanized surface coating.
- Punched edges should be deburred.
- You require 2 insert nuts, type PEM M10-H (number ① in the console drawing).

The following data applies for creating the mounting plates:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ±0.15; other dimensions - where the tolerance is not specified - must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawing without dimensions must have radius R2.
- All chamfers shown in the drawing without dimensions must be 3x45°.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- For each mounting plate, you require 6 insert nuts, type PEM M10-H (number ① in the mounting plate drawing).

To mount the individual parts, you also require in addition:

- 16 screws, type ISO14585 5.5x13 for fastening the mounting plate (number ② in the installation drawing), e.g. Rittal No. VX 5051.018.
- 8 screws SN60736-C-M8x16 (number ③ in the installation drawing) with M8 captive nuts (number ④, Rittal No. TS 4165.000) for fastening the console.

Dimension drawings of the spare parts




Figure 9-13 Console for a Rittal VX25 control cabinet

9.6 Control cabinet installation for devices in the Chassis-2 format




Figure 9-14 Mounting plate for a Rittal VX25 control cabinet

Installing the individual parts




Figure 9-15 Mounting the individual parts in a 600 mm wide Rittal VX25 control cabinet

9.6.2 Installing the devices in a Rittal TS8 control cabinet

9.6.2.1 Installing an Active Line Modules Chassis-2 or Motor Modules Chassis-2

Description

To install an Active Line Module Chassis-2 or Motor Module in a Rittal TS8 control cabinet, you require a baseplate and a mounting plate for the rear panel of the control cabinet.

Models of the individual parts are also available in the "DT Configurator", see "DT Configurator (https://www.siemens.com/dt-configurator)".

The following data applies for creating the base plate:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with 2 x 45°.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 2 insert nuts, type KVT M10-H (number ① in the baseplate drawing).

The following data applies for creating the mounting plate for a 400 mm wide control cabinet:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with $2 \times 45^{\circ}$.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 4 insert nuts, type KVT PEM-M10-H (number ① in the mounting plate drawing).

The following data applies for creating the mounting plate for a 600 mm wide control cabinet:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawings without dimensions must have radius R2.
- All radii shown in the drawings without dimensions must have radius R4.
- All chamfers shown in the drawings without dimensions must be implemented with $2 \times 45^{\circ}$.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- You require 4 insert nuts, type KVT PEM-M10-H (number ① in the mounting plate drawing).
- To fasten the Control Unit, you require an additional 2 insert nuts, type KVT PEM-M6-SS-2 (number ② in the mounting plate drawing).

To mount the individual parts, you also require in addition:

• 16 screws, type ISO14585 5.5x13 (number ③ in the installation drawing), e.g. Rittal No. VX 5051.018.

Dimension drawings of the spare parts




Figure 9-16 Baseplate for a Rittal TS8 control cabinet




Figure 9-17 Mounting plate for a 400 mm wide Rittal TS8 control cabinet

9.6 Control cabinet installation for devices in the Chassis-2 format




Figure 9-18 Mounting plate for a 600 mm wide Rittal TS8 control cabinet

Installing the individual parts




Figure 9-19 Installing the individual parts in a 400 mm wide Rittal TS8 control cabinet




Figure 9-20 Installing the individual parts in a 600 mm wide Rittal TS8 control cabinet

9.6.2.2 Installing an Active Interface Modules Chassis-2

Description

To install Active Interface Modules Chassis-2 in a Rittal TS8 control cabinet, you require a console and two mounting plates for the rear panel of the control cabinet.

Models of the individual parts are also available in the "DT Configurator", see "DT Configurator (https://www.siemens.com/dt-configurator)".

The following data applies for creating the console.

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.3 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawing without dimensions must have radius R4.
- All radii shown in the drawing without dimensions must have radius R4.
- All chamfers shown in the drawing without dimensions must be 5x45°
- Material for the console: EN10025-2 S235JRC+N 4 with galvanized surface coating.
- Punched edges should be deburred.
- You require 2 insert nuts, type PEM M10-H (number ① in the console drawing).

The following data applies for creating the mounting plates:

- All punch geometry dimensions, where a tolerance is not specified, must have a tolerance of ± 0.15 ; other dimensions where the tolerance is not specified must have a tolerance according to ISO 2768 m-K.
- All bending radii shown in the drawing without dimensions must have radius R2.
- All chamfers shown in the drawing without dimensions must be 3x45°.
- Material for the sheet metal parts: EN10346-DX52D+Z140-M-B-CO-2.5.
- Punched edges should be deburred.
- For each mounting plate, you require 6 insert nuts, type PEM M10-H (number ① in the mounting plate drawing).

To mount the individual parts, you also require in addition:

- 16 screws, type ISO14585 5.5x13 for fastening the mounting plate (number ② in the installation drawing), e.g. Rittal No. VX 5051.018.
- 8 screws SN60736-C-M8x16 (number ③ in the installation drawing) with M8 captive nuts (number ④, Rittal No. TS 4165.000) for fastening the console.

Dimension drawings of the spare parts




Figure 9-21 Console for a Rittal TS8 control cabinet




Figure 9-22 Mounting plate for a Rittal TS8 control cabinet

Installing the individual parts




Figure 9-23 Installing the individual parts in a 600 mm wide Rittal TS8 control cabinet

Maintenance and Servicing 10

10.1 Chapter content

This chapter provides information on the following:

- Maintenance and servicing procedures that have to be carried out on a regular basis to ensure the availability of the components.
- · Exchanging device components when the unit is serviced
- Forming the DC-link capacitors



Not observing fundamental safety instructions and residual risks

Not observing fundamental safety instructions and residual risks listed in Chapter 1 can result in accidents with severe injuries or death.

- Comply with the fundamental safety instructions.
- When assessing the risk, take into account remaining risks.

! WARNING

Electric shock from external supply voltages

When the external power supply or the external 230 V AC auxiliary supply is connected, dangerous voltages are still present in components even when the main switch is open.

Contact with live parts can result in death or serious injury.

 Switch off external supply voltages and external 230 V AC auxiliary supply before opening the device.

10.2 Maintenance

The devices comprise mostly electronic components. Apart from the fan(s), therefore, they contain hardly any components that are subject to wear or that require maintenance or servicing. Maintenance is intended to ensure that the equipment remains in the specified condition. Dirt and contamination must be removed regularly and parts subject to wear replaced.

The following points must generally be observed.

Cleaning

Dust deposits

Dust deposits inside the device must be removed at regular intervals (or at least once a year) by qualified personnel in line with the relevant safety regulations. The unit must be cleaned using a brush and vacuum cleaner, and dry compressed air (max. 1 bar) for areas that cannot be easily reached.

Ventilation

The ventilation openings in the devices must never be obstructed. The fans must be checked to make sure that they are functioning correctly.

Cable and screw terminals

Cable and screw terminals must be checked regularly to ensure that they are secure in position, and if necessary, retightened. Cabling must be checked for defects. Defective parts must be replaced immediately.

Note

Maintenance intervals

The actual intervals at which maintenance procedures are to be performed depend on the installation conditions (cabinet environment) and the operating conditions.

Siemens offers its customers support in the form of a service contract. For further details, contact your regional office or sales office.

10.3 Maintenance

Servicing involves activities and procedures for maintaining and restoring the specified condition of the devices.

Required tools

The following tools are required for replacing components:

- Standard set of tools with screwdrivers, screw wrenches, socket wrenches, etc.
- Torque wrenches 1.5 Nm up to 100 Nm
- 600 mm extension for socket wrenches

Tightening torques for screw connections

The following tightening torques apply when tightening current-conducting connections (DC link connections, motor connections, busbars, lugs) and other connections (ground connections, protective conductor connections, steel threaded connections).

Table 10-1 Tightening torques for screw connections

Thread	Ground connections, protective conductor connections, steel threaded connections	Aluminum threaded connections, plastic, busbars, lugs
M3	1.3 Nm	0.8 Nm
M4	3 Nm	1.8 Nm
M5	6 Nm	3 Nm
M6	10 Nm	6 Nm
M8	25 Nm	13 Nm
M10	50 Nm	25 Nm
M12	88 Nm	50 Nm
M16	215 Nm	115 Nm

Note

Screw connections for protective covers

The threaded connections for the protective covers made of Makrolon may only be tightened with 2.5 Nm.

10.3.1 Installation device

Description

The installation device is used for installing and removing the power blocks for the Basic Line Modules, Smart Line Modules, Active Line Modules, and Motor Modules in chassis format.

The mounting equipment cannot be used for Motor Modules Chassis-2.

It is used as a mounting aid and is placed in front of and secured to the module. The telescopic rails allow the withdrawable device to be adjusted according to the height at which the power blocks are installed. Once the mechanical and electrical connections have been undone, the power block can be removed from the module, whereby the power block is guided and supported by the guide rails on the withdrawable devices.



Figure 10-1 Installation device

Article number

The article number for the installation device is 6SL3766-1FA00-0AA0.

10.3.2 Using crane lifting lugs to transport power blocks

Crane lifting lugs

The power blocks are fitted with crane lifting lugs for transportation on a lifting harness in the context of replacement.

The positions of the crane lifting lugs are illustrated by arrows in the figures below.

NOTICE

Damage to the device due to improper transport

Improper transport can cause mechanical loads on the power block housing or the busbars, which result in damage to the device.

- When transporting the power blocks, use a lifting harness with vertical ropes or chains.
- Do not use the power block busbars to support or secure lifting harnesses.




Figure 10-2 Crane lifting lugs on power block frame size FX, GX, FB

10.3 Maintenance




Figure 10-3 Crane lifting lugs on HX, JX power block

Note

Crane lifting lugs on HX, JX power block

On HX and JX power blocks, the front crane lifting lug is located behind the busbar.




Figure 10-4 Crane lifting lugs on power block frame size GB, GD

Crane lifting lugs for Active Interface Modules Chassis-2

Active Interface Modules Chassis-2 are fitted with crane lifting lugs for transport using a lifting harness to facilitate replacement.




Figure 10-5 Crane lifting lugs for Active Interface Modules Chassis-2

Crane lifting lugs for Active Line Module and Motor Modules Chassis-2

Active Line Modules and Motor Modules Chassis-2 are fitted with crane lifting lugs for transport using a lifting harness to facilitate replacement.

The crane eyelet on the side of the line or motor connections (front view on the right side) is also used to secure the device when tilting it onto its side if this should be required during replacement.




Figure 10-6 Crane lifting lugs for Active Line Module and Motor Module Chassis-2

10.4.1 Safety information



Improper transport and installation of devices and components

Serious injury or even death and substantial material damage can occur if the devices are not transported or installed properly.

- Transport, mount, and remove the devices and components only if you are qualified to do so.
- Take into account that the devices and components are in some cases heavy and topheavy; take the necessary precautionary measures.
 The weights of the individual power blocks are listed in the corresponding section.

10.4.2 Messages after replacement of DRIVE-CLiQ components

After DRIVE-CLiQ components are replaced (Control Interface Module, TM31, SMCxx) when service is required, generally no message is output after power-up, since an identical component is identified and accepted as component when the system boots.

The reason for this is that an identical component is detected and accepted as spare part when running-up. If, unexpectedly, a fault message of the "topology fault" category is displayed, then when replacing a component, one of the following faults/errors should have occurred:

- A Control Interface Module with different firmware data was installed.
- When connecting-up DRIVE-CLiQ cables, connections were interchanged.

Automatic firmware update

A firmware update for the replaced DRIVE-CLiQ component may run automatically after switching on the electronics.

• The following LEDs will flash slowly to indicate that an automatic firmware update is in progress: the "RDY" LED on the Control Unit (orange, 0.5 Hz) and an LED on the relevant DRIVE-CLiQ component (green/red, 0.5 Hz).

Note

Do not shut down the converter

Do not shut down the converter during this process as the firmware update will otherwise have to be started again.

- Once the automatic firmware update is complete, the "RDY" LED on the Control Unit will flash quickly (orange, 2 Hz) along with an LED on the relevant DRIVE-CLiQ component (green/red, 2 Hz).
- To complete the automatic firmware update process, a POWER ON is required (switch the device off and back on again).

10.4.3 Replacing the power block, Active Line Module, and Motor Module, frame size FX

Replacing the power block




Figure 10-7 Replacing the power block, Active Line Module, and Motor Module (type FX)

Preparatory steps

- Disconnect the drive line-up from the power supply
- · Allow unimpeded access to the power block
- Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Unscrew the connection to the line or to the motor (three screws).
- 2. Unscrew the connection to the DC link (four screws).
- 3. Remove the retaining screws at the top (two screws).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 6. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 7. Remove the mounts for the Control Interface Module (two nuts) and carefully pull out the Control Interface Module.
 - When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).
- 8. Disconnect the plug-in connections for the fiber-optic cables and signal cables (five connectors).
- 9. Disconnect the plug for the thermocouple.
- 10. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 66 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.4 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size GX

Replacing the power block




Figure 10-8 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size GX

Preparatory steps

- · Disconnect the drive line-up from the power supply
- Allow unimpeded access to the power block
- Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Unscrew the connection to the line or to the motor (three screws).
- 2. Unscrew the connection to the DC link (four screws).
- 3. Remove the retaining screws at the top (two screws).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Remove DRIVE-CLiQ cables and connections at -X41 / -X42 / -X46 (6 connectors). The DRIVE-CLiQ cables should be marked so that they can be correctly connected at a later time.
- 6. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 7. Remove the mount for the Control Interface Module (one nut) and carefully pull out the Control Interface Module.
 - When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).
- 8. Disconnect the plug-in connections for the fiber optic cables and signal cables (five connectors) and release the cable connectors for the signal cables (two connectors).
- 9. Disconnect the plug for the thermocouple.
- 10. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 89 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

The fiber-optic cable plugs must be remounted at their original slot. Fiber-optic cables and sockets are labeled to ensure that they are assigned correctly (U11, U21, U31).

Note

Connection clip of the integrated basic interference suppression module to ground at the Smart Line Module, frame size GX

The connection clip of the integrated basic interference suppression module to ground is mounted on the spare power block together with a yellow warning label.

Please note the information in the chapter "Electrical connection" of the corresponding device.

10.4.5 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size HX

Replacing the left-hand power block




Figure 10-9 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size HX - left power block

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access to the power block
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the busbar (six screws).
- 2. Unscrew the connection to the DC link (eight nuts).
- 3. Remove the retaining screw at the top (one screw).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Disconnect the plug-in connections for the fiber-optic cables and signal cables (two connectors).
- 6. Remove the connection for the current transformer and associated PE connection (one connector).
- 7. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 64 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

Replacing the right-hand power block




Figure 10-10 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size HX - right power block

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access to the power block
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the busbar (twelve screws).
- 2. Unscrew the connection to the DC link (eight nuts).
- 3. Remove the retaining screw at the top (one screw).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Disconnect the plug-in connections for the fiber-optic cables and signal cables (two connectors).
 - The second plug connection for the fiber optic cables cannot be disconnected until the power block has been pulled out slightly.
- 6. Remove the connection for the current transformer and associated PE connection (two connectors).
- 7. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 86 kg!

The second plug connection for the fiber optic cables cannot be disconnected until the power block has been pulled out slightly (see Step 5).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.6 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Replacing the power block




Figure 10-11 Replacing the power block, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Preparatory steps

- · Disconnect the drive line-up from the power supply
- Allow unimpeded access to the power block
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Unscrew the connection to the line or to the motor (eight screws).
- 2. Unscrew the connection to the DC link (eight nuts).
- 3. Remove the retaining screw at the top (one screw).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Disconnect the plug-in connections for the fiber-optic cables and signal cables (three connectors).
- 6. Remove the connection for the current transformer and associated PE connection (one connector).
- 7. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 90 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

• When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.7 Replacing the power block, Basic Line Module, frame size FB

Replacing the power block




Figure 10-12 Replacing the power block, Basic Line Module, frame size FB

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access to the power block
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Unscrew the connection to the DC link (four screws).
- 2. Unscrew the connection to the line connection (six screws).
- 3. Remove the retaining screws at the top (two screws).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Remove DRIVE-CLiQ cables and connections at -X41 / -X42 / -X46 (6 connectors). The DRIVE-CLiQ cables should be marked so that they can be correctly connected at a later time.
- 6. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 7. Remove the mounts for the Control Interface Module (one screw and two nuts) and carefully pull out the Control Interface Module.
 - When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).
- 8. Disconnect the plug for the thermocouple.
- 9. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 65 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

• When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

Note

Connection clip of the integrated basic interference suppression module to ground

The connection clip of the integrated basic interference suppression module to ground is mounted on the spare power block together with a yellow warning label.

Please note the information in the chapter "Electrical connection" of the corresponding device.

10.4.8 Replacing the power block, Basic Line Module GB, GD

Replacing the power block




Figure 10-13 Replacing the power block, Basic Line Module, frame sizes GB, GD

Preparatory steps

- Disconnect the drive line-up from the power supply
- · Allow unimpeded access to the power block
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Unscrew the connection to the DC link (six screws).
- 2. Unscrew the connection to the line connection (nine screws).
- 3. Remove the retaining screws at the top (four screws).
- 4. Remove the retaining screws at the bottom (two screws).
- 5. Remove DRIVE-CLiQ cables and connections at -X41 / -X42 / -X46 (6 connectors). The DRIVE-CLiQ cables should be marked so that they can be correctly connected at a later time.
- 6. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 7. Remove the mounts for the Control Interface Module (two nuts) and carefully pull out the Control Interface Module.
 - When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).
- 8. Disconnect the plug for the thermocouple.
- 9. Unscrew the two retaining screws for the fan and attach the equipment for assembling the power block at this position.

You can now remove the power block.

Note

The power block weighs approx. 135 kg!

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the power block is removed. This can cause the device to fail.

• When removing the power block, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

Note

Connection clip of the integrated basic interference suppression module to ground

The connection clip of the integrated basic interference suppression module to ground is mounted on the spare power block together with a yellow warning label.

Please note the information in the chapter "Electrical connection" of the corresponding device.

10.4.9 Replacing the Control Interface Module, Active Line Module and Motor Module, frame size FX

Replacing the Control Interface Module




Figure 10-14 Replacing the Control Interface Module, Active Line Module and Motor Module, frame size FX

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the mount for the CU320 (one nut).
- 2. Disconnect the plug-in connections for the fiber-optic cables and signal cables (five connectors).
- 3. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 4. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 5. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item (5)): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.10 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size GX

Replacing the Control Interface Module




Figure 10-15 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size GX

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the mount for the CU320 (one nut).
- 2. Disconnect the plug-in connections for the fiber-optic cables and signal cables (five connectors).
- 3. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 4. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 5. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item (5)): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.11 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size HX

Replacing the Control Interface Module




Figure 10-16 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size HX

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the mount for the CU320 (one nut).
- 2. Disconnect the plug-in connections for the fiber-optic cables and signal cables (five connectors).
- 3. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 4. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 5. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item (5)): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.12 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Replacing the Control Interface Module




Figure 10-17 Replacing the Control Interface Module, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Preparatory steps

- · Disconnect the drive line-up from the power supply
- · Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the mount for the CU320 (one nut).
- 2. Disconnect the plug-in connections for the fiber-optic cables and signal cables (five connectors).
- 3. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 4. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 5. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item (5)): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

The fiber-optic cable plugs must be remounted at their original slot. Fiber-optic cables and sockets are labeled to ensure that they are assigned correctly (U11, U21, U31).

10.4.13 Replacing the Control Interface Module, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4, FS4+

Replacing the Control Interface Module




Figure 10-18 Replacing Control Interface Module, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4+, FS4+ Part 1




Figure 10-19 Replacing Control Interface Module, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4, FS4+ Part 2

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover
- Withdraw all plug connectors to the signal connections (-X9, -X41 ... -X49, -X400 ... -X402).
- When being removed from the electrical cabinet, the device must be carefully secured so that it can either topple over nor roll away.

Removal

The removal step numbering corresponds to the numbers in the diagrams.

- 1. Open the service flap for the Control Interface Module (2 screws).
- 2. Withdraw the plug connectors for the current transformers X431 X433 (3 plug connectors).
- 3. Withdraw the plug connectors for the temperature sensors X31, X32 (\cdot 2 plug connectors) and the fan control X50 (1 plug connector).
- 4. Withdraw the plug connectors of the fiber-optic cables U11, U21, U31 (3 plug connectors).
- 5. Withdraw the plug connector for the DC link voltage sensing X60 (1 plug connector).
- 6. Withdraw the plug connector for the 24 V DC control X271 (1 plug connector at the lower module).
- 7. Withdraw the plug connector for the internal fan X272 (1 plug connector at the lower module).
- 8. Press the interlocking of the front cover for the signal connections and remove the cover.
- 9. Remove the retaining screws of the Control Interface Module (5 screws).

You can now remove the Control Interface Module.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can be damaged when withdrawing the Control Interface Module, which can result in a device failure.

• When withdrawing the Control Interface Module, ensure that you do not damage any signal cables.

Transferring the IPD card

When replacing the Control Interface Module with a replacement part, after removing the defective module, the IPD card must be transferred into the replacement part.

The IPD card contains the internal device data; it is not included with a replacement Control Interface Module.

Remove the IPD Card:

Open the locking mechanism and withdraw the IPD card from the Control Interface Module.

Insert the IPD card:

Insert the IPD card into the slot until the locking mechanism engages.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item ③): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

The fiber-optic cable plugs must be remounted at their original slot. To ensure a correct assignment, the fiber-optic cables and the slots on the module are labeled (U11, U21, U31); the same is true for the plug connections for the current transformers (X431, X432, X433).

10.4.14 Replacing the Control Interface Module, Basic Line Module, frame size FB

Replacing the Control Interface Module




Figure 10-20 Replacing the Control Interface Module, Basic Line Module, frame size FB

Preparatory steps

- · Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Disconnect the plugs for the signal cables (two connectors).
- 2. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 3. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 4. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item 4): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.15 Replacing the Control Interface Module, Basic Line Module, frame size GB, GD

Replacing the Control Interface Module




Figure 10-21 Replacing the Control Interface Module, Basic Line Module, frame sizes GB, GD

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Disconnect the plugs for the signal cables (two connectors).
- 2. Remove DRIVE-CLiQ cables and connections at -X41/-X42/-X46 (six connectors). The DRIVE-CLiQ cables should be marked to ensure that they are subsequently correctly inserted.
- 3. Take out the retaining screws for the IPD card (two screws) and remove the IPD card from plug -X45 on the Control Interface Module.
- 4. Remove the retaining screws for the Control Interface Module (two screws).

When removing the Control Interface Module, you have to disconnect five additional plugs one after the other (two at the top, three below).

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the Control Interface Module is removed. This can cause the device to fail.

 When removing the Control Interface Module, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the Control Interface Module (M6 x 16, item 4): 6 Nm.

Note

Specifications for the installation

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

Carefully insert the plug-in connections and ensure that they are secure.

10.4.16 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame sizes FX, GX




Figure 10-22 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame sizes FX, GX

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the front cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- Remove the retaining screws for the fan (2 for FX; 3 for GX).
- 2. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.17 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame size HX

Replacing the fan (left-hand power block)




Figure 10-23 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame size HX - left power block

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the busbar (six screws).
- 2. Remove the retaining screws for the fan (three screws).
- 3. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

Replacing the fan (right-hand power block)




Figure 10-24 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame size HX - right power block

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the busbars (twelve screws).
- 2. Remove the retaining screws for the fan (three screws).
- 3. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.18 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame size JX




Figure 10-25 Replacing the fan, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the busbar (eight screws).
- 2. Remove the retaining screws for the fan (three screws).
- 3. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.19 Replacing the fan, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4, FS4+




Figure 10-26 Replacing the fan, Active Line Module and Motor Module Chassis-2, frame size FS2, FS2+, FS4, FS4+

Description

The fan does not operate continuously, but only when required; it is monitored in operation.

The expected remaining operating time of the fan can be read-out from parameter p0277 "Heat sink fan wear counter".

500 hours before reaching the maximum operating duration, Alarm A30042 "Power unit: Fan has reached the maximum operating hours" indicated with alarm value "0" in r2124.

When reaching 99 % of the maximum operating duration, Alarm A30042 is output with alarm value "1" in r2124.

When reaching the maximum operating duration, Alarm A30042 is output with alarm value "2" in r2124.

If the fan no longer operates correctly, then this is signaled using Alarm A30048 "Power unit: Fan defective" with alarm value "0" is indicated in r2124.

If the fan does not correctly operate within 10 seconds after powering up after the pulses have been enabled, then fault F30058 "Power Unit: Heat sink fan defective" is displayed and shut down with OFF2.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the retaining screws for the Control Interface Module (2 screws).
- 2. Completely remove the fan assembly from the device. The power supply automatically disengages when withdrawing.

NOTICE

Secure the fan module so that cannot topple over

When withdrawing the fan module, the module housing or the plug connector can be damaged if the module is not secured to prevent it toppling over.

• Carefully withdraw the fan module and secure it so that it cannot topple over.

Installation steps

NOTICE

Checking the contacts of the new fan assembly to ensure that they are not damaged

A damaged plug connector of the new fan assembly can damage the mating contacts when inserting the assembly into the housing.

• Before inserting the new fan assembly, check that the plug connections are not damaged.

Note

Sealing surface at the upper side of the new fan assembly

When mounting, ensure that the seal on the upper side of the new fan assembly is in a good condition.

To reinstall, perform the above steps in reverse order. The power supply automatically engages when inserting.

The tightening torque of the retaining screws for the fan assembly is 10 Nm.

10.4.20 Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame sizes FS2, FS2+, FS4, FS4+

Replacing the electronic fan




Figure 10-27 Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame sizes FS2, FS2+, FS4+, FS4+, Part 1

Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame sizes FS2, FS2+, FS4





Figure 10-28 Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame sizes FS2, FS2+, FS4, Part 2






Figure 10-29 Replacing the electronic fan, Active Line Modules and Motor Module Chassis-2, frame size FS4+, Part 2

Description

The service life of the electronic fan is designed for the typical service life of the device itself - it doesn't operate continuously, but only when required. The electronic fan is monitored in operation.

If the fan no longer operates correctly, then this is signaled using Alarm A30048 "Power unit: Fan defective" with alarm value "1" in r2124.

If, with Alarm A30048 active, the measured air intake temperature indicated in r0037[3] violates an appropriate threshold, then fault F30059 "Power unit: Interior fan defective" is displayed, and the system is shut down with OFF2.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover
- After it has been removed from the electrical cabinet, the device must be secured so that it can either topple over nor roll away.

Removal

The removal step numbering corresponds to the numbers in the diagrams.

- 1. Open the service flap for the Control Interface Module (2 screws).
- 2. Withdraw the plug connector for the electronic fan the power supply.
- 3. Release the retaining screws for the electronic fan (2 screws).
- 4. Remove the electronic fan.

Installation steps

To reinstall, perform the above steps in reverse order.

Tightening torque for the retaining screws of the electronic fan (M6 x 16, item ③): 6 Nm.

Note

Pay attention to the tightening torques

10.4.21 Replacing the fan, Active Interface Module, frame size FI




Figure 10-30 Replacing the fan, Active Interface Module, frame size FI

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the retaining screws for the fan unit (two screws).
- 2. Unplug connector -X630.

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.22 Replacing the fan, Active Interface Module, frame size GI




Figure 10-31 Replacing the fan, Active Interface Module, frame size GI

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply.
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the retaining screws for the fan unit (3 screws).
- 2. Unplug connector -X630.

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.23 Replacing the fan, Active Interface Module, frame size HI




Figure 10-32 Replacing the fan, Active Interface Module, frame size HI

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the retaining screws for the fan unit (3 screws).
- 2. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.24 Replacing the fan, Active Interface Module, frame size JI




Figure 10-33 Replacing the fan, Active Interface Module, frame size JI

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Remove the retaining screws for the fan unit (3 screws).
- 2. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.25 Replacing the fan, Active Interface Module Chassis-2




Figure 10-34 Replacing the fan, Active Interface Module Chassis-2

Description

The typical service life of the device fan is 40,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and may therefore deviate from this value.

The fan must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Loosen the retaining screws of the bottom cover (4 screws) and remove the cover.
- 2. Remove the retaining screws for the fan assembly (6 screws).
- 3. Release the connector for the fan supply and remove it.
- 4. Release the cable from the cable holder.
- 5. Completely remove the fan assembly from the device.

Installation steps

To reinstall, perform the above steps in reverse order.

The tightening torque of the retaining screws for the fan assembly is 10 Nm.

The tightening torque for the plug connector fastening screws for the fan power supply is 0.5 ... 0.6 Nm.

The tightening torque of the retaining screws of the bottom cover is 10 Nm.

10.4.26 Replacing the fan, Basic Line Module, frame sizes FB, GB, GD




Figure 10-35 Replacing the fan, Basic Line Module, frame sizes FB, GB and GD

Description

The average service life of the device fans is 50,000 hours. In practice, however, the service life depends on other variables (e.g. ambient temperature, degree of cabinet protection, etc.) and, therefore, may deviate from this value.

The fans must be replaced in good time to ensure that the device is available.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- Remove the retaining screws for the fan (two screws for frame size FB, three screws for frame size GB)
- 2. Disconnect the supply cables (1 x "L", 1 x "N").

You can now carefully remove the fan.

NOTICE

Damage to the device if signal cables become damaged during removal

Signal cables can become damaged when the fan is removed. This can cause the device to fail.

• When removing the fan, ensure that you do not damage any signal cables.

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

10.4.27 Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size HX

Replacing the DC fuses




Figure 10-36 Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size HX

10.4 Replacing components

Description

The DC fuses are installed in a fuse insert. To replace the fuses, the fuse insert be removed.

NOTICE

Device failure after a DC fuse trips

The neighboring DC fuses may also become damaged if a DC fuse trips. Failure to replace all fuses at the same time can cause the device to fail.

• After a DC fuse trips, always replace all DC fuses at the same time. Always use fuses of the same type.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Release the DC connections at DCP and DCN (four screws each)
- 2. Remove nuts (eight screws)
- 3. Remove the retaining screws for the connection plate of the housing (four screws) and remove the connection plate
- 4. Remove the retaining screw for the fuse insert (one screw)

You can now remove the fuse insert.

NOTICE

Damage to the device if signal cables or plastic parts become damaged during removal

Signal cables or plastic parts can become damaged when the fuse insert is removed. This can cause the device to fail.

• When removing the fuse insert, ensure that you do not damage any signal cables or plastic parts.

You can then replace the DC fuses.

10.4 Replacing components

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

10.4.28 Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Replacing the DC fuses




Figure 10-37 Replacing the DC fuses, Smart Line Module, Active Line Module, and Motor Module, frame size JX

Description

The DC fuses are installed in a fuse insert. To replace the fuses, the fuse insert be removed.

NOTICE

Device failure after a DC fuse trips

The neighboring DC fuses may also become damaged if a DC fuse trips. Failure to replace all fuses at the same time can cause the device to fail.

• After a DC fuse trips, always replace all DC fuses at the same time. Always use fuses of the same type.

Preparatory steps

- Disconnect the drive line-up from the power supply
- Allow unimpeded access
- · Remove the protective cover

Removal

The removal steps are numbered in accordance with the numbers in the diagram.

- 1. Release the DC connections at DCP and DCN (four screws each)
- 2. Remove nuts (eight screws)
- 3. Remove the retaining screws for the connection plate of the housing (four screws) and remove the connection plate
- 4. Remove the retaining screw for the fuse insert (one screw)

You can now remove the fuse insert.

NOTICE

Damage to the device if signal cables or plastic parts become damaged during removal

Signal cables or plastic parts can become damaged when the fuse insert is removed. This can cause the device to fail.

• When removing the fuse insert, ensure that you do not damage any signal cables or plastic parts.

You can then replace the DC fuses.

10.4 Replacing components

Installation steps

To reinstall, perform the above steps in reverse order.

Note

Pay attention to the tightening torques

The tightening torques specified in the table "Tightening torques for screw connections" must be observed.

10.4.29 Replacement of the fan fuses

Basic Line Modules, Smart Line Modules, Active Line Modules and Motor Modules of the Chassis design contain fan fuses (-F10/-F11), which can be replaced in the event of failure.

Active Line Modules and Motor Modules of the Chassis-2 design do not contain any fan fuses, these must be provided on terminal strip X51 at the plant.

Article numbers for replacing fan fuses that have blown can be found in the spare parts list.

Note

Removing fault causes

Make sure that the cause of the fault is found before the fuse is replaced.

10.5 Long time storage of replacement parts

10.5.1 Storing fans for devices in the Chassis-2 format

When replacement fans are stored, the fan bearings are subject to an aging process. This can result in a higher level of wear and in turn, premature fan failure.

For replacement fans for Active Interface Module, Active Line Module and Motor Module in the Chassis-2 format, the following constraints must be taken into consideration.

Storing fans for Active Line Modules and Motor Modules in the Chassis-2 format

In order to guarantee perfect operation and the longest possible service life, do not store the device for more than one year.

Storing electronic fans for Active Line Modules and Motor Modules in the Chassis-2 format

If stored for longer periods of time, the fan should be operated for approximately 15 minutes every year in order to move the motor bearings.

Storing fans for Active Interface Modules in the Chassis-2 format

Avoid excessively long storage times; we recommend a maximum one year (for longer periods of time, contact the manufacturer before commissioning).

- Before installing, carefully check the motor bearings to ensure that they function correctly.
- Recommendation: Regularly rotate the fan impeller to prevent it from seizing up and damaging the bearings.

10.6 Forming the DC link capacitors

10.6 Forming the DC link capacitors

Description

If the Basic Line Module, Smart Line Module, Active Line Module, and Motor Module have not been used for more than two years, the DC link capacitors must be reformed. If this is not carried out, the units could be damaged when the DC link voltage is connected under load.

If the cabinet is commissioned within two years of its date of manufacture, then the DC link capacitors do not need to be reformed. The date of manufacture can be taken from the serial number on the nameplate.

Note

Storage period

It is important that the storage period is calculated from the date of manufacture and not from the date that the equipment was shipped.

Nameplate

SIEMENS




Figure 10-38 Nameplate using an Active Line Module as example

Date of manufacture

The date of manufacture can be determined as follows:

Table 10- 2 Production year and month

Character	Year of manufacture	Character	Month of manufacture
А	2010	1 9	January to September
В	2011	0	October
С	2012	N	November
D	2013	D	December
Е	2014		
F	2015		
Н	2016		
J	2017		
K	2018		
L	2019		
М	2020		
N	2021		
Р	2022		
R	2023		
S	2024		
Т	2025		
U	2026		
V	2027		
W	2028		
Х	2029		

Procedure in the event of repair or replacement

A replacement Line Module or Motor Module or the corresponding replacement power block has to be formed after being in storage for a period of more than two years.

The DC link capacitors are formed by connecting the line voltage without any load connected for at least 30 minutes.

To do this, the DC link must be precharged (i.e. the Line Modules switched on), while the controller for the existing Motor Modules must not be enabled for the specified length of time.

Procedure for reforming outside the drive line-up

Replacement power units which have to be held ready for immediate use in the event of repair or replacement can also be re-formed individually and outside the drive line-up.

For this, the equipment must be connected to the forming circuits described in the following.

Components for the forming circuit (recommendation)

- 1 fuse switch 3-phase 400 V / 10 A or 690 V / 10 A
- 3 incandescent lamps 230 V / 100 W for a line voltage of 3 AC 380 to 480 V. Alternatively, use three resistors of 1 k Ω / 100 W each (e.g. GWK150J1001KLX000 from Vishay) instead of the incandescent lamps.
- 6 incandescent lamps 230 V / 100 W for a line voltage of 3 AC 500 to 690 V, where two incandescent lamps must be connected in series in each supply phase.
 Alternatively, use three resistors of 1 kΩ / 160 W each (e.g. GWK200J1001KLX000 from Vishay) instead of the incandescent lamps.
- Various small components, such as lamp sockets, cable 1.5 mm², etc.



MWARNING

Electric shock when lamp sockets are installed so that they are not insulated

If two incandescent lamps connected in series are used, the insulation of the lamp sockets is not designed for a high voltage of 3 AC 500 to 690 V. Touching live parts can result in death or serious injury.

• For a line voltage of 500 to 690 V 3-ph AC, install the two lamp sockets connected in series so that they are carefully insulated - and protect them so that they cannot be touched.

Forming circuit for Line Modules

Note

Forming the Line Modules

Voltage must be supplied to Line Modules via a connected Motor Module and the associated DC link.




Figure 10-39 Forming circuit for Line Modules

Forming circuit for Motor Modules




Figure 10-40 Forming circuit for Motor Modules

Procedure

- It is not permissible that the device being formed receives a power-on command (e.g. from the keyboard, BOP20 or terminal strip).
- Connect the appropriate forming circuit.
- Forming has been completed if the DC link voltage no longer increases.

Maintaining the operational readiness of individual power blocks for servicing

It is recommended that during the planned downtimes, the power blocks positioned on the line side are replaced in order to guarantee the correct functioning of the power blocks during servicing.

10.7 Recycling and disposal



For environmentally friendly recycling and disposal of your old device, please contact a company certified for the disposal of old electrical and electronic devices and dispose of the device in accordance with the regulations in your country.

Appendix

A.1 Cable lugs

Cable lugs

The cable connections on the devices are designed for cable lugs according to DIN 46234 or DIN 46235.

For connection of alternative cable lugs, the maximum dimensions are listed in the table below.

These cable lugs are not to exceed these dimensions, as mechanical fastening and adherence to the voltage distances is not guaranteed otherwise.




Figure A-1 Dimensions of the cable lugs

Table A- 1 Dimensions of the cable lugs

Screw / bolts	Connection cross- section [mm²]	d2 [mm]	b [mm]	l [mm]	c1 [mm]	c2 [mm]
M8	70	8.4	24	55	13	10
M10	185	10.5	37	82	15	12
M10	240	13	42	92	16	13
M12	95	13	28	65	16	13
M12	185	13	37	82	16	13
M12	240	13	42	92	16	13
M16	240	17	42	92	19	16

Attaching 2 cable lugs per phase

The cable lugs can be attached as shown in the following diagram if 2 cable lugs must be connected at each phase connection.



Figure A-2 2 cable lugs per connection

Cable lugs for devices of the Chassis-2 design

The cable connections for the line or motor connection to the Active Line Modules and Motor Modules of the Chassis-2 design are designed for M12 cable lugs according to the following representation.

When connecting alternative cable lugs, the maximum dimensions are listed in the following table.

These cable lugs are not to exceed these dimensions, as otherwise mechanical fastening and compliance with the voltage clearances is not guaranteed.




Figure A-3 Dimensions of the cable lugs

Table A- 2 Dimensions of the cable lugs

Screw / bolts	Connection cross-section [mm²]	d2 [mm]	b [mm]	l [mm]	c1 [mm]	c2 [mm]
M12	240	13	43	87	24	24

Note

The following list of abbreviations includes all abbreviations and their meanings used in the entire SINAMICS family of drives.

Abbreviation	Derivation of abbreviation	Meaning
Α	·	•
A	Alarm	Alarm
AC	Alternating Current	Alternating current
ADC	Analog Digital Converter	Analog digital converter
Al	Analog Input	Analog input
AIM	Active Interface Module	Active Interface Module
ALM	Active Line Module	Active Line Module
AO	Analog Output	Analog output
AOP	Advanced Operator Panel	Advanced Operator Panel
APC	Advanced Positioning Control	Advanced Positioning Control
AR	Automatic Restart	Automatic restart
ASC	Armature Short-Circuit	Armature short-circuit
ASCII	American Standard Code for Information Interchange	American coding standard for the exchange of information
AS-i	AS-Interface (Actuator Sensor Interface)	AS-Interface (open bus system in automation technology)
ASM	Asynchronmotor	Induction motor
AVS	Active Vibration Suppression	Active vibration suppression
В		
BB	Betriebsbedingung	Operating condition
BERO	-	Contactless proximity switch
BI	Binector Input	Binector input
BIA	Berufsgenossenschaftliches Institut für Arbeitssicherheit	BG Institute for Occupational Safety and Health
BICO	Binector Connector Technology	Binector connector technology
BLM	Basic Line Module	Basic Line Module
ВО	Binector Output	Binector output
ВОР	Basic Operator Panel	Basic Operator Panel
С		
С	Capacitance	Capacitance
C	-	Safety message
CAN	Controller Area Network	Serial bus system
CBC	Communication Board CAN	Communication board CAN
CBE	Communication Board Ethernet	PROFINET communication module (Ethernet)
CD	Compact Disc	Compact disc
CDS	Command Data Set	Command data set
CF Card	CompactFlash Card	CompactFlash card
CI	Connector Input	Connector input

Abbreviation	Derivation of abbreviation	Meaning
CLC	Clearance Control	Clearance control
CNC	Computerized Numerical Control	Computerized numerical control
CO	Connector Output	Connector output
CO/BO	Connector Output/Binector Output	Connector output/binector output
COB-ID	CAN Object-Identification	CAN object identification
CoL	Certificate of License	Certificate of License
СОМ	Common contact of a change-over relay	Common contact of a change-over relay
СОММ	Commissioning	Commissioning
СР	Communication Processor	Communications processor
CPU	Central Processing Unit	Central processing unit
CRC	Cyclic Redundancy Check	Cyclic redundancy check
CSM	Control Supply Module	Control Supply Module
CU	Control Unit	Control Unit
CUA	Control Unit Adapter	Control Unit Adapter
CUD	Control Unit DC	Control Unit DC
	Control Offit DC	Control offit DC
D DAC	District Angles Converter	Digital analog converter
	Digital Analog Converter	Digital analog converter
DC	Direct Current	Direct current
DCB	Drive Control Block	Drive Control Block
DCBRK	DC Brake	DC braking
DCC	Drive Control Chart	Drive Control Chart
DCN	Direct Current Negative	Direct current negative
DCP	Direct Current Positive	Direct current positive
DDC	Dynamic Drive Control	Dynamic Drive Control
DDS	Drive Data Set	Drive Data Set
DI	Digital Input	Digital input
DI/DO	Digital Input/Digital Output	Digital input/output, bidirectional
DMC	DRIVE-CLiQ Hub Module Cabinet	DRIVE-CLiQ Hub Module Cabinet
DME	DRIVE-CLiQ Hub Module External	DRIVE-CLiQ Hub Module External
DMM	Double Motor Module	Double Motor Module
DO	Digital Output	Digital output
DO	Drive Object	Drive object
DP	Decentralized Peripherals	Decentralized peripherals
DPRAM	Dual Ported Random Access Memory	Dual-Port Random Access Memory
DQ	DRIVE-CLiQ	DRIVE-CLiQ
DRAM	Dynamic Random Access Memory	Dynamic Random Access Memory
DRIVE-CLiQ	Drive Component Link with IQ	Drive Component Link with IQ
DSC	Dynamic Servo Control	Dynamic Servo Control
DSM	Doppelsubmodul	Double submodule
DTC	Digital Time Clock	Timer
E		1
EASC	External Armature Short-Circuit	External armature short-circuit
EDS	Encoder Data Set	Encoder data set
EEPROM	Electrically Erasable Programmable Read-Only Memory	Electrically Erasable Programmable Read-Only Memory
EGB	Elektrostatisch gefährdete Baugruppen	Electrostatically sensitive devices

Abbreviation	Derivation of abbreviation	Meaning
EIP	EtherNet/IP	EtherNet Industrial Protocol (real-time Ethernet)
ELCB	Earth Leakage Circuit Breaker	Residual current operated circuit breaker
ELP	Earth Leakage Protection	Ground-fault monitoring
EMC	Electromagnetic Compatibility	Electromagnetic compatibility
EMF	Electromotive Force	Electromotive force
EMK	Elektromotorische Kraft	Electromotive force
EMV	Elektromagnetische Verträglichkeit	Electromagnetic compatibility
EN	Europäische Norm	European standard
EnDat	Encoder-Data-Interface	Encoder interface
EP	Enable Pulses	Pulse enable
EPOS	Einfachpositionierer	Basic positioner
ES	Engineering System	Engineering system
ESB	Ersatzschaltbild	Equivalent circuit diagram
ESD	Electrostatic Sensitive Devices	Electrostatically sensitive devices
ESM	Essential Service Mode	Essential service mode
ESR	Extended Stop and Retract	Extended stop and retract
F	·	
F	Fault	Fault
FAQ	Frequently Asked Questions	Frequently Asked Questions
FBLOCKS	Free Blocks	Free function blocks
FCC	Function Control Chart	Function control chart
FCC	Flux Current Control	Flux current control
FD	Function Diagram	Function diagram
F-DI	Failsafe Digital Input	Fail-safe digital input
F-DO	Failsafe Digital Output	Fail-safe digital output
FEPROM	Flash-EPROM	Non-volatile write and read memory
FG	Function Generator	Function generator
FI	-	Fault current
FOC	Fiber-Optic Cable	Fiber-optic cable
FP	Funktionsplan	Function diagram
FPGA	Field Programmable Gate Array	Field Programmable Gate Array
FW	Firmware	Firmware
G		
GB	Gigabyte	Gigabyte
GC	Global Control	Global control telegram (broadcast telegram)
GND	Ground	Reference potential for all signal and operating voltages, usually defined as 0 V (also referred to as M)
GSD	Gerätestammdatei	Generic Station Description: Describes the features of a PROFIBUS slave
GSV	Gate Supply Voltage	Gate supply voltage
GUID	Globally Unique Identifier	Globally Unique Identifier
Н		
HF	High frequency	High frequency
HFD	Hochfrequenzdrossel	Radio frequency reactor
HLA	Hydraulic Linear Actuator	Hydraulic linear actuator

Abbreviation	Derivation of abbreviation	Meaning
HLG	Hochlaufgeber	Ramp-function generator
НМ	Hydraulic Module	Hydraulic Module
НМІ	Human Machine Interface	Human Machine Interface
HTL	High-Threshold Logic	Logic with high interference threshold
HW	Hardware	Hardware
I		
i. V.	In Vorbereitung	Under development: This property is currently not available
I/O	Input/Output	Input/output
I2C	Inter-Integrated Circuit	Internal serial data bus
IASC	Internal Armature Short-Circuit	Internal armature short-circuit
IBN	Inbetriebnahme	Commissioning
ID	Identifier	Identification
IE	Industrial Ethernet	Industrial Ethernet
IEC	International Electrotechnical Commission	International Electrotechnical Commission
IF	Interface	Interface
IGBT	Insulated Gate Bipolar Transistor	Insulated gate bipolar transistor
IGCT	Integrated Gate-Controlled Thyristor	Semiconductor power switch with integrated control electrode
IL	Impulslöschung	Pulse suppression
IP	Internet Protocol	Internet Protocol
IPO	Interpolator	Interpolator
IT	Isolé Terre	Non-grounded three-phase line supply
IVP	Internal Voltage Protection	Internal voltage protection
J	•	<u> </u>
JOG	Jogging	Jogging
K		
KDV	Kreuzweiser Datenvergleich	Data cross-check
KHP	Know-how protection	Know-how protection
KIP	Kinetische Pufferung	Kinetic buffering
Кр	-	Proportional gain
KTY84-130	-	Temperature sensor
L	•	•
L	-	Symbol for inductance
LED	Light Emitting Diode	Light emitting diode
LIN	Linearmotor	Linear motor
LR	Lageregler	Position controller
LSB	Least Significant Bit	Least significant bit
LSC	Line-Side Converter	Line-side converter
LSS	Line-Side Switch	Line-side switch
LU	Length Unit	Length unit
LWL	Lichtwellenleiter	Fiber-optic cable
М		•
М	-	Symbol for torque
М	Masse	Reference potential for all signal and operating voltages, usually defined as 0 V (also referred to as GND)

Abbreviation	Derivation of abbreviation	Meaning
MB	Megabyte	Megabyte
MCC	Motion Control Chart	Motion Control Chart
MDI	Manual Data Input	Manual data input
MDS	Motor Data Set	Motor data set
MLFB	Maschinenlesbare Fabrikatebezeichnung	Machine-readable product code
MM	Motor Module	Motor Module
MMC	Man-Machine Communication	Man-machine communication
MMC	Micro Memory Card	Micro memory card
MSB	Most Significant Bit	Most significant bit
MSC	Motor-Side Converter	Motor-side converter
MSCY_C1	Master Slave Cycle Class 1	Cyclic communication between master (class 1) and slave
MSR	Motorstromrichter	Motor-side converter
MT	Messtaster	Probe
N		
N. C.	Not Connected	Not connected
N	No Report	No report or internal message
NAMUR	Normenarbeitsgemeinschaft für Mess- und Regeltechnik in der chemischen Industrie	Standardization association for measurement and control in chemical industries
NC	Normally Closed (contact)	NC contact
NC	Numerical Control	Numerical control
NEMA	National Electrical Manufacturers Association	Standardization association in USA (United States of America)
NM	Nullmarke	Zero mark
NO	Normally Open (contact)	NO contact
NSR	Netzstromrichter	Line-side converter
NTP	Network Time Protocol	Standard for synchronization of the time of day
NVRAM	Non-Volatile Random Access Memory	Non-volatile read/write memory
0		
OA	Open Architecture	Software component which provides additional functions for the SINAMICS drive system
OAIF	Open Architecture Interface	Version of the SINAMICS firmware as of which the OA application can be used
OASP	Open Architecture Support Package	Expands the commissioning tool by the corresponding OA application
OC	Operating Condition	Operating condition
OCC	One Cable Connection	One-cable technology
OEM	Original Equipment Manufacturer	Original equipment manufacturer
OLP	Optical Link Plug	Bus connector for fiber-optic cable
OMI	Option Module Interface	Option Module Interface
Р		
p	-	Adjustable parameters
P1	Processor 1	CPU 1
P2	Processor 2	CPU 2
РВ	PROFIBUS	PROFIBUS
PcCtrl	PC Control	Master control
PD	PROFIdrive	PROFIdrive

Abbreviation	Derivation of abbreviation	Meaning
PDC	Precision Drive Control	Precision Drive Control
PDS	Power unit Data Set	Power unit data set
PDS	Power Drive System	Drive system
PE	Protective Earth	Protective ground
PELV	Protective Extra Low Voltage	Protective extra low voltage
PFH	Probability of dangerous failure per hour	Probability of dangerous failure per hour
PG	Programmiergerät	Programming device
PI	Proportional Integral	Proportional integral
PID	Proportional Integral Differential	Proportional integral differential
PLC	Programmable Logical Controller	Programmable logic controller
PLL	Phase-Locked Loop	Phase-locked loop
PM	Power Module	Power Module
PMI	Power Module Interface	Power Module Interface
PMSM	Permanent-magnet synchronous motor	
PN	PROFINET	Permanent-magnet synchronous motor PROFINET
		PROFIBUS user organization
PNO	PROFIBUS Nutzerorganisation	
PPI	Point to Point Interface	Point-to-point interface
PRBS	Pseudo Random Binary Signal	White noise
PROFIBUS	Process Field Bus	Serial data bus
PS	Power Supply	Power supply
PSA	Power Stack Adapter	Power Stack Adapter
PT1000	-	Temperature sensor
PTC	Positive Temperature Coefficient	Positive temperature coefficient
PTP	Point To Point	Point-to-point
PWM	Pulse Width Modulation	Pulse width modulation
PZD	Prozessdaten	Process data
Q		
R		
r	-	Display parameters (read-only)
RAM	Random Access Memory	Memory for reading and writing
RCCB	Residual Current Circuit Breaker	Residual current operated circuit breaker
RCD	Residual Current Device	Residual current device
RCM	Residual Current Monitor	Residual current monitor
REL	Reluctance motor textile	Reluctance motor textile
RESM	Reluctance synchronous motor	Synchronous reluctance motor
RFG	Ramp-Function Generator	Ramp-function generator
RJ45	Registered Jack 45	Term for an 8-pin socket system for data transmission with shielded or non-shielded multi-wire copper cables
RKA	Rückkühlanlage	Cooling unit
RLM	Renewable Line Module	Renewable Line Module
RO	Read Only	Read only
ROM	Read-Only Memory	Read-only memory
RPDO	Receive Process Data Object	Receive Process Data Object
RS232	Recommended Standard 232	Interface standard for cable-connected serial data transmission between a sender and receiver (also known as EIA232)

Abbreviation	Derivation of abbreviation	Meaning
RS485	Recommended Standard 485	Interface standard for a cable-connected differential, parallel, and/or serial bus system (data transmission between a number of senders and receivers, also known as EIA485)
RTC	Real Time Clock	Real-time clock
RZA	Raumzeigerapproximation	Space-vector approximation
S		·
S1	-	Continuous operation
S3	-	Intermittent duty
SAM	Safe Acceleration Monitor	Safe acceleration monitoring
SBC	Safe Brake Control	Safe brake control
SBH	Sicherer Betriebshalt	Safe operating stop
SBR	Safe Brake Ramp	Safe brake ramp monitoring
SBT	Safe Brake Test	Safe brake test
SCA	Safe Cam	Safe cam
SCC	Safety Control Channel	Safety Control Channel
SCSE	Single Channel Safety Encoder	Single-channel safety encoder
SD Card	SecureDigital Card	Secure digital memory card
SDC	Standard Drive Control	Standard Drive Control
SDI	Safe Direction	Safe motion direction
SE	Sicherer Software-Endschalter	Safe software limit switch
SESM	Separately-excited synchronous motor	Separately excited synchronous motor
SG	Sicher reduzierte Geschwindigkeit	Safely limited speed
SGA	Sicherheitsgerichteter Ausgang	Safety-related output
SGE	Sicherheitsgerichteter Eingang	Safety-related input
SH	Sicherer Halt	Safe stop
SI	Safety Integrated	Safety Integrated
SIC	Safety Info Channel	Safety Info Channel
SIL	Safety Integrity Level	Safety Integrity Level
SITOP	-	Siemens power supply system
SLA	Safely-Limited Acceleration	Safely limited acceleration
SLM	Smart Line Module	Smart Line Module
SLP	Safely-Limited Position	Safely Limited Position
SLS	Safely-Limited Speed	Safely limited speed
SLVC	Sensorless Vector Control	Sensorless vector control
SM	Sensor Module	Sensor Module
SMC	Sensor Module Cabinet	Sensor Module Cabinet
SME	Sensor Module External	Sensor Module External
SMI	SINAMICS Sensor Module Integrated	SINAMICS Sensor Module Integrated
SMM	Single Motor Module	Single Motor Module
SN	Sicherer Software-Nocken	Safe software cam
SOS	Safe Operating Stop	Safe operating stop
SP	Service Pack	Service pack
SP	Safe Position	Safe position
SPC	Setpoint Channel	Setpoint channel
SPI	Serial Peripheral Interface	Serial peripheral interface

Abbreviation	Derivation of abbreviation	Meaning
SPS	Speicherprogrammierbare Steuerung	Programmable logic controller
SS1	Safe Stop 1	Safe Stop 1 (time-monitored, ramp-monitored)
SS1E	Safe Stop 1 External	Safe Stop 1 with external stop
SS2	Safe Stop 2	Safe Stop 2
SS2E	Safe Stop 2 External	Safe Stop 2 with external stop
SSI	Synchronous Serial Interface	Synchronous serial interface
SSL	Secure Sockets Layer	Encryption protocol for secure data transfer (new TLS)
SSM	Safe Speed Monitor	Safe feedback from speed monitor
SSP	SINAMICS Support Package	SINAMICS support package
STO	Safe Torque Off	Safe torque off
STW	Steuerwort	Control word
T		
ТВ	Terminal Board	Terminal Board
TEC	Technology Extension	Software component which is installed as an additional technology package and which expands the functionality of SINAMICS (previously OA application)
TIA	Totally Integrated Automation	Totally Integrated Automation
TLS	Transport Layer Security	Encryption protocol for secure data transfer (previously SSL)
TM	Terminal Module	Terminal Module
TN	Terre Neutre	Grounded three-phase line supply
Tn	-	Integral time
TPDO	Transmit Process Data Object	Transmit Process Data Object
TSN	Time-Sensitive Networking	Time-Sensitive Networking
TT	Terre Terre	Grounded three-phase line supply
TTL	Transistor-Transistor-Logic	Transistor-transistor logic
Tv	-	Rate time
U		
UL	Underwriters Laboratories Inc.	Underwriters Laboratories Inc.
UPS	Uninterruptible Power Supply	Uninterruptible power supply
USV	Unterbrechungsfreie Stromversorgung	Uninterruptible power supply
UTC	Universal Time Coordinated	Universal time coordinated
V		
VC	Vector Control	Vector control
Vdc	-	DC link voltage
VdcN	-	Partial DC link voltage negative
VdcP	-	Partial DC link voltage positive
VDE	Verband Deutscher Elektrotechniker	Association of German Electrical Engineers
VDI	Verein Deutscher Ingenieure	Association of German Engineers
VPM	Voltage Protection Module	Voltage Protection Module
Vpp	Volt peak to peak	Volt peak to peak
VSM	Voltage Sensing Module	Voltage Sensing Module
W		, ,
WEA	Wiedereinschaltautomatik	Automatic restart
WZM	Werkzeugmaschine	Machine tool

Abbreviation	Derivation of abbreviation	Meaning
Х		
XML	Extensible Markup Language	Extensible markup language (standard language for Web publishing and document management)
Υ		
Z		
ZK	Zwischenkreis	DC link
ZM	Zero Mark	Zero mark
ZSW	Zustandswort	Status word

Index

11	C
"Siemens Industry Online Support" app, 13	Cabinet design and EMC, 425 Cable lugs, 551, 552 2 cable lugs per phase, 552
A	Back-to-back, 552
Active Infeed, 225 Active Infeed Chassis-2, 109 Active Interface Modules, 81 Dimension drawing, 95 Active Interface Modules Chassis-2, 108 Dimension drawing, 118 Installation, 119 Active Line Modules, 194, 224	Cleaning, 468 Connection dv/dt filter compact plus Voltage Peak Limiter, 410 dV/dt filter with voltage peak limiter, 390 Connection example Active Interface Modules, 88 Active Interface Modules Chassis-2, 112 Braking Module, 341 Control cabinet design
Dimension drawing, 210 Active Line Modules Chassis-2 Dimension drawing, 242 Duty cycle with maximum current, 258 Installation, 245 PE connections, 249 Shield connections, 250 Use in line supplies according to Standard IEC 61000-2-4, Class 2, 227 Use in weak line supplies, 227	Air conditioning, 431 Chassis, 444 Chassis-2 in Rittal TS8, 456 Chassis-2 in Rittal VX25, 445 Ventilation, 432 Control Interface Module Frame size FB, replacement, 508 Frame size FS2, replacing, 504 Frame size FS2+, replacing, 504 Frame size FS4+, replacing, 504 Frame size FS4+, replacing, 504
В	Frame size FX, replacement, 496 Frame size GX, replacement, 498
Basic Line Modules, 132 Dimension drawing, 145 Basic structure and regulated infeed, 48 and unregulated infeed, 50	Frame size dX, replacement, 490 Frame size HX, replacement, 500 Frame sizes JX, replacement, 502 Frame sizes GB, GD, replacement, 510 Correct and intended use, 19
with unregulated infeed / regenerative feedback, 49 Basic structure of a drive system with SINAMICS	D
S120, 48 Braking Module, 335 Braking resistor connection, 341 Installation, 345 S1 – Threshold switch, 343 X21 digital inputs/outputs, 342 Braking resistors, 359 Dimension drawing, 362	Date of manufacture, 547 DC fuses Frame size HX, replacement, 539 Frame size JX, replacement, 542 DC-link components Braking Module, 335 Braking resistors, 359 Derating factors Current derating as a function of the pulse frequency, 294, 331

Function of installation altitude and ambient	F
temperature, 43 Dimension drawing Active Interface Modules, 95 Active Interface Modules Chassis-2, 118 Active Line Modules, 210 Active Line Modules Chassis-2, 242 Basic Line Modules, 145 Braking resistors, 362 dV/dt filter compact plus voltage peak limiter, 413 dV/dt reactor, 393 Line filters for Active Line Modules, 62 Line filters for Basic Line Modules, 55 Line filters for Smart Line Modules, 62 Line reactors for Basic Line Modules, 68 Line reactors for Smart Line Modules, 74 Motor Modules, 274 Motor Modules Chassis-2, 313 Motor reactors, 376 Precharging resistor, 127, 153 Sine-wave filter, 370 Smart Line Modules, 178 Voltage peak limiter, 396 Disconnect the basic interference suppression module, 99, 122, 147, 181 Disposal, 550 dv/dt filter, 384 Interfaces, 388 dv/dt filter compact plus Voltage Peak Limiter, 403 Connection, 410 Interfaces, 408 dV/dt filter compact plus voltage peak limiter Dimension drawing, 413 dV/dt filter with voltage peak limiter Connection, 390	Fan Active Interface Module Chassis-2, replacement, 535 Frame size FI, replacement, 527 Frame size FS2, bearings, 545 Frame size FS2, replacing, 520 Frame size FS2+, replacing, 520 Frame size FS2+, storage, 545 Frame size FS4, replacing, 520 Frame size FS4, storage, 545 Frame size FS4+, replacing, 520 Frame size FS4+, replacing, 520 Frame size FS4+, storage, 545 Frame size FS4+, storage, 545 Frame size HI, replacement, 529 Frame size HI, replacement, 531 Frame size JI, replacement, 533 Frame size JX, replacement, 518 Frame sizes FR, GB, GD, replacement, 537 Frame sizes FX and GX, replacement, 512 Fan voltage Active Line Modules, 214 Basic Line Modules, 214 Basic Line Modules, 150 Motor Modules, 278 Smart Line Modules, 185 FAQs, 13 Forming the DC link capacitors, 546 Fundamental safety instructions SINAMICS hardware, 23 Fuse Fan (-F10/-F11), 544
dV/dt reactor Dimension drawing, 393	General Data Protection Regulation, 21
Electromagnetic fields, 26 Electronic fan Frame size FS2, replacing, 523 Frame size FS2+, replacing, 523 Frame size FS4, replacing, 523 Frame size FS4+, replacing, 523 Electrostatic sensitive devices, 29 EMC General information, 425	ID link, 13 Installation Active Interface Modules Chassis-2, 119 Active Line Modules Chassis-2, 245 Motor Modules Chassis-2, 316 Installation device, 470 Interfaces Active Interface Modules, 84 Active Interface Modules Chassis-2, 111 Basic Line Modules, 136 Braking Module, 338 dv/dt filter, 388 dv/dt filter compact plus Voltage Peak Limiter, 408 Smart Line Modules, 168

IT system, 99, 122, 147, 181	Shield connections, 321 Motor reactors, 372 Dimension drawing, 376
L LEDs Active Interface Modules, 94, 117 Active Line Modules, 209 Active Line Modules Chassis-2, 241 Basic Line Modules, 144 Motor Modules, 273 Motor Modules Chassis-2, 312 Smart Line Modules, 177 Line filters for Active Line Modules, 59 Dimension drawing, 62 Line filters for Basic Line Modules, 51 Dimension drawing, 55 Line filters for Smart Line Modules, 59 Dimension drawing, 62 Line Modules, 131 Active Line Modules, 194, 224 Basic Line Modules, 132 Smart Line Modules, 162 Line reactors for Basic Line Modules, 66 Dimension drawing, 68 Line reactors for Smart Line Modules, 72 Dimension drawing, 74 Line-side power components, 51 Active Interface Modules, 81 Active Interface Modules Chassis-2, 108 Line filters for Active Line Modules, 59 Line filters for Smart Line Modules, 59 Line filters for Smart Line Modules, 59 Line reactors for Basic Line Modules, 66 Line reactors for Smart Line Modules, 66 Line reactors for Smart Line Modules, 72 List of abbreviations, 553	Dimension drawing, 376 Motor-side power components, 367 dv/dt filter, 384 dv/dt filter compact plus Voltage Peak Limiter, 403 Motor reactors, 372 Sine-wave filters, 367 N Nameplate, 546 Non-grounded system, 99, 122, 147, 181 O Operation on a non-grounded system, 99, 122, 147, 181 Overload capability Basic Line Modules, 161 High overload, 161 Overload capability of Active Line Modules, 223 High overload, 223 Overload capability of the Motor Modules, 292 High overload, 293 Low overload, 293 Overload capability, Motor Modules Chassis-2, 328 High overload, 329 Low overload, 329 So duty cycle, 330 Overload capacity of Active Line Modules Chassis-2, 327
	2, 257 Low overload, 258 Overload reserve for Smart Line Modules, 193 High overload, 193
M	Р
Maintenance, 468, 469 Maintenance and servicing, 467 Maximum cable lengths, 427 Motor Modules, 259 Dimension drawing, 274 Minimum cable length, 296 Parallel connection, 296 Motor Modules Chassis-2, 298 Dimension drawing, 313 Installation, 316 Minimum cable length, 333 Parallel connection, 332 PE connections, 320	Parallel connection Motor Modules, 296 Motor Modules Chassis-2, 332 Power block Crane lifting lugs, 471 Frame size FB, replacement, 490 Frame size FX, replacement, 477 Frame size GX, replacement, 480 Frame size HX, replacement, 483 Frame size JX, replacement, 488 Frame sizes GB, GD, replacement, 493 Precharging circuit Active Line Modules Chassis-2, 124 Basic Line Modules, 151

Precharging resistor Dimension drawing, 127, 153	S
Emichation drawing, 127, 133	Safety information
	Braking Modules, 337 Braking resistors, 360
R	dV/dt filter compact plus voltage peak limiter, 405
Recycling, 550	Line reactors for Basic Line Modules, 66
Replacement	Line reactors for Smart Line Modules, 72
Automatic firmware update, 476	Motor reactors, 374
Control Interface Module, frame size FS2, 504	Sine-wave filter, 368
Control Interface Module, frame size FS2+, 504	Safety instructions
Control Interface Module, frame size FS4, 504	Active Interface Modules, 82, 109
Control Interface Module, frame size FS4+, 504	Active Line Modules, 197, 228
Control Interface Module, frame sizes GB, GD, 510	Basic Line Modules, 134
Crane lifting lugs, 471	Control cabinet design, 425
Electronic fan, frame size FS2, 523	dV/dt filter plus Voltage Peak Limiter, 386
Electronic fan, frame size FS2+, 523	Electromagnetic fields, 26
Electronic fan, frame size FS4, 523	Electrostatic sensitive devices, 29
Electronic fan, frame size FS4+, 523	EMC, 425
Error messages, 476	General safety instructions, 23
Fan, Active Interface Module Chassis-2, 535	Line filters for Active Line Modules, 59
Fan, frame size FS2, 520	Line filters for Basic Line Modules, 52
Fan, frame size FS2+, 520	Line filters for Smart Line Modules, 59
Fan, frame size FS4, 520	Maintenance and servicing, 467
Fan, frame size FS4+, 520	Motor Modules, 261, 300 Smart Line Modules, 165
Replacing Control Interface Module, frame size FB, 508	Siemens Industry Online Support, 16
Control Interface Module, frame size FX, 496	App, 13
Control Interface Module, frame size GX, 498	Sine-wave filter
Control Interface Module, frame size HX, 500	Dimension drawing, 370
Control Interface Module, frame size JX, 502	Sine-wave filters, 367
DC fuses, frame size HX, 539	Smart Line Modules, 162
DC fuses, frame size JX, 542	Dimension drawing, 178
Fan, frame size FI, 527	Standards, 45
Fan, frame size GI, 529	Storage
Fan, frame size HI, 531	Fan, frame size FS2, 545
Fan, frame size HX, 514	Fan, frame size FS2+, 545
Fan, frame size JX, 518, 533	Fan, frame size FS4, 545
Fan, frame sizes FB, GB, GD, 537	Fan, frame size FS4+, 545
Fan, frame sizes FX and GX, 512	System overview, 33
Installation device, 470	
Power block, frame size FB, 490	
Power block, frame size FX, 477	Т
Power block, frame size GX, 480	Technical data
Power block, frame size HX, 483	Active Interface Modules, 105
Power block, frame size JX, 488	Active Interface Modules Chassis-2, 129
Power block, frame sizes GB, GD, 493	Active Line Modules, 215
Replacing components, 476	Active Line Modules Chassis-2, 252
Residual risks, 31	Basic Line Modules, 154
	Braking Modules, 356
	Braking resistors, 364
	Derating factors, 43

dV/dt filter compact plus voltage peak limiter, 418 dv/dt filter plus Voltage Peak Limiter, 399, 400 General technical data, 40
Line filters for Active Line Modules, 65
Line filters for Basic Line Modules, 57
Line filters for Smart Line Modules, 65
Line reactors for Basic Line Modules, 70
Line reactors for Smart Line Modules, 80
Motor Modules, 279
Motor Modules Chassis-2, 323
Motor reactors, 380
Sine-wave filter, 371
Smart Line Modules, 187
Tightening torques, 469
Tool, 469

V

Voltage peak limiter Dimension drawing, 396

W

Web sites of third-party companies, 13

More information

Siemens:

www.siemens.com

Industry Online Support (service and support): www.siemens.com/online-support

IndustryMall:

www.siemens.com/industrymall